

# Power Grid Security Analysis : An Optimization Approach

by

Abhinav Verma

Submitted in partial fulfillment of the  
requirements for the degree  
of Doctor of Philosophy  
in the Graduate School of Arts and Sciences

COLUMBIA UNIVERSITY

2009

## ABSTRACT

Power Grid Security Analysis : An Optimization Approach

# Contents

<b>1</b>	<b>Introduction</b>	<b>1</b>
1.1	Previous work on vulnerability problems . . . . .	3
1.2	Our Contribution . . . . .	7
1.3	Review of Power Flow Models . . . . .	8
1.3.1	AC Power Flow Model . . . . .	8
1.3.2	Linear Power Flow Models . . . . .	11
1.4	Review of Basic Mathematics . . . . .	16
1.4.1	Network Flows . . . . .	16
1.4.2	Benders' Decomposition . . . . .	18
1.4.3	Lagrangians . . . . .	19
<b>2</b>	<b>The “N - k” problem</b>	<b>21</b>
2.1	Problem Definition . . . . .	23
2.1.1	Non-monotonicity . . . . .	30
2.1.2	Brief review of previous work . . . . .	33

2.2	An algorithm for the min-cardinality problem . . . . .	34
2.2.1	Discussion . . . . .	39
2.3	A better mixed-integer programming formulation . . . . .	41
2.3.1	Setting <b>M</b> . . . . .	48
2.3.2	Tightening the formulation . . . . .	50
2.3.3	Strengthening the Benders cuts . . . . .	52
2.4	Implementation details . . . . .	55
2.5	Computational experiments the with min-cardinality model . . . . .	56
2.5.1	Data sets . . . . .	56
2.5.2	Goals of the experiments . . . . .	58
2.5.3	Results . . . . .	58
2.5.4	Comparison with pure enumeration . . . . .	65
2.5.5	One configuration problems . . . . .	67
<b>3</b>	<b>A continuous, nonlinear attack problem</b>	<b>69</b>
3.1	Solution methodology . . . . .	73
3.1.1	Some comments . . . . .	75
3.1.2	Laplacians . . . . .	77
3.1.3	Observations . . . . .	80
3.2	Relationship to the standard N-k problem . . . . .	82
3.3	Efficient computation of the gradient and Hessian . . . . .	84

3.4	Implementation details . . . . .	87
3.5	Experiments . . . . .	90
3.5.1	Data sets . . . . .	90
3.5.2	Focus of the experiments . . . . .	91
3.5.3	Basic run behavior . . . . .	91
3.5.4	Alternative starting points . . . . .	99
3.5.5	Distribution of attack weights . . . . .	101
3.5.6	Comparison with the minimum-cardinality attack model . . . . .	103
<b>4</b>	<b>Nonlinear Flow Model</b>	<b>109</b>
4.1	Introduction . . . . .	110
4.2	Model Description . . . . .	112
4.3	Throughput maximization . . . . .	116
4.4	Linear Programming Approximation . . . . .	122
4.5	Computational Results . . . . .	125
4.6	Capacitated Nonlinear Flow Model . . . . .	127
4.6.1	Model Description . . . . .	128
<b>5</b>	<b>NP-completeness proof</b>	<b>134</b>
5.1	Proof of Theorem 4.6.2 . . . . .	134

# List of Figures

2.1	A simple example. . . . .	27
2.2	Non-monotone example. . . . .	31
3.1	Primal values approaching termination. . . . .	100
4.1	Non-monotone example. . . . .	132
4.2	Flow on arc (1, 2) v Throughput. . . . .	132
5.1	“Banana” network. . . . .	135
5.2	“Variable” network. . . . .	137
5.3	“Clause” network. . . . .	138
5.4	Linking Arcs. . . . .	139

# List of Tables

2.1	<i>Min-cardinality problem, 57-bus test case</i>	59
2.2	<i>Min-cardinality problem, 118-bus test case</i>	60
2.3	<i>Min-cardinality problem, small network</i>	62
2.4	<i>Min-cardinality problem, larger network</i>	64
2.5	<i>Pure enumeration, 98 nodes 204 arcs</i>	66
2.6	<i>49 nodes, 84 arcs, one configuration</i>	67
3.1	<i>57 nodes, 78 arcs, <math>\Gamma(2)</math></i>	93
3.2	<i>118 nodes, 186 arcs, <math>\Gamma(2)</math></i>	94
3.3	<i>49 nodes, 84 arcs, constraint set <math>\Gamma(1)</math></i>	95
3.4	<i>49 nodes, 84 arcs, constraint set <math>\Gamma(2)</math></i>	96
3.5	<i>300 nodes, 409 arcs, constraint set <math>\Gamma(2)</math></i>	97
3.6	<i>600 nodes, 990 arcs, constraint set <math>\Gamma(2)</math></i>	98
3.7	<i>649 nodes, 1368 arcs, <math>\Gamma(2)</math></i>	99
3.8	<i>Impact of changing the starting point</i>	101

<b>3.9 Solution histogram</b> . . . . .	102
<b>3.10 Comparison between models</b> . . . . .	107
<b>4.1 Computational Results</b> . . . . .	128

## ACKNOWLEDGMENTS

# Chapter 1

## Introduction

Recent large-scale power grid failures have highlighted the need for effective computational tools for analyzing vulnerabilities of electrical transmission networks. Blackouts are extremely rare, but their consequences can be severe. Recent blackouts had, as their root cause, an exogenous damaging event (such as a storm) which developed into a system collapse even though the initial quantity of disabled power lines was *small*.

As a recent example, the August 14, 2003 blackout in the northeast of the U.S. resulted in a loss of estimated 61.8 GW of electric load and affected 50 million people [35]. The cost associated with this blackout was about \$6 billion as estimated by the U.S. Department of Energy (DOE) [36]. While many factors contributed to the prevailing operating conditions on that afternoon, just *three* transmission lines that underwent faults and subsequent outages in relatively short succession initiated the

blackout process. These line outages irreversibly overloaded the system and resulted in a very fast and dramatic blackout.

As a result, a problem that has gathered increasing importance is what might be termed the *vulnerability evaluation* problem: given a power grid, is there a small set of power lines whose removal will lead to system failure? Here, “smallness” is parameterized by an integer  $k$ , and indeed experts have called for small values of  $k$  (such as  $k = 3$  or  $4$ ) in the analysis. Additionally, an explicit goal in the formulation of the problem is that the analysis should be agnostic: we are interested in rooting out small, “hidden” vulnerabilities of a complex system which is otherwise quite robust; as much as possible the search for such vulnerabilities should be devoid of assumptions regarding their structure. This problem is not new, and researchers have used a variety of names for it: network *interdiction*, network *inhibition* and so on, although the “N - k problem” terminology is common in the industry (where “N” is the number of arcs). We will provide a more complete review of the (rather extensive) literature later on; the core central theme is that the  $N - k$  problem is very highly intractable, even for small values of  $k$  – the pure enumeration approach is simply impractical. In addition to the combinatorial explosion, another significant difficulty is the need to model the laws of physics governing power flows in a sufficiently accurate and yet computationally tractable manner: power flows are much more complex than “flows” in traditional applications.

A critique that has been leveled against optimization-based approaches to the

$N - k$  problem is that they tend to focus on large values of  $k$ , say  $k = 8$ . When  $k$  is large the problem tends to become easier, but on the other hand the argument can be made that the cardinality of the attack is unrealistically large. At the other end of the spectrum lies the case  $k = 1$ , which can be addressed by enumeration but may not yield useful information. The middle range,  $2 \leq k \leq 5$ , is both relevant and difficult, and is our primary focus.

## 1.1 Previous work on vulnerability problems

There is a large amount of prior work on optimization methods applied to blackout-related problems. Typically work has focused on identifying a small set of arcs whose removal (to model complete failure) will result in a network unable to deliver a minimum amount of demand. A problem of this type can be solved using mixed-integer programming techniques. Generally speaking, the mixed-integer programs to be solved can prove quite challenging.

Salmeron, Wood, and Baldick [4] employed a linearized power flow model and used a bilevel optimization framework along with mixed-integer programming to analyze the security of the electric grid. The critical elements of the grid were identified by maximizing the long-term disruption in the power system operation. The bilevel optimization framework has also been used by Arroyo and Galiana [6] and Alvarez [5].

Bilevel programming problem can be viewed as a static version of the noncooperative two-person game introduced by Von Stackelberg [34] in the context of unbalanced economic markets. In the basic model, control of the decision variables is partitioned amongst the players who seek to optimize their individual payoff functions. Perfect information is assumed so that both players know the objective and feasible choices available to the other. The fact that the game is said to be 'static' implies that each player has only one move. The *leader* goes first and attempts to minimize net costs. In doing so, he must anticipate all possible responses of his opponent, termed the 'follower'. The follower observes the leader's decision and reacts in a way that is personally optimal without regard to extramural effects. Because the set of feasible choices available to either player is interdependent, the leader's decision affects both the follower's payoff and allowable actions, and vice versa. Bard [33] gives a detailed account of the theory and practical algorithms for bilevel optimization problems.

A different line of research on vulnerability problems focuses on attacks with certain structural properties. An example of this approach is used in Pinar et. al. [8]. Here, as an approximation to the  $N - k$  problem in the "lossless" power flow model (see Chapter 4 for a detailed discussion of "lossless" power flow model), the authors formulate a linear mixed-integer program to solve the following combinatorial problem: remove a minimum number of arcs, such that in the resulting network there

is a partition of the nodes into two sets,  $N_1$  and  $N_2$ , such that

$$D(N_1) + G(N_2) + \text{cap}(N_1, N_2) \leq Q^{\min}.$$

Here  $D(N_1)$  is the total demand in  $N_1$ ,  $G(N_2)$  is the total generation capacity in  $N_2$ ,  $\text{cap}(N_1, N_2)$  is the total capacity in the (non-removed) arcs between  $N_1$  and  $N_2$ , and  $Q^{\min}$  is a minimum amount of demand that needs to be satisfied. The quantity in the left-hand side in the above expression is an upper-bound on the total amount of demand that can be satisfied – the upper-bound can be strict because under power flow laws it may not be attained.

Thus this is an approximate model that could underestimate the effect of an attack (i.e. the algorithm may produce attacks larger than strictly necessary). On the other hand, methods of this type bring to bear powerful mathematical tools, and thus can handle larger problems than algorithms that rely on generic mixed-integer programming techniques.

Another example of the same approach is used in Lesieutre et.al. [11],[12]. Here, the authors approached this problem from a graph theoretical perspective, by looking for subgraphs in a given graph that are loosely connected to the rest of the graph and have a significant load/generation mismatch. Our method in Chapter 3 can also be viewed as an example of this approach.

There is also a significant literature on network reinforcement problem. In these problems there is a fixed set of scenarios and in each scenario a subset of edges is

deleted. The objective is to add to the network a minimum-cost set of power lines (edges), so that in each scenario the power flow in every edge is within its capacity. Bienstock and Mattia [7] used the direct current power flow model and mixed integer linear programming to find the most cost-effective way to increase edge capacities to avoid cascading outages for a given set of failure scenarios. Oliviera et al. [32] have used similar models and techniques to study how to add power lines to improve system resilience.

Finally, in addition to these largely static analysis, system dynamics for cascading events has also drawn a lot of interest. In [26]-[28], Dobson et al. used a long-term model of the grid to study how failure of a component affects other components in the system, to reveal failure statistics consistent with those observed in the power grid. The same authors have also studied probabilistic models with the aim to better understand cascade propagation [29]-[31]. Bienstock and Mattia [7] consider network reinforcement problem in a model which considers the dynamics of a cascade in a multistage fashion. These models for behavior of a grid under stress are much sophisticated which attempt to capture the multistage nature of blackouts, and are thus more comprehensive than the static models considered above and in this thesis.

## 1.2 Our Contribution

In this thesis we take an approach based on strict optimization. First we look at  $N - k$  problem where we present results using two models. The first (Chapter 2.2) is a new linear mixed-integer programming formulation that explicitly models a “game” between a fictional attacker seeking to disable the network, and a controller who tries to prevent a collapse by selecting which generators to operate and adjusting generator outputs and demand levels. As far as we can tell, the problem we consider here is more general than has been previously studied in the literature; nevertheless our approach yields practicable solution times for larger instances than previously studied.

The second model (Chapter 3) is given by a new, continuous nonlinear programming formulation whose goal is to capture, in a compact way, the interaction between the underlying physics and the network structure. While both formulations provide substantial savings over the pure enumerational approach, the second formulation appears particularly effective and scalable; enabling us to handle in an optimization framework models an order of magnitude larger than those we have seen in the literature.

In Chapter 4 we study some properties of the so-called “lossless” flow model. The “lossless” flow model can be viewed as a refinement to the linearized power flow model. We look at the throughput maximization problem (operate network so as to satisfy maximum demand) for both capacitated and uncapacitated case. We present

efficient algorithms for the uncapacitated version of the problem and prove that the capacitated version is NP-hard. As far as we can tell, the properties of the “lossless” flow model and the throughput maximization problem have not been studied formally in literature before.

## 1.3 Review of Power Flow Models

In this section we review power flow models, with special emphasis on the widely used linear or **DC** power flow model.

### 1.3.1 AC Power Flow Model

For general background on power networks we refer the reader to [3]. Broadly speaking, a power grid is made up of three components: generation, transmission and distribution. At one end of the grid there are the generators (power units) that produce power at relatively high voltage. At the other end is consumption, primarily in metropolitan areas. There, power is conveyed at fairly low voltages by means of (relatively) simple sub-networks known as distribution networks. Between generation and consumption lies the transmission network, whose purpose it to convey power from one to the other. Transmission networks operate at fairly high voltages (for efficiency); both generators and distribution networks are connected to transmission networks by means of transformers.

For a number of economic and political reasons, modern transmission networks are large and complex, spanning great distances and conveying power from many generators to many metropolitan areas located far away. The reader familiar with e.g. telecommunication networks may expect that one can control how power flows in a network. In fact, this is actually not true - power flows according to the laws of physics and one can only indirectly in consequence this flow.

A power system is predominantly in steady state operation or in a state that could with sufficient accuracy be regarded as steady state. In a power system there are always small load changes, switching actions, and other transients occurring so that in a strict mathematical sense most of the variables are time dependent. However, these variations are (most of the time) so small that an algebraic, i.e. not time varying model of the power system is justified. For the purpose of this study, we will only look at power system in steady state.

Steady state power flows are usually studied using the so-called AC flow model. (For convenience we will usually use the standard node, edge graph-theoretic terminology, although we will sometimes use the term “line” to refer to an edge). In this model, the voltage at a node  $k$  of the network is represented by a complex number,  $U_k e^{j\theta_k}$ , where  $j = \sqrt{-1}$  and  $\theta_k$  is the angle at  $k$ . The power flowing from  $k$  to  $q$  along the (undirected) edge  $\{k, q\}$  depends on known parameters  $g_{kq}; b_{kq}; b_{kq}^{sh}$  and is

expressed as  $f_{kq} + jq_{kq}$ , where

$$f_{kq} = U_k^2 g_{kq} - U_k U_q g_{kq} \cos \theta_{kq} - U_k U_q b_{kq} \sin \theta_{kq} \quad (1.1)$$

$$q_{kq} = -U_k^2 (b_{kq} + b_{kq}^{sh}) + U_k U_q b_{kq} \cos \theta_{kq} - U_k U_q g_{kq} \sin \theta_{kq} \quad (1.2)$$

$$\theta_{kq} \doteq \theta_k - \theta_q \quad (1.3)$$

The quantity  $f_{kq}$  is called the active power flow,  $q_{kq}$  is the reactive power flow. Both quantities have concrete physical interpretations, and can take negative values. Note that this model permits that e.g.  $f_{qk} \neq -f_{kq}$ . At a node  $k$  of the network, the net power injected into the network at  $k$  is (approximately) given by the complex number  $P_k + jQ_k$ , where

$$P_k = \sum_{kq} f_{kq} \quad (\text{net active power leaving } k) \quad (1.4)$$

$$Q_k = \sum_{kq} q_{kq} \quad (\text{net reactive power leaving } k) \quad (1.5)$$

These are standard network flow conservation constraints - we stress that in both of them there is a term for each edge incident with node  $k$ . If  $k$  is a generator node, then  $P_k \geq 0$ ; in general at a generator node there will be a constraint of the form

$$P_k^{min} \leq P_k \leq P_k^{max}$$

and similar bounds for the reactive power at  $k$ . If  $k$  is a load (demand) node,  $P_k < 0$ ; at any point in time this represents the negative of the demand at  $k$ . If  $k$  is neither a generator nor a demand node, then  $P_k = Q_k = 0$ .

The model given by constraints (1.1)-(1.5) provides a fairly accurate approximation of the steady state behavior of a power grid. Nevertheless, it suffers from two shortcomings: First, it can be expensive to solve, and second, the system may have multiple solutions (the solution set may be discrete; less frequently, the system may even be infeasible). Partly in order to remedy the second difficulty, the most popular approaches to computing **AC** power flows rely on iterative methods, which require an initial “guess” of the solution. Such a guess is relatively easy to arrive at when one is familiar with the network being solved but not so if the network is in an unusual configuration; an incorrect guess can lead to convergence to the “wrong” solution. Human input in this loop is frequently used. Among the popular iterative methods used are Gauss-Seidel iterative method and the Newton-Raphson method. For a detailed review of these methods we refer the interested reader to [3].

### 1.3.2 Linear Power Flow Models

In order to bypass the shortcomings of the **AC** power flow model, and primarily the speed issue, a linear model is frequently used. This is the so-called **DC** flow model, which relies on some estimations, primarily that  $\theta_{kq} \approx 0$  for each edge  $\{k, q\}$  and  $U_k \approx 1$  for any node  $k$ . The (approximate) active power constraint (1.1) becomes

$$-x_{kq}f_{kq} + \theta_k - \theta_q = 0 \quad \text{for all } \{k, q\} \quad (1.6)$$

where  $x_{kq} \doteq -\frac{1}{b_{kq}}$  is the series resistance. This equation is analogous to Ohms law

applied to a resistor carrying a dc current:

- $f_{kq}$  is the dc current
- $\theta_k$  and  $\theta_q$  are the dc voltages at resistor terminals
- $x_{kq}$  is the resistance for edge  $\{k, q\}$ .

Also note that because of (1.6), we have  $f_{qk} = -f_{kq}$  for each edge  $\{k, q\}$ , in other words the two equations (1.6) corresponding to  $\{k, q\}$  are equivalent. Alternatively, we can view the network as directed, and use a negative flow value to indicate flow in the direction of the reversed edge.

When analyzing a power network, there is an additional, critical, operational requirement. For each edge  $\{k, q\}$  there is a “capacity”  $u_{kq}$ , representing a thermal limit. In the DC ow model, we should have  $|f_{kq}| \leq u_{kq}$ . This (or the appropriate statement in the **AC** flow model) is not a constraint that enters into the solution procedure - the power flow values are determined by the physics of the network, whereas the capacity constraint is simply a desirable outcome. Should an edge exceed its capacity, then eventually it will burn up (how long this takes depends on the overload) but normally protection equipment will disconnect the edge when the failure point is approached. We stress that a small overload is tolerable and that the protection equipment will not act immediately in such a case. Note: we will use the term “capacity” because of its familiar interpretation in optimization.

From the description above, it is evident that the *DC* power flow model is a rather parsimonious description of the underlying *AC* power flow model (1.1)-(1.5). We would like to *stress* that the use of *DC* power flow model is very popular in literature even when it is not clearly justified.

Finally we summarize the *linearized*, or *DC* power flow model, which we will use for the most part in this thesis: We represent power grid by a directed network  $\mathcal{N}$ , where:

- Each node corresponds to a “generator” (i.e., a supply node), or to a “load” (i.e., a demand node), or to a node that neither generates nor consumes power.
- If node  $i$  corresponds to a generator, then there are values  $0 \leq P_i^{min} \leq P_i^{max}$ . If the generator is operated, then its output must be in the range  $[P_i^{min}, P_i^{max}]$ ; if the generator is not operated, then its output is zero. In general, we expect  $P_i^{min} > 0$ . We denote by  $\mathcal{C}$  the set of generator nodes.
- If node  $i$  corresponds to a demand, then there is a value  $D_i^{nom}$  (the “nominal” demand value at node  $i$ ). We will denote the set of demands by  $\mathcal{D}$ .
- The arcs of  $\mathcal{N}$  represent power lines. For each arc  $(i, j)$ , we are given a parameter  $x_{ij} > 0$  (the resistance) and a parameter  $u_{ij}$  (the capacity).

Given a set  $\mathcal{C}$  of operating generators, a *power flow* is a solution to the system of constraints given next. In this system, for each arc  $(i, j)$ , we use a variable  $f_{ij}$  to

represent the (power) flow on  $(i, j)$  – possibly  $f_{ij} < 0$ , in which case power is effectively flowing from  $j$  to  $i$ . In addition, for each node  $i$  we will have a variable  $\theta_i$  (the “phase angle” at  $i$ ). Finally, if  $i$  is a generator node, then we will have a variable  $P_i$ , while if  $i$  represents a demand node, we will have a variable  $D_i$ . The constraints are:

$$\sum_{(i,j) \in \delta^+(i)} f_{ij} - \sum_{(j,i) \in \delta^-(i)} f_{ji} = \begin{cases} P_i & i \in \mathcal{C} \\ -D_i & i \in \mathcal{D} \\ 0 & \text{otherwise} \end{cases} \quad (1.7)$$

$$\theta_i - \theta_j - x_{ij} f_{ij} = 0 \quad \forall (i, j) \quad (1.8)$$

$$|f_{ij}| \leq u_{ij}, \quad \forall (i, j) \quad (1.9)$$

$$P_i^{\min} \leq P_i \leq P_i^{\max} \quad \forall i \in \mathcal{C} \quad (1.10)$$

$$0 \leq D_j \leq D_j^{\text{nom}} \quad \forall j \in \mathcal{D} \quad (1.11)$$

We will denote this system by  $\mathbf{P}(\mathcal{N}, \mathcal{C})$ . Constraint (1.7) models flow conservation, while (1.10) and (1.11) describe generator and demand node bounds. Optionally, one may impose additional constraints, in particular bounds on the  $\theta_i$  or on the quantities  $|\theta_i - \theta_j|$  (over the arcs  $(i, j)$ ).

### Basic results

A useful property satisfied by the linearized model is given by the following result.

**Lemma 1.3.1** *Let  $\mathcal{C}$  be given, and suppose  $\mathcal{N}$  is connected. Then for any choice of*

nonnegative values  $P_i$  (for  $i \in \mathcal{C}$ ) and  $D_i$  (for  $i \in \mathcal{D}$ ) such that

$$\sum_{i \in \mathcal{C}} P_i = \sum_{i \in \mathcal{D}} D_i, \quad (1.12)$$

system (1.7)-(1.8) has a unique solution in the  $f_{ij}$ ; thus, the solution is also unique in the  $\theta_i - \theta_j$  (over the arcs  $(i, j)$ ).

*Proof.* Let  $N$  denote the node-arc incidence of the network [1], let  $b$  be the vector with an entry for each node, where  $b_i = P_i$  for  $i \in \mathcal{C}$ ,  $b_i = -D_i$  for  $i \in \mathcal{D}$ , and  $b_i = 0$  otherwise. Writing  $X$  for the diagonal matrix with entries  $x_{ij}$ , then (1.7)-(1.8) can be summarized as

$$Nf = b, \quad (1.13)$$

$$N^T\theta - Xf = 0. \quad (1.14)$$

Pick an arbitrary node  $v$ ; then system (1.13-1.14) has a solution iff it has one with  $\theta_v = 0$ . As is well-known,  $N$  does not have full row rank, but writing  $\bar{N}$  for the submatrix of  $N$  with the row corresponding to  $v$  omitted then the connectivity assumption implies that  $\bar{N}$  does have full row rank [1]. In summary, writing  $\bar{b}$  for the corresponding subvector of  $b$ , we have that (1.13-1.14) has a solution iff

$$\bar{N}f = \bar{b}, \quad (1.15)$$

$$\bar{N}^T\eta - Xf = 0. \quad (1.16)$$

where the vector  $\eta$  has an entry for every node other than  $v$ . Here, (1.16) implies  $f = X^{-1}\bar{N}^T\eta$ , and so (1.15) implies that  $\eta = (\bar{N}X^{-1}\bar{N}^T)^{-1}\bar{b}$  (where the matrix is

invertible since  $\bar{N}$  has full row rank). Consequently,  $f = X^{-1}\bar{N}^T(\bar{N}X^{-1}\bar{N}^T)^{-1}\bar{b}$ . ■

**Remark 1.3.2** *We stress that Lemma 1.3.1 concerns the subsystem of  $P(\mathcal{N}, \mathcal{C})$  consisting of (1.7) and (1.8). In particular, the “capacities”  $u_{ij}$  play no role in the determination of solutions.*

When the network is not connected Lemma 1.3.1 can be extended by requiring that (1.12) hold for each component.

**Definition 1.3.3** *Let  $(f, \theta, P, D)$  be feasible a solution to  $P(\mathcal{N}, \mathcal{C})$ . The **throughput** of  $(f, \theta, P, D)$  is defined as*

$$\frac{\sum_{i \in \mathcal{D}} D_i}{\sum_{i \in \mathcal{D}} D_i^{nom}}. \quad (1.17)$$

*The throughput of  $\mathcal{N}$  is the maximum throughput of any feasible solution to  $P(\mathcal{N}, \mathcal{C})$ .*

## 1.4 Review of Basic Mathematics

In this section we present some background on some basic mathematical concepts and notations that we have used throughout the thesis.

### 1.4.1 Network Flows

For general background on network flows we refer the reader to [1]. Matrix representations of graphs have long been used to apply algebraic techniques to analyze

graphs. Here we review the node-arc incidence matrix and the Laplacian matrix, as two of the commonly used representations for graphs. The node-arc incidence matrix of a graph is used in flow problems, and we will use this representation to present power flow equations. The Laplacian matrix for graphs, on the other hand, underlies spectral graph theory, which can be used to analyze the connectedness of graphs.

Let  $G = (V, E)$  be a directed network defined by a set  $V$  of  $n$  nodes and a set  $E$  of  $m$  *directed arcs*. We use  $(i, j)$  to denote an edge that goes from vertex  $i$  to vertex  $j$ . We define the node-arc incidence matrix,  $N$ , of this graph as an  $n \times m$  matrix, where the  $k^{\text{th}}$  row of  $N$  represents the vertex  $k$ , and the  $l^{\text{th}}$  column represents the  $l^{\text{th}}$  edge,  $(i, j)$  between nodes  $i$  and  $j$ . Each column has only two non-zeros at the rows that represent the end vertices of the respective edge. The entry is  $-1$  or  $1$ , depending on whether the respective edge is directed from or to the corresponding vertex, respectively.

We will say that two nodes  $i$  and  $j$  are *connected* if the graph contains at least one path from node  $i$  to node  $j$ . A graph is connected if every pair of its nodes is connected; otherwise the graph is *disconnected*.

Next we turn our attention to defining Laplacians of graphs. The interested reader is referred to [24] for more detailed material. We have a directed network  $G$  with  $n$  nodes and  $m$  arcs and with node-arc incidence matrix  $N$ . We assume  $G$  is connected.

For a positive diagonal matrix  $Y \in \mathcal{R}^{m \times m}$  we will write

$$L = NYN^T, \quad J = L + \frac{1}{n} \mathbf{1}\mathbf{1}^T. \quad (1.18)$$

where  $\mathbf{1} \in \mathcal{R}^n$  is the vector  $(1, 1, \dots, 1)^T$ .  $L$  is called a *generalized Laplacian*. We have that  $L$  is symmetric positive-semidefinite. If  $\lambda_1 \leq \lambda_2 \leq \dots \leq \lambda_n$  are the eigenvalues of  $L$ , and  $v^1, v^2, \dots, v^n$  are the corresponding unit-norm eigenvectors, then

$$\lambda_1 = 0, \quad \text{but } \lambda_i > 0 \quad \text{for } i > 1, \quad (1.19)$$

because  $G$  is connected, and thus  $L$  has rank  $n - 1$ . The same argument shows that since  $N\mathbf{1} = 0$ , we can assume  $v^1 = n^{-1/2} \mathbf{1}$ . Finally, since different eigenvectors are orthogonal, we have  $\mathbf{1}^T v^i = 0$  for  $2 \leq i \leq n$ .

### 1.4.2 Benders' Decomposition

The well known Benders' decomposition technique [13] is based on the idea of exploiting decomposable structure present in the formulation of a given problem so that its solution can be obtained from the solution of several smaller sub-problems. One is the *follower* problem which is obtained by fixing a number of decision variables of the initial problem to a feasible value. The second problem is the restricted *master* problem which is expected to provide the optimal solution after several iterations. At each iteration a cut or (several) cuts are added to the *master* problem. The cuts are deduced from the solution of the follower problem in each iteration of the algorithm.

In each iteration, cuts are appended to restricted master problem which is solved again to optimality.

One can generally prove that Benders' decomposition terminates in a finite number of iterations, though the number of iterations can be exponential. Benders' decomposition methods can be viewed as a special case of cutting-plane methods. As is the case for cutting-plane methods for combinatorial optimization, there is no adequate general theory to explain why Benders' decomposition, when adequately implemented, tends to converge in few iterations.

Benders' decomposition algorithms have long enjoyed popularity in many contexts. In the case of stochastic programming with large number of scenarios, they prove essential in that they effectively reduce a massively large continuous problem into a number of much smaller independent problems. In the context of non-convex optimization the appeal of decomposition is that it vastly reduces combinatorial complexity.

### 1.4.3 Lagrangians

For a comprehensive discussion on Lagrangian duality see [2]. In mathematical programming, the method of Lagrangian duality provides a construction for finding the minimum of a function subject to constraints. The basic idea in Lagrangian duality is to take the constraints into account by augmenting the objective function with a weighted sum of the constraint functions.

One can use Lagrangian duality to derive the *dual* problem to any mathematical program. The *dual* problem is *always* a convex optimization problem (i.e. minimizing a convex function over a convex set) and thus is generally easier than the original problem, both in terms of computational effort and optimality guarantees.

In the case of a convex optimization problem (subject to appropriate regularity constraints) there is “strong duality”, i.e. the value of the original problem and the value of the dual are the same. Strong duality does not, in general, hold for non-convex optimization problems, in which case the dual merely provides a bound (a lower bound in the case of a minimization problem). The non-zero gap between the objective values of the original problem and its dual is known as the “duality gap”.

## Chapter 2

### The “N - k” problem

In this chapter we present our algorithm for the  $N - k$  problem as applicable to the linearized power flow model.

As discussed in the previous chapter, the linearized power flow model is an approximation to the AC power flow model which describes the steady state dynamics of the power network. The issue of whether to use the more exact nonlinear formulation, or the approximate DC formulation, is rather thorny. On the one hand, the linearized formulation certainly is an approximation only. On the other hand, the AC formulation can prove intractable or otherwise inappropriate (e.g. the formulation may have multiple solutions), and, we stress, is *itself* in any case an approximate model of the underlying physics.

For these reasons, studies that require multiple power flow computations tend to rely on the linearized formulation. This will be the approach we take in this thesis,

though some of our techniques extend directly to the AC model. An approach such as ours can therefore be criticized because it relies on an ostensibly approximate model; on the other hand we are able to focus more explicitly on the basic combinatorial complexity that underlies the  $N - k$  problem. In contrast, an approach that uses the AC model would have a better representation of the physics, but at the cost of not being able to tackle the combinatorial complexity quite as effectively, for the simple reason that the theory and computational machinery for linear programming are far more mature, effective *and* scalable than those for nonlinear, nonconvex optimization. In summary, both approaches present limitations and benefits. In this thesis, our bias is toward explicitly handling the combinatorial nature of the problem.

A final point that we would like to stress is that whether we use the AC or DC power flow model, the resulting problems have a far more complex structure than (say) traditional single- or multi-commodity flow models because of side-constraints such as (1.8). Constraints of this type give rise to counter-intuitive behavior reminiscent of Braess’s Paradox [14].

The model we consider in this section can be further enriched by including many other real-life constraints. For example, when considering the response to a contingency one could insist that demand be curtailed in a (geographically) even-handed pattern, and not in an aggregate fashion, as we do below and has been done in the literature. Or we could impose upper bounds on the number of stand-by power units that are turned on in the event of a contingency (and this itself could have a ge-

ographical perspective). Many such realistic features suggest themselves and could give rise to interesting extensions to the problem we consider here.

## 2.1 Problem Definition

We begin by formally defining the  $N - k$  problem : Let  $\mathcal{N}$  be a network with  $n$  nodes and  $m$  arcs representing a power grid. We denote the set of arcs by  $E$  and the set of nodes by  $V$ . A fictional *attacker* wants to remove a small number of arcs from  $\mathcal{N}$  in order to maximize damage. Somewhat informally (and, as it turns out, incompletely), the goal of the attacker is that in the resulting network all feasible flows should have low throughput. At the same time, a *controller* is operating the network; the controller responds to an attack by appropriately choosing the set  $\mathcal{C}$  of operating generators, their output levels, and the demands  $D_i$ , so as to feasibly obtain high throughput.

Thus, the attacker seeks to defeat *all possible courses of action* by the controller, in other words, we are modeling the problem as a Stackelberg game between the attacker and the controller, where the attacker moves first. To cast this in a precise way we will use the following definition. We let  $0 \leq T^{min} \leq 1$  be a given value.

**Definition 2.1.1** *Given a network  $\mathcal{N}$ ,*

- *An **attack**  $\mathcal{A}$  is a set of arcs removed by the attacker.*

- Given an attack  $\mathcal{A}$ , the **surviving network**  $\mathcal{N} - \mathcal{A}$  is the subnetwork of  $\mathcal{N}$  consisting of the arcs not removed by the attacker.
- A **configuration** is a set  $\mathcal{C}$  of generators.
- We say that an attack  $\mathcal{A}$  **defeats** a configuration  $\mathcal{C}$ , if either (a) the maximum throughput of any feasible solution to  $\mathbf{P}(\mathcal{N} - \mathcal{A}, \mathcal{C})$  is strictly less than  $T^{min}$ , or (b) no feasible solution to  $\mathbf{P}(\mathcal{N} - \mathcal{A}, \mathcal{C})$  exists. Otherwise we say that  $\mathcal{C}$  **defeats**  $\mathcal{A}$ .
- We say that an attack is **successful**, if it defeats **every** configuration.
- The **min-cardinality attack problem** consists in finding a successful attack  $\mathcal{A}$  with  $|\mathcal{A}|$  minimum.

Our primary focus will be on the min-cardinality attack problem. Before proceeding further we would like to comment on our model, specifically on the parameter  $T^{min}$ . In a practical use of the model, one would wish to experiment with different values for  $T^{min}$  – for the simple reason that an attack  $\mathcal{A}$  which is not successful for a given choice for  $T^{min}$  could well be successful for a slightly larger value; e.g. no attack or cardinality 3 or less exists that reduces demand by 31%, and yet there exists an attack of cardinality 3 that reduces satisfied demand by 30%. In other words, the minimum cardinality of a successful attack could vary substantially as a function of  $T^{min}$ .

Given this fact, *it might appear* that a better approach to the power grid vulnerability problem would be to leave out the parameter  $T^{min}$  entirely, and instead redefine the problem to that of finding a set of  $k$  or fewer arcs to remove, so that the resulting network has minimum throughput (here,  $k$  is given). We will refer to this as the *budget- $k$  min-throughput problem*. However, there are reasons why this latter problem is less attractive than the min-cardinality problem.

- (a) Clearly, in a sense, the min-cardinality and min-throughput problems are duals of each other. A modeler considering the min-throughput problem would want to run that model multiple times, because given  $k$ , the value of the budget- $k$  min-throughput problem could be much smaller than the value of the budget- $(k + 1)$  min-throughput problem. For example, it could be the case that using a budget of  $k = 2$ , the attacker can reduce throughput by no more than 5%; but nevertheless with a budget of  $k = 3$ , throughput can be reduced by e.g. 50%. In other words, even if a network is “resilient” against attacks of size  $\leq 2$ , it might nevertheless prove very vulnerable to attacks of size 3. For this reason, and given that the models of grids, power flows, etc., are rather approximate, a practitioner would want to test various values of  $k$  – this issue is obviously related to what percentage of demand loss would be considered tolerable, in other words, the parameter  $T^{min}$ .
- (b) From an operational perspective it should be straightforward to identify rea-

sonable values for the quantity  $T^{min}$ ; whereas the value  $k$  is more obscure and bound to models of how much power the adversary can wield.

- (c) Because of a subtlety that arises from having positive quantities  $P_i^{min}$ , explained next, it turns out that the min-throughput problem is significantly more complex and is difficult to even formulate in a compact manner.

We will now expand on (c). One would expect that when a configuration  $\mathcal{C}$  is defeated by an attack  $\mathcal{A}$ , it is because only small throughput solutions are feasible in  $\mathcal{N} - \mathcal{A}$ . However, because the lower bounds  $P_i^{min}$  are in general strictly possible, it may also be the case that *no feasible solution to  $\mathbf{P}(\mathcal{N} - \mathcal{A}, \mathcal{C})$  exists.*

**Example 2.1.2** Consider the following example on a network  $\mathcal{N}$  with three nodes (see Figure 2.1), where

1. Nodes 1 and 2 represent generators;  $P_1^{min} = 2$ ,  $P_1^{max} = 4$ ,  $P_2^{min} = 0$ , and  $P_2^{max} = 4$ ,
2. Node 3 is a demand node with  $D_3^{nom} = 6$ . Furthermore,  $T^{min} = 1/2$ .
3. There are three arcs; arc (1, 2) with  $x_{12} = 1$  and  $u_{12} = 1$ , arc (2, 3) with  $x_{23} = 1$  and  $u_{23} = 5$ , and arc (1, 3) with  $x_{13} = 1$  and  $u_{13} = 3$ .

When the network is not attacked, the following solution is feasible:  $P_1 = P_2 = 3$ ,  $D_3 = 6$ ,  $f_{12} = 0$ ,  $f_{13} = f_{23} = 3$ ,  $\theta_1 = \theta_2 = 0$ ,  $\theta_3 = -3$ . This solution has throughput




Figure 2.1: A simple example.

100%. On the other hand, consider the attack  $\mathcal{A}$  consisting of the single arc  $(1, 3)$ , and suppose we choose the configuration  $\mathcal{C} = \{1, 2\}$  (i.e. we operate both generators). Since  $P_1^{min} > u_{12}$ ,  $\mathbf{P}(\mathcal{N} - \mathcal{A}, \mathcal{C})$  has no feasible solution, and  $\mathcal{A}$  defeats  $\mathcal{C}$  (in spite of the fact that we can still meet 100% of the demand).

Likewise,  $\mathcal{A}$  defeats the configuration where we only operate generator 1. Thus,  $\mathcal{A}$  is successful if and only if it also defeats the configuration where we only operate generator 2, which it does not since in that configuration we can feasibly send up to four units of flow on  $(2, 3)$  and  $T^{min} = 1/2 < 4/6$ .

As the example highlights, it is important to understand how an attack  $\mathcal{A}$  can defeat a particular configuration  $\mathcal{C}$ . It turns out that there are *three* different ways for this to happen.

(i) Consider a partition of the nodes of  $\mathcal{N}$  into two classes,  $N^1$  and  $N^2$ . Write

$$D^k = \sum_{i \in \mathcal{D} \cap N^k} D_i^{nom}, \quad k = 1, 2, \quad \text{and} \quad (2.1)$$

$$P^k = \sum_{i \in \mathcal{C} \cap N^k} P_i^{max}, \quad k = 1, 2, \quad (2.2)$$

e.g. the total (nominal) demand in  $N_1$  and  $N_2$ , and the maximum power generation in  $N_1$  and  $N_2$ , respectively. The following condition, should it hold, would guarantee that  $\mathcal{A}$  defeats  $\mathcal{C}$ :

$$T^{min} \sum_{j \in \mathcal{D}} D_j^{nom} - \min\{D^1, P^1\} - \min\{D^2, P^2\} > \sum_{(i,j) \notin \mathcal{A}: i \in N^1, j \in N^2} u_{ij} + \sum_{(i,j) \notin \mathcal{A}: i \in N^2, j \in N^1} u_{ij} \quad (2.3)$$

To understand this condition, note that for  $k = 1, 2$ ,  $\min\{D^k, P^k\}$  is the maximum demand within  $N^k$  that could possibly be met using power flows that do not leave  $N^k$ . Consequently the left-hand side of (2.3) is a lower bound on the amount of flow that must travel between  $N^1$  and  $N^2$ , whereas the right-hand side of (2.3) is the total capacity of arcs between  $N^1$  and  $N^2$  under attack  $\mathcal{A}$ . In other words, condition (2.3) amounts to a mismatch between demand and supply. A special case of (2.3) is that where in  $\mathcal{N} - \mathcal{A}$  there are no arcs between  $N^1$  and  $N^2$ , i.e. the right-hand side of (2.3) is zero.

(ii) Consider a partition of the nodes of  $\mathcal{N}$  into two classes,  $N^1$  and  $N^2$ , such that in  $\mathcal{N} - \mathcal{A}$  there are *no* arcs between  $N^1$  and  $N^2$ . Then attack  $\mathcal{A}$  defeats  $\mathcal{C}$  if

$$\sum_{i \in \mathcal{D} \cap N^1} D_i^{nom} < \sum_{i \in \mathcal{C} \cap N^1} P_i^{min}, \quad (2.4)$$

i.e., the minimum power output within  $N^1$  exceeds the maximum demand within  $N^1$ . Note that (ii) may apply even if (i) does not.

(iii) Even if (i) and (ii) do not hold, it may still be the case that the system (1.7)-(1.11) does not admit a feasible solution. To put it differently, suppose that for every choice of demand values  $0 \leq D_i \leq D_i^{nom}$  (for  $i \in \mathcal{D}$ ) and supply values  $P_i^{min} \leq P_i \leq P_i^{max}$  (for  $i \in \mathcal{C}$ ) such that  $\sum_{i \in \mathcal{C}} P_i = \sum_{i \in \mathcal{D}} D_i$  the unique solution to system (1.7)-(1.8) in network  $\mathcal{N} - \mathcal{A}$  (as per Lemma 1.3.1) does *not* satisfy the “capacity” inequalities  $|f_{ij}| \leq u_{ij}$  for all arcs  $(i, j) \in \mathcal{N} - \mathcal{A}$ . Then  $\mathcal{A}$  defeats  $\mathcal{C}$ . This is the most subtle case of all – it involves the interplay of flow conservation and Ohm’s law.

Note that in particular in case (ii), the defeat condition is unrelated to throughput. Nevertheless, should case (ii) arise, it is clear that the attack has succeeded (against configuration  $\mathcal{C}$ ) – this makes the min-throughput problem difficult to model; our formulation for the min-cardinality problem, given in Section 2.2, does capture the three defeat criteria above.

From a practical perspective, it is important to handle models where the values  $P_i^{min}$  are positive. It is also important to model *standby* generators that are turned on when needed, and to model the turning off of generators that are unable to dispose of their minimum power output, post-attack. All these features arise in practice.

Example 2.1.2 above shows that models where generators cannot be turned off can exhibit unreasonable behavior. Of course, the ability to select the operating generators comes at a cost, in that in order to certify that an attack is successful we need to evaluate, at least implicitly, a possibly exponential number of control possibilities.

As far as we can tell, most (or all) prior work in the literature **does** require that the controller must always use the configuration  $\bar{\mathcal{G}}$  consisting of all generators. As the example shows, however, if the quantities  $P_i^{min}$  are positive there may be attacks  $\mathcal{A}$  such that  $\mathbf{P}(\mathcal{N} - \mathcal{A}, \bar{\mathcal{G}})$  is infeasible. Because of this fact, algorithms that rely on direct application of Benders’ decomposition or bilevel programming are problematic, and *invalid* formulations can be found in the literature.

Our approach works with general  $P_i^{min} \geq 0$  quantities; thus, it also applies to the case where we always have  $P_i^{min} = 0$ . In this case our formulation is simple enough that a commercial integer program solver can directly handle instances larger than previously reported in the literature.

### 2.1.1 Non-monotonicity

Consider the example in Figure 2.2, where we assume  $T^{min} = 0.3$ . Notice that there are two parallel copies of arcs (2, 4) and (3, 5), each with capacity 10 and impedance 1. It is easy to see that the network with no attack is feasible: we operate generator 1 and

not operate generators 2 and 3, and send 3 units of flow along the paths  $1 - 6 - 2 - 4$  and  $1 - 6 - 3 - 5$  (the flow on e.g. the two parallel  $(2, 4)$  arcs is evenly split).




Figure 2.2: Non-monotone example.

On the other hand, consider the attack consisting of arc  $(1, 6)$  – we will show this attack is successful. To see this, note that under this attack, the controller cannot operate both generators 2 and 3, since their combined minimum output exceeds the total demand. Suppose, for example, that only generator 3 is operated, and assume by contradiction that a feasible solution exists – then this solution must route *at most* 3 units of flow along  $3 - 6 - 2 - 4$ , and (since  $P_3^{\min} = 8$ ) *at least* 5 units of flow on  $(3, 5)$  (both copies altogether). In such a case, the voltage drop from 3 to 5 is at least 2.5,

whereas the voltage drop from 3 to 4 is at most 1.56. In other words,  $\theta_4 - \theta_5 \geq 0.94$ , and so we will have  $f_{45} \geq 0.94$  – thus, the net inflow at node 5 is at least 5.94. Hence the attack is indeed successful.

However, there is *no* successful attack consisting of arc (1, 6) and another arc. To see this, note that if one of (2, 6), (3, 6) or (4, 5) are also removed then the controller can *just* operate one of the two generators 2, 3 and meet eight units of demand. Suppose that (say) one of the two copies of (3, 5) is removed (again, in addition to (1, 6)). Then the controller operates generator 2, sending 2.5 units of flow on each of the two parallel (2, 4) arcs; thus  $\theta_2 - \theta_4 = 2.5$ . The controller also routes 3 units of flow along 2 – 6 – 3 – 5, and therefore  $\theta_2 - \theta_5 = 3.06$ . Consequently  $\theta_4 - \theta_5 = .56$ , and  $f_{45} = .56$ , resulting in a feasible flow which satisfies 4.44 units of demand at 4 and 3.56 units of demand at 5.

In fact, it is straightforward to show that *no* successful attack of cardinality 2 exists – hence we observe non-monotonicity.

By elaborating on the above, one can create examples with arbitrary patterns in the cardinality of successful attacks. One can also generate examples that exhibit non-monotone behavior in response to controller actions. In both cases, the non-monotonicity can be viewed as a manifestation of the so-called “Braess’s Paradox” [14]. In the above example we can observe combinatorial subtleties that arise from the ability of the controller to choose which generators to operate, and from the lower bounds on output in operating generators. Nevertheless, it is clear that the critical

core reason for the complexity is the interaction between voltages and flows, i.e. between “Ohm’s law” (1.8) and flow conservation (1.7) – the combinatorial attributes of the problem exercise this interaction. Thus, we view it as crucial that an optimization model address the interaction in an explicit manner.

### 2.1.2 Brief review of previous work

The min-cardinality problem, as defined above, can be viewed as a bilevel program (see 1.1 for definition of bilevel programming) where both the master problem and the subproblem are mixed-integer programs – the master problem corresponds to the attacker (who chooses the arcs to remove) and the subproblem to the controller (who chooses the generators to operate). In general, such problems are extremely challenging. A recent general-purpose algorithm for such integer programs is given in [21].

Alternatively, each configuration of generators can be viewed as a “scenario”. In this sense our problem resembles a stochastic program, although without a probability distribution. Recent work [22] considers a single commodity max-flow problem under attack by an interdicator with a limited attack budget; where an attacked arc is removed probabilistically, leading to a stochastic program (to minimize the expected max flow). A deterministic, multi-commodity version of the same problem is given in [23].

Previous work on the power grid vulnerability models has focused on cases where

either the generator lower bounds  $P_i^{min}$  are all zero, or all generators must be operated (the single configuration case). Algorithms for these problems have either relied on heuristics, or on mixed-integer programming techniques, usually a direct use of Benders’ decomposition or bilevel programming. [5] considers a version of the min-throughput problem with  $P_i^{min} = 0$  for all generators  $i$ , and presents an algorithm using Benders’ decomposition (also see references therein). They analyze the so-called IEEE One-Area and IEEE Two-Area test cases, with, respectively, 24 nodes and 38 arcs, and 48 nodes and 79 arcs. Also see [4].

[6] studies the IEEE One-Area test case, and allows  $P_i^{min} > 0$ , but does not allow generators to be turned off; the authors present a bilevel programming formulation which, unfortunately, is incorrect, due to reasons outlined above.

## 2.2 An algorithm for the min-cardinality problem

In this section we will describe an iterative algorithm for the min-cardinality attack problem. The algorithm iterates in Benders-like fashion, solving at each iteration two mixed-integer programs. Before describing the algorithm we need to introduce some notation and concepts.

Let  $\mathcal{A}$  be a given attack. Suppose the controller attempts to defeat the attacker by choosing a certain configuration  $\mathcal{C}$  of generators. Denote by  $z^{\mathcal{A}}$  the indicator vector for  $\mathcal{A}$ , i.e.  $z_{ij}^{\mathcal{A}} = 1$  iff  $(i, j) \in \mathcal{A}$ . Then the controller needs to solve the following linear

program:

$$\mathbf{K}_{\mathcal{C}}(\mathcal{A}) : \quad t_{\mathcal{C}}(z^{\mathcal{A}}) \doteq \min t \quad (2.5)$$

Subject to:

$$\sum_{(i,j) \in \delta^+(i)} f_{ij} - \sum_{(j,i) \in \delta^-(i)} f_{ji} = \begin{cases} P_i & i \in \mathcal{G} \\ -D_i & i \in \mathcal{D} \\ 0 & \text{otherwise} \end{cases} \quad (2.6)$$

$$\theta_i - \theta_j - x_{ij} f_{ij} = 0 \quad \forall (i,j) \notin \mathcal{A} \quad (2.7)$$

$$u_{ij} t - |f_{ij}| \geq 0, \quad \forall (i,j) \notin \mathcal{A} \quad (2.8)$$

$$f_{ij} = 0, \quad \forall (i,j) \in \mathcal{A} \quad (2.9)$$

$$P_i^{\min} \leq P_i \leq P_i^{\max} \quad \forall i \in \mathcal{C} \quad (2.10)$$

$$P_i = 0, \quad \forall i \in \mathcal{G} - \mathcal{C} \quad (2.11)$$

$$\sum_{j \in \mathcal{D}} D_j \geq T^{\min} \left( \sum_{j \in \mathcal{D}} D_j^{\text{nom}} \right), \quad (2.12)$$

$$0 \leq D_j \leq D_j^{\text{nom}} \quad \forall j \in \mathcal{D} \quad (2.13)$$

**Remark 2.2.1** *Using the convention that the value of an infeasible linear program is infinite,  $\mathcal{A}$  defeats  $\mathcal{C}$  if and only if  $t_{\mathcal{C}}(z^{\mathcal{A}}) > 1$ .*

Thus, an attack  $\mathcal{A}$  is *not* successful if and only if we can find  $\mathcal{C} \subseteq \mathcal{G}$  with  $t_{\mathcal{C}}(z^{\mathcal{A}}) \leq 1$ ; we test for this conditions by solving the problem:

$$\min_{\mathcal{C} \subseteq \mathcal{G}} t_{\mathcal{C}}(z^{\mathcal{A}}).$$

This is done by replacing, in the above formulation, equations (2.10), (2.11) with

$$P_i^{min} y_i \leq P_i \leq P_i^{max} y_i, \quad \forall i \in \mathcal{G}, \quad (2.14)$$

$$y_i = 0 \text{ or } 1, \quad \forall i \in \mathcal{G}. \quad (2.15)$$

Here,  $y_i = 1$  if the controller operates generator  $i$ .

The min-cardinality attack problem can now be written as follows:

$$\min \sum_{(i,j)} z_{ij} \quad (2.16)$$

$$t_{\mathcal{C}}(z) > 1, \quad \forall \mathcal{C} \subseteq \mathcal{G}, \quad (2.17)$$

$$z_{ij} = 0 \text{ or } 1, \quad \forall (i,j). \quad (2.18)$$

This formulation, of course, is impractical, because we do not have a compact way of representing any of the constraints (2.17), and there are an exponential number of them.

Putting these issues aside, we can outline an algorithm for the min-cardinality attack problem. Our algorithm will be iterative, and will maintain a “master attacker” mixed-integer program which will be a *relaxation* of (2.16)-(2.18) – i.e. it will have objective (2.16) but weaker constraints than (2.17). Initially, the master attacker MIP will include no variables other than the  $z$  variables, and no constraints other than (2.18). The algorithm proceeds as follows.

**Basic algorithm for min-cardinality attack problem**

**Iterate:**

**1. Attacker:** Solve master attacker MIP and let  $z^*$  be its solution.

**2. Controller:** Search for a set  $\mathcal{C}$  of generators such that  $t_{\mathcal{C}}(z^*) \leq 1$ .

**(2.a)** If no such set  $\mathcal{C}$  exists, **EXIT:**

$\sum_{ij} z_{ij}^*$  is the minimum cardinality of a successful attack.

**(2.b)** Otherwise, suppose such a set  $\mathcal{C}$  is found.

Add to the master attacker MIP a system of valid inequalities that cuts off  $z^*$ .

Go to **1**.

As discussed above, the search in Step 2 can be implemented by solving a mixed integer program. Since in 2.b we add valid inequalities to the master, then inductively we always have a relaxation of (2.16)-(2.18) and thus the value of the master at any execution of step 1, i.e. the value  $\sum_{ij} z_{ij}^*$ , is a lower bound on the cardinality of any successful attack. Thus the exit condition in step 2.a is correct, since it proves that the attack implied by  $z^*$  is successful.

The implementation of Case 2.b, on the other hand, requires some care. Assuming we are in case 2.b, we have that  $t_{\mathcal{C}}(z^*) \leq 1$ , and certainly the linear program  $\mathbf{K}_{\mathcal{C}}(\mathcal{A})$  is feasible. The optimal dual solution would therefore (apparently) furnish a Benders cut that cuts off  $z^*$ . However this would be incorrect since the structure of constraints

(2.5)-(2.13)) depends on  $z^*$  itself.

Instead, we need to proceed as in two-stage stochastic programming with recourse, where the  $z$  variables play the role as “first-stage” variables *and* also appear in the second-stage problem (the subproblem); solutions to the dual of the second-stage problem can then be used to generate cuts to add to the master problem. Toward this goal, we proceed as follows, given  $\mathcal{C}$  and  $z^*$ :

B.1 Write the *dual* of  $K_{\mathcal{C}}(\emptyset)$ .

B.2 As is standard in interdiction-type problems (see [23], [22], [21], [5]), the dual is then “combinatorialized” by adding the  $z$  variables and additional constraints. For example, if  $\beta_{ij}$  indicates the dual of constraint (2.7), then we add, to the dual of  $K_{\mathcal{C}}(\emptyset)$ , inequalities of the form

$$\beta_{ij} - M_{ij}^1 z_{ij} \leq 0, \quad -\beta_{ij} - M_{ij}^1 z_{ij} \leq 0,$$

for an appropriate constant  $M_{ij}^1 > 0$ . We proceed similarly with constraint (2.8), obtaining the “combinatorial dual”. This combinatorial dual is the functional equivalent of the second-stage problem in stochastic programming.

B.3 Fix the  $z_{ij}$  variables in the combinatorial dual to  $z^*$ ; this yields a problem that is equivalent to  $K_{\mathcal{C}}(z^*)$  and has the general structure

$$\begin{aligned} t_{\mathcal{C}}(z^*) = \quad & \max \quad c^T v \\ & Pv \leq b + Qz^*. \end{aligned} \tag{2.19}$$

Here, the  $v$  are variables,  $P$  and  $Q$  are matrices, and  $b$  is a vector, of appropriate dimensions; and we have a maximization problem since the  $K_C()$  are minimization problems. We obtain a cut of the form

$$\bar{\alpha}^T(b + Qz) \geq 1 + \epsilon$$

where  $\epsilon > 0$  is a small constant and  $\bar{\alpha}$  is the vector of optimal dual variables to (2.19). Since by assumption  $t_C(z^*) \leq 1$  this inequality cuts off  $z^*$ .

Note the use of the tolerance  $\epsilon$ . The use of this parameter gives *more* power to the controller, i.e. “borderline” attacks are not considered successful. In a strict sense, therefore, we are not solving the optimization problem to exact precision; nevertheless in practice we expect our relaxation to have negligible impact so long as  $\epsilon$  is small. A deeper issue here is how to interpret truly borderline attacks that are successful according to our strict model (and which our use of  $\epsilon$  disallows); we expect that in practice such attacks would be ambiguous and that the approximations incurred in modeling power flows, estimating demands levels, and so on, not to mention the numerical sensitivity of the integer and linear solvers being used, would have a far more significant impact on precision.

### 2.2.1 Discussion

In order to make the outline provided in B.1-B.3 into a formal algorithm, we need to specify the constants  $M_{ij}^1$ . As is well-known, the folklore of integer programming

dictates that the  $M_{ij}^1$  should be chosen small to improve the quality of the linear programming relaxation of the master problem.

While this is certainly true, we have found that popular optimization packages show significant numerical instability when solving power flow *linear* programs. In fact, in our experience it is primarily this behavior that mandates that the  $M_{ij}^1$  should be kept as small as possible. In particular we do not want the  $M_{ij}^1$  to grow with network since this would lead to a non-scalable approach.

It turns out that our formulation  $K_C(\mathcal{A})$  is not ideal toward this goal. A particularly thorny issue is that the attack  $\mathcal{A}$  may disconnect the network, and proving “reasonable” upper bounds on the dual variables to (for example) constraint (2.6), when the network is disconnected, does not seem possible. In the next section we describe a different formulation for the min-cardinality attack problem which is much better in this regard. Our eventual algorithm will apply steps B.1 - B.3 to this improved formulation, while the rest of our basic algorithmic methodology as described above will remain unchanged.

## 2.3 A better mixed-integer programming formulation

As before, let  $\mathcal{A}$  be an attack and  $\mathcal{C}$  a (given) configuration of generators. Let  $y^{\mathcal{C}} \in R^{\mathcal{G}}$  be the indicator vector for  $\mathcal{C}$ , i.e.  $y_i^{\mathcal{C}} = 1$  if  $i \in \mathcal{C}$  and  $y_i^{\mathcal{C}} = 0$  otherwise. Consider the following *linear* program:

$$K_{\mathcal{C}}^*(\mathcal{A}) : \quad t_{\mathcal{C}}^*(z^{\mathcal{A}}) \quad \doteq \quad \min t \quad (2.20)$$

Subject to:

$$(\alpha_i^{\mathcal{C}}) \quad \sum_{(i,j) \in \delta^+(i)} f_{ij} - \sum_{(j,i) \in \delta^-(i)} f_{ji} = \begin{cases} P_i & i \in \mathcal{G} \\ -D_i & i \in \mathcal{D} \\ 0 & \text{otherwise} \end{cases} \quad (2.21)$$

$$(\beta_{ij}^{\mathcal{C}}) \quad \theta_i - \theta_j - x_{ij} f_{ij} = 0 \quad \forall (i,j) \notin \mathcal{A} \quad (2.22)$$

$$(\rho_{ij}^{\mathcal{C}}, q_{ij}^{\mathcal{C}}) \quad u_{ij} t - |f_{ij}| \geq 0, \quad \forall (i,j) \notin \mathcal{A} \quad (2.23)$$

$$(\omega_{ij}^{\mathcal{C}+}, \omega_{ij}^{\mathcal{C}-}) \quad t - |f_{ij}| \geq 1, \quad \forall (i,j) \in \mathcal{A} \quad (2.24)$$

$$(\gamma_i^{\mathcal{C}+}, \gamma_i^{\mathcal{C}-}) \quad P_i^{\min} y_i^{\mathcal{C}} \leq P_i \leq P_i^{\max} y_i^{\mathcal{C}} \quad \forall i \in \mathcal{G} \quad (2.25)$$

$$(\mu^{\mathcal{C}}) \quad \sum_{j \in \mathcal{D}} D_j \geq T^{\min} \left( \sum_{j \in \mathcal{D}} D_j^{\text{nom}} \right), \quad (2.26)$$

$$(\Delta_j^{\mathcal{C}}) \quad D_j \leq D_j^{\text{nom}} \quad \forall j \in \mathcal{D} \quad (2.27)$$

$$P \geq 0, \quad D \geq 0. \quad (2.28)$$

To the left of each constraint we have indicated the corresponding dual variable –

(2.23) is really two constraints written as one, and the same with (2.24).

Note that we do not force  $f_{ij} = 0$  for  $(i, j) \in \mathcal{A}$ . Moreover arcs  $(i, j) \in \mathcal{A}$  are also exempted from constraint (2.22). Thus, the controller has significantly more power than in  $K_C(\mathcal{A})$ . However, because of constraint (2.24), we have  $t_C^*(z^{\mathcal{A}}) > 1$  as soon as any of the arcs in  $\mathcal{A}$  actually carries flow. We can summarize these remarks as follows:

**Remark 2.3.1**  $\mathcal{A}$  defeats  $\mathcal{C}$  if and only if  $t_C^*(z^{\mathcal{A}}) > 1$ .

Note that the above formulation depends on  $\mathcal{C}$  only through constraint (2.25). Using appropriate matrices  $\bar{A}_f, \bar{A}_\theta, \bar{A}_P, \bar{A}_D, \bar{A}_t$ , and vector  $\hat{b}$ , the formulation can be abbreviated as

$$K_C^*(\mathcal{A}) : \quad t_C^*(z^{\mathcal{A}}) \quad \doteq \quad \min t$$

Subject to:

$$\bar{A}_f f + \bar{A}_\theta \theta + \bar{A}_P P + \bar{A}_D D + \bar{A}_t t \geq \bar{b}$$

$$P_i^{\min} y_i^{\mathcal{C}} \leq P_i \leq P_i^{\max} y_i^{\mathcal{C}}, \quad \forall i \in \mathcal{G}$$

Allowing the  $y$  quantities to become 0/1 variables, we obtain the problem

$$t^*(z^{\mathcal{A}}) \doteq \min t \quad (2.29)$$

Subject to:

$$\bar{A}_f f + \bar{A}_\theta \theta + \bar{A}_P P + \bar{A}_D D + \bar{A}_t t \geq \bar{b} \quad (2.30)$$

$$P_i^{\min} y_i \leq P_i \leq P_i^{\max} y_i, \quad \forall i \in \mathcal{G} \quad (2.31)$$

$$y_i = 0 \text{ or } 1, \quad \forall i \in \mathcal{G}. \quad (2.32)$$

This is the *controller's problem*: we have that  $t^*(z^{\mathcal{A}}) \leq 1$  if and only if there exists some configuration of the generators that defeats  $\mathcal{A}$ .

However, for the purposes of this section, we will assume  $\mathcal{C}$  is given and that the  $y^{\mathcal{C}}$  are constants. We can now write the dual of  $K_{\mathcal{C}}^*(\mathcal{A})$ , suppressing the index  $\mathcal{C}$  from the variables, for clarity.

$$\mathbf{A}_{\mathcal{C}}(\mathcal{A}) : \max \sum_{i \in \mathcal{G}} y_i^{\mathcal{C}} P_i^{\min} \gamma_i^- - \sum_{i \in \mathcal{G}} y_i^{\mathcal{C}} P_i^{\max} \gamma_i^+ - \sum_{j \in \mathcal{D}} D_j^{\text{nom}} \Delta_j + \sum_{j \in \mathcal{D}} D_j^{\text{nom}} \mu_j + \sum_{(i,j) \in E} (\omega_{ij}^+ + \omega_{ij}^-)$$

Subject to:

$$(f_{ij}) \quad \alpha_i - \alpha_j - x_{ij}\beta_{ij} - p_{ij} + q_{ij} + \omega_{ij}^+ - \omega_{ij}^- = 0 \quad \forall (i, j) \in E \quad (2.33)$$

$$(\theta_i) \quad \sum_{(i,j) \in \delta^+(i)} \beta_{ij} - \sum_{(j,i) \in \delta^-(i)} \beta_{ji} = 0 \quad \forall i \in V \quad (2.34)$$

$$(t) \quad \sum_{(i,j) \in E} u_{ij}(p_{ij} + q_{ij}) + \sum_{(i,j) \in E} (\omega_{ij}^+ + \omega_{ij}^-) \leq 1 \quad (2.35)$$

$$(P_i) \quad -\alpha_i - \gamma_i^- + \gamma_i^+ = 0 \quad \forall i \in \mathcal{G} \quad (2.36)$$

$$(D_j) \quad \alpha_j + \mu - \Delta_j \leq 0 \quad \forall j \in \mathcal{D} \quad (2.37)$$

$$(\xi_{ij}^+, \xi_{ij}^-) \quad x_{ij}^{1/2} |\beta_{ij}| \leq \mathbf{M}(1 - z_{ij}^{\mathcal{A}}) \quad \forall (i, j) \in E \quad (2.38)$$

$$(\varrho_{ij}) \quad p_{ij} + q_{ij} \leq \frac{1}{u_{ij}}(1 - z_{ij}^{\mathcal{A}}) \quad \forall (i, j) \in E \quad (2.39)$$

$$(\eta_{ij}) \quad \omega_{ij}^+ + \omega_{ij}^- \leq z_{ij}^{\mathcal{A}} \quad \forall (i, j) \in E \quad (2.40)$$

$$\omega_{ij}^+ \geq 0, \quad \omega_{ij}^- \geq 0, \quad p_{ij} \geq 0, \quad q_{ij} \geq 0 \quad \forall (i, j) \in E$$

$$\gamma_i^+, \gamma_i^- \geq 0 \quad \forall i \in \mathcal{G}$$

$$\mu \geq 0, \quad \Delta_j \geq 0 \quad \forall j \in \mathcal{D}$$

$$\delta_{ij}, \beta_{ij} \text{ free} \quad \forall (i, j) \in E$$

$$\alpha_i \text{ free} \quad \forall i \in V.$$

In the above formulation,  $E$  represents the set of edges in the network and as before, for each constraint we indicate the corresponding dual variable. Observe that the above formulation includes extra terms in (2.33)- (2.35) as well as the attack indicator vector  $z^{\mathcal{A}}$ , when compared to the *exact* dual of  $K_{\mathcal{C}}^*(\mathcal{A})$ . We will next show that the

above formulation is equivalent to the *exact* dual of  $K_C^*(\mathcal{A})$ .

The dual constraint for variable  $f_{ij}$  in  $K_C^*(\mathcal{A})$  is given by :

$$\alpha_i - \alpha_j - x_{ij}\beta_{ij} - p_{ij} + q_{ij} = 0 \quad \forall(i, j) \text{ s.t. } z_{ij}^A = 0$$

$$\alpha_i - \alpha_j + \omega_{ij}^+ - \omega_{ij}^- = 0 \quad \forall(i, j) \text{ s.t. } z_{ij}^A = 1$$

Constraints (2.38) and (2.39) force  $\beta_{ij} = p_{ij} = q_{ij} = 0$  when  $z_{ij}^A = 1$  while (2.40) insures  $\omega_{ij}^+ = \omega_{ij}^- = 0$  when  $z_{ij}^A = 0$ . Hence, the above two dual constraints can be combined together and expressed as (2.33). The extra terms in (2.34) and (2.35) can be explained similarly. Hence the above formulation  $A_C(\mathcal{A})$  is equivalent to the dual of  $K_C^*(\mathcal{A})$ .

In (2.38),  $\mathbf{M}$  is an appropriately chosen constant (we will provide a precise value for it below). Note that we are scaling  $\beta_{ij}$  by  $x_{ij}^{1/2}$  – this is allowable since  $x_{ij}^{1/2} > 0$ ; the reason for this scaling will become clear below.

Abbreviating

$$(\alpha^c, \beta^c, p^c, q^c, \omega^{c+}, \omega^{c-}, \gamma^{c-}, \gamma^{c+}, \mu^c, \Delta^c) = \psi^c,$$

we have that  $A_C(\mathcal{A})$  can be rewritten as:

$$\max \{ w_C^T \psi^c : A\psi^c \leq b + B(1 - z^A) \} \quad (2.41)$$

where  $A$ ,  $B$ ,  $w_C$  and  $b$  are appropriate matrices and vectors. Consequently, we can

now rewrite the min-cardinality attack problem:

$$\min \sum_{(i,j)} z_{ij} \quad (2.42)$$

$$\text{Subject to:} \quad t^{\mathcal{C}} \geq 1 + \epsilon, \quad \forall \mathcal{C} \subseteq \mathcal{G} \quad (2.43)$$

$$w_{\mathcal{C}}^T \psi^{\mathcal{C}} - t^{\mathcal{C}} \geq 0, \quad \forall \mathcal{C} \subseteq \mathcal{G}, \quad (2.44)$$

$$A\psi^{\mathcal{C}} + Bz \leq b + B \quad \forall \mathcal{C} \subseteq \mathcal{G}, \quad (2.45)$$

$$z_{ij} = 0 \text{ or } 1, \quad \forall (i, j). \quad (2.46)$$

This formulation, of course, is exponentially large. An alternative is to use Benders cuts – having solved the linear program  $A_{\mathcal{C}}(\mathcal{A})$ , let  $(\bar{f}, \bar{\theta}, \bar{t}, \bar{P}, \bar{D}, \bar{\xi}^+, \bar{\xi}^-, \bar{\varrho}, \bar{\eta})$  be optimal dual variables. Then the resulting Benders cut is

$$t^{\mathcal{C}} + \sum_{(i,j) \in E} ((\bar{\xi}_{ij}^+ + \bar{\xi}_{ij}^-) \mathbf{M}(1 - z_{ij})) + \sum_{(i,j) \in E} \left( \frac{1}{u_{ij}} \bar{\varrho}_{ij} (1 - z_{ij}) \right) + \sum_{(i,j) \in E} \bar{\eta}_{ij} z_{ij} \geq 1 + \epsilon, \quad (2.47)$$

We can now update our algorithmic template for the min-cardinality problem.

**Updated algorithm for min-cardinality attack problem**

**Iterate:**

- 1. Attacker:** Solve master attacker MIP, obtaining attack  $\mathcal{A}$ .
- 2. Controller:** Solve the controller’s problem (2.29)-(2.32) to search

for a set  $\mathcal{C}$  of generators such that  $t_{\mathcal{C}}^*(z^{\mathcal{A}}) \leq 1$ .

**(2.a)** If no such set  $\mathcal{C}$  exists, **EXIT:**

$\mathcal{A}$  is a minimum cardinality successful attack.

**(2.b)** Otherwise, suppose such a set  $\mathcal{C}$  is found. Then

**(2.b.1)** Add to the master the Benders’ cut (2.47), and, optionally

**(2.b.2)** Add to the master the entire system (2.43)-(2.45),

**Go to 1.**

Clearly, option (2.b.2) can only be exercised sparingly (if ever). Below we will discuss how we choose, in our implementation, between (2.b.1) and (2.b.2). We will also describe how to (significantly) strengthen the straightforward Benders cut (2.47). One point to note is that the cuts (or systems) arising from different configurations  $\mathcal{C}$  reinforce one another.

At each iteration of the algorithm, the master attacker MIP becomes a stronger relaxation for the min-cardinality problem, and thus its solution in step 1 provides a lower bound for the problem. Thus, if in a certain execution of step 2 we certify that  $t_{\mathcal{C}}^*(z^{\mathcal{A}}) > 1$  for every configuration  $\mathcal{C}$ , we have solved the min-cardinality problem to optimality.

What we have above is a complete outline of our algorithm. In order to make the algorithm effective we need to further sharpen the approach. In particular, we need set the constant  $\mathbf{M}$  to as small a value as possible, and we need to develop stronger inequalities than the basic Benders’ cuts.

### 2.3.1 Setting $\mathbf{M}$

In this section we show how to choose for  $\mathbf{M}$  a value that does not grow with network size (see Section 2.2.1 for detailed discussion).

**Lemma 2.3.2** *We can set*

$$\mathbf{M} = \max_{(i,j) \in E} \left\{ \frac{1}{\sqrt{x_{ij}} u_{ij}} \right\} \quad (2.48)$$

*Proof.* Given an attack  $\mathcal{A}$ , consider a connected component  $K$  of  $\mathcal{N} - \mathcal{A}$ . For any arc  $(i, j)$  with both ends in  $K$ ,  $\omega_{ij}^+ + \omega_{ij}^- = 0$  by (2.40). Hence we can rewrite constraints (2.33)-(2.34) over all arcs with both ends in  $K$  as follows:

$$N_K^T \alpha_K - X_K \beta_K = p_K - q_K, \quad (2.49)$$

$$N_K \beta_K = 0. \quad (2.50)$$

Here,  $N_K$  is the node arc incidence matrix of  $K$ ,  $\alpha_K, \beta_K, p_K, q_K$  are the restrictions of  $\alpha, \beta, p, q$  to  $K$ , and  $X_K$  is the diagonal matrix  $diag\{x_{ij} : (i, j) \in K\}$ . From this system we obtain

$$N_K X_K^{-1} N_K \alpha_K = N_K X_K^{-1} (p_K - q_K). \quad (2.51)$$

The matrix  $N_K X_K^{-1} N_K$  has one-dimensional null space and thus we have one degree of freedom in choosing  $\alpha_K$ . Thus, to solve (2.51), we can remove from  $N_K$  an arbitrary row, obtaining  $\tilde{N}_K$ , and remove the same row from  $\alpha_K$ , obtaining  $\tilde{\alpha}_K$ . Thus, (2.51) is equivalent to:

$$\tilde{N}_K X_K^{-1} \tilde{N}_K \tilde{\alpha}_K = \tilde{N}_K X_K^{-1} (p_K - q_K), \quad (2.52)$$

The matrix  $\tilde{N}_K X_K^{-1} \tilde{N}_K$  and thus (2.52) has a unique solution (given  $p_K - q_K$ ); we complete this to a solution to (2.51) by setting to zero the entry of  $\alpha_K$  that was removed. Moreover,

$$X_K^{-1/2} N_K^T \alpha_K = X_K^{-1/2} \tilde{N}_K^T \tilde{\alpha}_K = X_K^{-1/2} \tilde{N}_K^T (\tilde{N}_K X_K^{-1} \tilde{N}_K^T)^{-1} \tilde{N}_K X_K^{-1} (p_K - q_K). \quad (2.53)$$

The matrix

$$M = X_K^{-1/2} \tilde{N}_K^T (\tilde{N}_K X_K^{-1} \tilde{N}_K^T)^{-1} \tilde{N}_K X_K^{-1/2}$$

is symmetric and idempotent, e.g.  $MM^T = I$ . Thus, from (2.53) we get

$$\|X_K^{-1/2} N_K^T \alpha_K\|_2 \leq \|M\|_2 \|X_K^{-1/2} (p_K - q_K)\|_2 \leq \|X_K^{-1/2} (p_K - q_K)\|_2, \quad (2.54)$$

where the last inequality follows from the idempotent attribute. Because of constraints (2.35), (2.39) and (2.40), we can see that the right-hand side of (2.54) is upper-bounded by the value of the convex maximization problem,

$$\max \sum_{(i,j) \in E} x_{ij}^{-1} (p_{ij} - q_{ij})^2 \quad (2.55)$$

$$\text{s.t.} \quad \sum_{(i,j) \in E} u_{ij} (p_{ij} + q_{ij}) \leq 1 \quad (2.56)$$

$$p_{ij} \geq 0, \quad q_{ij} \geq 0, \quad (2.57)$$

which, as is easily seen, equals

$$\max_{(i,j) \in E} \left\{ \frac{1}{x_{ij} u_{ij}^2} \right\}. \blacksquare$$

### 2.3.2 Tightening the formulation

In this Section we describe a family of inequalities that are valid for the attacker problem. These cuts seek to capture the interplay between the flow conservation equations and Ohm’s law. First we present a technical result.

**Lemma 2.3.3** *Let  $Q$  be matrix with  $r$  rows with rank  $r$ , and let  $A = Q^T(QQ^T)^{-1}Q \in \mathcal{R}^{r \times r}$ . Let  $B := I - A$ . Then for any  $p \in \mathcal{R}^r$  we have*

$$\|p\|_2^2 = \|Ap\|_2^2 + \|Bp\|_2^2 \quad (2.58)$$

$$\|p\|_1 \geq |(Ap)_j| + |(Bp)_j| \quad \forall j = 1 \dots r \quad (2.59)$$

*Proof.*  $A$  and  $B$  are symmetric and idempotent, i.e.,  $A^2 = A$ ,  $B^2 = B$ , and any  $p \in \mathcal{R}^r$  can be written as  $p = Ap + Bp$ . Multiplying equation this by  $p$  and using the fact that  $A$  and  $B$  are symmetric and idempotent we get (2.58):

$$p^T p = p^T Ap + p^T Bp \quad (2.60)$$

$$= p^T A^2 p + p^T B^2 p \quad (2.61)$$

$$\|p\|_2^2 = \|Ap\|_2^2 + \|Bp\|_2^2 \quad (2.62)$$

We also have  $A^T B = A(I - A) = A - A^2 = 0$ , so  $y^T A^T B y = 0$  for any  $y \in \mathcal{R}^r$ .

Thus, if we rename  $Ap = x$  and  $Bp = y$ , then the following holds:  $p = x + y$ ,  $x^T y =$

$$0, \|p\|_2^2 = \|x\|_2^2 + \|y\|_2^2.$$

Let  $1 \leq j \leq r$ . We have

$$\|p\|_2^2 - (|x_j| + |y_j|)^2 = \|x\|_2^2 + \|y\|_2^2 - (|x_j| + |y_j|)^2 = \sum_{i,i \neq j} x_i^2 + \sum_{i,i \neq j} y_i^2 - 2|x_j y_j|$$

where the first equality follows from (2.58). Since  $x^T y = 0$ , we have  $|x_j y_j| = |\sum_{i,i \neq j} x_i y_i|$ . Hence,

$$\sum_{i,i \neq j} x_i^2 + \sum_{i,i \neq j} y_i^2 - 2|x_j y_j| = \sum_{i,i \neq j} x_i^2 + \sum_{i,i \neq j} y_i^2 - 2 \left| \sum_{i,i \neq j} x_i y_i \right| \quad (2.63)$$

$$\geq \sum_{i,i \neq j} x_i^2 + \sum_{i,i \neq j} y_i^2 - 2 \sum_{i,i \neq j} |x_i y_i| \quad (2.64)$$

$$= \sum_{i,i \neq j} (|x_i| - |y_i|)^2 \quad (2.65)$$

$$\geq 0 \quad (2.66)$$

So we have  $\|p\|_2^2 - (|x_j| + |y_j|)^2 \geq 0$ , which implies  $\|p\|_1 \geq \|p\|_2 \geq (|x_j| + |y_j|) \quad \forall j = 1 \dots r$ . ■

As a consequence of this result we now have:

**Lemma 2.3.4** *Given configuration  $\mathcal{C}$ , the following inequalities are valid for system (2.45)-(2.46) for each  $(i, j) \in E$ :*

$$x_{ij}^{-\frac{1}{2}} |\alpha_i^{\mathcal{C}} - \alpha_j^{\mathcal{C}}| + x_{ij}^{\frac{1}{2}} |\beta_{ij}^{\mathcal{C}}| \leq x_{ij}^{-\frac{1}{2}} w_{ij}^{\mathcal{C}} + \mathbf{M}(1 - z_{ij}) \quad (2.67)$$

$$x_{ij}^{-\frac{1}{2}} |\alpha_i^{\mathcal{C}} - \alpha_j^{\mathcal{C}}| + x_{ij}^{\frac{1}{2}} |\beta_{ij}^{\mathcal{C}}| \leq \sum_{(k,l)} x_{kl}^{-\frac{1}{2}} (p_{kl}^{\mathcal{C}} + q_{kl}^{\mathcal{C}}) + w_{ij}^{\mathcal{C}} \quad (2.68)$$

where  $\mathbf{M} := \max_{(k,l) \in E} \left\{ \frac{1}{\sqrt{x_{kl} u_{kl}}} \right\}$  as before.

*Proof.* Suppose first that  $z_{ij} = 0$ . Let  $K$  be the component containing  $(i, j)$  after the attack. Then by (2.53) and (2.49),

$$X^{-1/2}N_K^T\alpha^C = AX^{-1/2}(p^C - q^C), \quad (2.69)$$

$$X^{1/2}\beta^C = (I - A)X^{-1/2}(p^C - q^C), \quad (2.70)$$

where  $A = X^{-1/2}\tilde{N}_K^T(\tilde{N}_K X^{-1}\tilde{N}_K^T)^{-1}\tilde{N}_K X^{-1/2}$ . Thus, we have

$$x_{ij}^{-1/2}|\alpha_i^C - \alpha_j^C| + x_{ij}^{1/2}|\beta_{ij}^C| \leq \sum_{(k,l)} x_{kl}^{-1/2}(p_{kl}^C + q_{kl}^C) \leq \mathbf{M} \quad (2.71)$$

where the first inequality follows from (2.59) proved in Lemma 2.3.3, and the second bound is obtained as in the proof of Lemma 2.3.2.

Suppose now that  $z_{ij} = 1$ . Here we have  $|\alpha_i^C - \alpha_j^C| \leq \omega_{ij}^C$ , by (2.33), (2.39), (2.38).

Using these (2.67)-(2.68) can be easily shown. ■

Inequalities (2.67)-(2.68) strengthen system (2.45)-(2.46); when case step (2.b.2) of the min-cardinality algorithm is applied then (2.58), (2.59) will become part of the master problem. If case (2.b.1) is applied, then the vector  $\psi^C = (\alpha^C, \beta^C, p^C, q^C, \omega^{C+}, \omega^{C-}, \gamma^{C-}, \gamma^{C+}, \mu^C, \Delta^C)$  is expanded by adding two new dual variables per arc  $(i, j)$ .

### 2.3.3 Strengthening the Benders cuts

Typically, the standard Benders cuts (2.47) prove weak. One manifestation of this fact is that in early iterations of our algorithm for the min-cardinality attack prob-

lem, the attacks produced in Step 1 will tend to be “weak” and, in particular, of very small cardinality. Here we discuss two routines that yield substantially stronger inequalities, still in the Benders mode.

In Step 2 of the algorithm, given an attack  $\mathcal{A}$ , we discover a generator configuration  $\mathcal{C}$  that defeats  $\mathcal{A}$ , and from this configuration a cut is obtained. However, it is not simply the configuration that defeats  $\mathcal{A}$ , but, rather, a vector of power flows. If we could somehow obtain a “stronger” vector of power flows, the resulting cut should prove tighter. To put it differently, a vector of power flows that are in some sense “minimal” might also defeat other attacks  $\mathcal{A}'$  that are “stronger” than  $\mathcal{A}$ ; in other words, they should produce stronger inequalities. One way of thinking about this is in analogy with the classical max-flow min-cut paradigm for single commodity flows.

We implement this rough idea in two different ways. Consider Step 2 of the min-cardinality attack algorithm, and suppose case (2.b) takes place. We execute steps I and II below, where in each case  $\mathcal{A}^*$  is initialized as  $E - \mathcal{A}$ , and  $f^*$  is initialized as the power flow that defeated  $\mathcal{A}$ :

(I) First, we add the Benders’ cut (2.47).

Also, initializing  $\mathcal{B} = \mathcal{A}$ , we run the following procedure, for  $k = 1, 2, \dots, |E - \mathcal{A}|$ :

(I.0) Let  $(i_k, j_k) = \operatorname{argmin} \{|f_{ij}^*| : (i, j) \in \mathcal{A}^*\}$ .

(I.1) If the attack  $\mathcal{B} \cup (i_k, j_k)$  is *not* successful, then reset  $\mathcal{B} \leftarrow \mathcal{B} \cup (i_k, j_k)$ , and update  $f^*$  to the power flow that defeats the (new) attack  $\mathcal{B}$ .

(I.2) Reset  $\mathcal{A}^* \leftarrow \mathcal{A}^* - (i_k, j_k)$ .

At the end of the loop, we have an attack  $\mathcal{B}$  which is not successful, i.e.  $\mathcal{B}$  is defeated by some configuration  $\mathcal{C}'$ . If  $\mathcal{B} = \mathcal{A}$  we do nothing. Otherwise, we add to the master problem the Benders cut arising from  $\mathcal{B}$  and  $\mathcal{C}'$ .

(II) Set  $\mathcal{F} = \emptyset$  and  $\mathcal{C}' = \mathcal{C}$ . We run the following step, for  $k = 1, 2, \dots, |E - \mathcal{A}|$ :

(II.0) Let  $(i_k, j_k) \in \mathcal{A}^*$  be such that its flow has minimum absolute value.

(II.1) Test whether  $\mathcal{A}$  is successful against a controller which is forced to satisfy the condition

$$f_{ij} = 0, \quad \forall (i, j) \in \mathcal{F} \cup (i_k, j_k). \quad (2.72)$$

(II.2) If *not* successful, let  $\mathcal{C}'$  be the configuration that defeats the attack, and reset  $f^*$  to the corresponding power flow that satisfies (2.72). Reset  $\mathcal{F} \leftarrow \mathcal{F} \cup (i_k, j_k)$ ,

(II.3) Reset  $\mathcal{A}^* \leftarrow \mathcal{A}^* - (i_k, j_k)$ .

**Comment.** Procedure (I) produces attacks of increasing cardinality. At termination, if  $\mathcal{A} \neq \mathcal{B}$ , then  $\mathcal{C} \neq \mathcal{C}'$ , and yet  $\mathcal{B}$  is still not successful. In some sense in this

case  $\mathcal{C}'$  is a 'stronger' configuration than  $\mathcal{C}$  and the resulting Benders' cut 'should' be tighter than the one arising from  $\mathcal{C}$  and  $\mathcal{A}$ . We say 'should' because the previously discussed non-monotonicity property of power flow problems could mean that  $\mathcal{C}'$  does not defeat  $\mathcal{A}$ . Nevertheless, *in general*, the new cut is indeed stronger.

In contrast with (I), procedure (II) considers a progressively weaker controller. In fact, because we are forcing flows to zero, but we are not voiding Ohm's equation (1.8), the power flow that defeats  $\mathcal{A}$  while satisfying (2.72) is a feasible power flow for the original network. Thus, at termination of the loop,

$$\mathcal{C}' \text{ defeats every attack } \mathcal{A}' \text{ of the form } \mathcal{A}' = \mathcal{A} \cup \mathcal{E} \text{ for each } \mathcal{E} \subseteq \mathcal{F}.$$

Thus, if  $\mathcal{F} \neq \emptyset$  the cut obtained in (II) should be particularly strong.

One final comment on procedures (I) and (II) is that each “test” requires the solution of the controller's problem (2.29)-(2.32), a mixed-integer program. In our testing, such problems can be solved *extremely* fast using a commercial solver.

## 2.4 Implementation details

Our implementation is based on the updated algorithmic outline given in Section 2.3. In step (2.b.1) we add the Benders' cut with strengthening as in section 2.3.3, so we may add two cuts. We execute Step (2.b.2) so that the relaxation includes up to two full systems (2.43)-(2.45) at any time: when a system is added at iteration  $k$ , say,

it is replaced at iteration  $k + 4$  by the system corresponding to the configuration  $\mathcal{C}$  discovered in Step 2 of that iteration. Because at each iteration the cut(s) added in step (2.b.1) cut-off the current vector  $z^A$ , the procedure is guaranteed to converge.

## 2.5 Computational experiments the with min-cardinality model

In the experiments reported in this section we used a 3.4 GHz Xeon machine with 2 MB L2 cache and 8 GB RAM. All experiments were run using a single core. The LP/IP solver was Cplex v. 10.01, with default settings. Altogether, we report on 118 runs of our algorithm.

### 2.5.1 Data sets

For our experiments we used problem instances of two types; all problem instances are available for download.

- (a) Two of the IEEE “test cases” [20]: the “57 bus” case (57 nodes, 78 arcs, 4 generators) and the “118 bus” case (118 nodes, 186 arcs, 17 generators).
- (b) Two artificial examples were also created. One was a “square grid” network with 49 nodes and 84 arcs, 4 generators and 14 demand nodes. We also considered a modified version of this data set with 8 generators but equal sum  $\sum_{i \in \mathcal{G}} P_i^{max}$ .

We point out that square grids frequently arise as difficult networks for combinatorial problems; they are sparse while at the same time the “squareness” gives rise to symmetry. We created a second artificial network by taking two copies of the 49-node network and adding a random set of arcs to connect the two copies; with resistances (resp. capacities) equal to the average in the 49-node network plus a small random perturbation. This yielded a 98- node, 204-arc network, with 28 demand nodes, and we used 10, 12, and 15 generator variants.

In all cases, each of the generator output lower bounds  $P_i^{min}$  was set to a random fraction (but never higher than 80%) of the corresponding  $P_i^{max}$ .

An important consideration involves the capacities  $u_{ij}$  – should capacities be too small, or too large, the problem we study tends to become quite easy (i.e. the network is either trivially too tightly capacitated, or has very large capacity surpluses). For example, if a generator accounts for, say, 20% of all demand then in a tightly capacitated situation the removal of just one arc incident with that node could constitute a successful attack for  $To^{min}$  large. For the purposes of our study, we assumed *constant* capacities for the two networks in (a) and the initial network in (b); these constants were scaled, through experiments with our algorithm, precisely to make the problems we solve difficult. A topic of further research would be to analyze the  $N - k$  problem under regimes where capacities are significantly different across arcs, possibly reflecting a condition of pre-existing stress. In Section 3.5, which addresses experiments involving the second model in this paper, we consider some variations in

capacities.

### 2.5.2 Goals of the experiments

The experiments focus, primarily, on the computational workload incurred by our algorithm. First, does the running time, and, in particular, the number of iterations, grow very rapidly with network size? Second, does the number of generators exponentially impact performance – does the algorithm need to enumerate a large fraction of the generator configurations? In general, what features of a problem instance adversely affect the algorithm – i.e., is there any particular pattern among the more difficult cases we observe?

As noted above, previous studies in the literature have considered examples with up to 79 arcs (and sparse). In this paper, in addition to considering significantly larger examples (from a combinatorial standpoint) we also face the added combinatorial complexity caused by the generator configurations. Potentially, therefore, our algorithm could rapidly break down – thus, our focus on performance.

### 2.5.3 Results

Tables 2.1-2.4 contain our results; Tables 2.1 and 2.2 refer to the 57-bus and 118-bus case, respectively, Table 2.3 considers the artificial 49-node case and Table 2.4 considers the 98-node case.

We will make some preliminary remarks about the tables; this will be followed

<b>57 nodes, 78 arcs, 4 generators</b>					
Entries show: (iteration count), CPU seconds,					
Attack status ( <b>F</b> = cardinality too small, <b>S</b> = attack success)					
<b>Min. throughput</b>	<b>Attack cardinality</b>				
	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6</b>
<b>0.75</b>	(1), 2, <b>F</b>	(2), 3, <b>S</b>			
<b>0.70</b>	(1), 1, <b>F</b>	(3), 7, <b>F</b>	(48), 246, <b>F</b>	(51), 251, <b>S</b>	
<b>0.60</b>	(2), 2, <b>F</b>	(3), 6, <b>F</b>	(6), 21, <b>F</b>	(6), 21, <b>S</b>	
<b>0.50</b>	(2), 2, <b>F</b>	(3), 7, <b>F</b>	(6), 13, <b>F</b>	(6), 13, <b>F</b>	(6), 13, <b>S</b>
<b>0.30</b>	(1), 1, <b>F</b>	(2), 3, <b>F</b>	(2), 3, <b>F</b>	(2), 3, <b>F</b>	(2), 3, <b>F</b>

Table 2.1: *Min-cardinality problem, 57-bus test case*

by an analysis of the results. In the tables, each row corresponds to a value of the minimum throughput  $T^{min}$ , while each column corresponds to an attack cardinality. For each (row, column) combination, the corresponding cell is labeled “Not Enough” when using any attack of the corresponding cardinality (or smaller) the attacker will not be able to reduce demand below the stated throughput, while “Success” means that some attack of the given cardinality (or smaller) does succeed. Further, we also indicate the number of iterations that the algorithm took in order to prove the given outcome (shown in parentheses) as well as the corresponding CPU time in seconds. Thus, for example, in Table 2.2, the algorithm *proved* that using an attack of size 3 or

<b>118 nodes, 186 arcs, 17 generators</b>			
Entries show: (iteration count), CPU seconds,			
Attack status ( <b>F</b> = cardinality too small, <b>S</b> = attack success)			
	<b>Attack cardinality</b>		
<b>Min. throughput</b>	<b>2</b>	<b>3</b>	<b>4</b>
<b>0.92</b>	(4), 18, <b>S</b>		
<b>0.90</b>	(5), 180, <b>F</b>	(6), 193, <b>S</b>	
<b>0.88</b>	(4), 318, <b>F</b>	(6), 595, <b>S</b>	
<b>0.84</b>	(2), 23, <b>F</b>	(6), 528, <b>F</b>	(148), 6562, <b>S</b>
<b>0.80</b>	(2), 18, <b>F</b>	(5), 394, <b>F</b>	(7), 7755, <b>F</b>
<b>0.75</b>	(2), 14, <b>F</b>	(4), 267, <b>F</b>	(7), 6516, <b>F</b>

Table 2.2: *Min-cardinality problem, 118-bus test case*

smaller we cannot reduce total demand below 75% of the nominal value; this required 4 iterations which overall took 267 seconds. At the same time, in 7 iterations (6516 seconds) the algorithm found a successful attack of cardinality 4.

As a preliminary remark on the 57- and 118-bus cases, the significantly higher CPU times for the second case could be explained by the much larger number of arcs. The larger number of generators could also be a cause – however, the number of generator configurations in the second case is more than eight thousand times larger than in the first; much larger than the actual slowdown shown by the tables. In

general, we believe that the total number of generators plays a second-order role in the complexity of the algorithm, and that the primary agent behind complexity is the number of arcs.

Table 2.3 presents experiments with our algorithm on the 49-node, 84-arc network, first using 4 and then 8 generators. The sum of maximum generator outputs,  $\sum_{i \in \mathcal{G}} P_i^{max}$ , is the same for both cases; the demand nodes and their nominal demand values are identical.

Not surprisingly, the network with 8 generators proves more resilient – for example, an attack of cardinality 5 is needed to reduce throughput below 84%, whereas the same can be achieved with an attack of size 3 in the case of the 4-generator network. Also note that the running-time performance does not significantly degrade as we move to the 8-generator case, even though the number of generator configurations is 511. Not surprisingly, the most time-consuming cases are those where the adversary fails, since here the algorithm must prove that this is the case (i.e. prove that no successful attack of a given cardinality exists) while in a “success” case the algorithm simply needs to find *some* successful attack of the right cardinality.

<b>49 nodes, 84 arcs</b>				
Entries show: (iteration count), CPU seconds,				
Attack status ( <b>F</b> = cardinality too small, <b>S</b> = attack success)				
<b>4 generators</b>				
	<b>Attack cardinality</b>			
<b>Min. throughput</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>
<b>0.84</b>	(4), 129, <b>F</b>	(4), 129, <b>S</b>		
<b>0.82</b>	(4), 364, <b>F</b>	(35), 1478, <b>F</b>	(36), 1484, <b>S</b>	
<b>0.78</b>	(4), 442, <b>F</b>	(4), 442, <b>F</b>	(26), 746, <b>S</b>	
<b>0.74</b>	(4), 31, <b>F</b>	(11), 242, <b>F</b>	(168), 4923, <b>F</b>	(168), 4923, <b>S</b>
<b>0.70</b>	(3), 31, <b>F</b>	(4), 198, <b>F</b>	(10), 1360, <b>F</b>	(203), 3067, <b>S</b>
<b>0.62</b>	(4), 86, <b>F</b>	(4), 86, <b>F</b>	(131), 2571, <b>F</b>	(450), 34298, <b>F</b>
<b>8 generators</b>				
	<b>Attack cardinality</b>			
<b>Min. throughput</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>
<b>0.90</b>	(1), 13, <b>F</b>	(3), 133, <b>S</b>		
<b>0.86</b>	(1), 59, <b>F</b>	(5), 357, <b>F</b>	(13), 1291, <b>S</b>	
<b>0.84</b>	(1), 48, <b>F</b>	(4), 227, <b>F</b>	(41), 2532, <b>F</b>	(43), 2535, <b>S</b>
<b>0.80</b>	(1), 14, <b>F</b>	(4), 210, <b>F</b>	(8), 1689, <b>F</b>	(50), 2926, <b>S</b>
<b>0.74</b>	(1), 8, <b>F</b>	(3), 101, <b>F</b>	(10), 1658, <b>F</b>	(68), 23433, <b>F</b>

Table 2.3: *Min-cardinality problem, small network*

Table 2.4 describes similar tests, but now on the 98-node, 204-arc network, and using 10, 12 and 15 generators. Note that in the 15 generator case there are over 30000 generator configurations that must be examined, at least implicitly, in order to certify that a given attack is successful.

As in the case of Table 2.3, we note that the number of generators does not have an exponential impact on the overall running time. Also, a point worth dwelling on is that, with a few exceptions, the running time tends to *decrease*, for a given attack cardinality, once the minimum throughput is sufficiently past the threshold where no successful attack exists. This can be explained as follows: as the minimum throughput decreases the controller has more ways to defeat the attacker – if no attack can succeed a pure enumeration algorithm would have to enumerate all possible attacks; thus arguably our cutting-plane approach does indeed discover useful structure that limits enumeration (i.e., the cuts added in step (2.b.1) of our algorithm enable us to prove an effective lower bound on the minimum attack cardinality needed to obtain a successful attack).

Also the CPU time increases with decreasing minimum throughput so long as a successful attack *does* exist. This can also be explained, as follows: in order for the algorithm to terminate it must generate a successful attack, but this search becomes more difficult as the minimum throughput decreases (the controller has more options). Roughly speaking, in summary, we would expect the problem to be “easiest” near extreme values of the minimum threshold; all tables tend to confirm this expectation.

98 nodes, 204 arcs			
Entries show: (iteration count), CPU seconds, Attack status ( <b>F</b> = cardinality too small, <b>S</b> = attack success)			
10 generators			
	Attack cardinality		
Min. throughput	2	3	4
0.89	(2) 177, <b>F</b>	(30) 555, <b>S</b>	
0.86	(2), 195, <b>F</b>	(12), 5150, <b>F</b>	(14), 5184, <b>S</b>
0.84	(2), 152, <b>F</b>	(11), 7204, <b>F</b>	(35), 223224, <b>F</b>
0.82	(2), 214, <b>F</b>	(9), 11458, <b>F</b>	(16), 225335, <b>F</b>
0.75	(2), 255, <b>F</b>	(9), 5921, <b>F</b>	(17), 151658, <b>F</b>
0.60		(1), 4226, <b>F</b>	N/R
12 generators			
	Attack cardinality		
Min. throughput	2	3	4
0.92	(2), 318, <b>F</b>	(11), 7470, <b>F</b>	(14), 11819, <b>S</b>
0.90	(2), 161, <b>F</b>	(11), 14220, <b>F</b>	(18), 16926, <b>S</b>
0.88	(2), 165, <b>F</b>	(10), 11178, <b>F</b>	(15), 284318, <b>S</b>
0.84	(2), 150, <b>F</b>	(9), 4564, <b>F</b>	(16), 162645, <b>F</b>
0.75	(2), 130, <b>F</b>	(9), 7095, <b>F</b>	(15), 93049, <b>F</b>
15 generators			
	Attack cardinality		
Min. throughput	2	3	4
0.94	(2), 223, <b>F</b>	(11), 654, <b>S</b>	
0.92	(2), 201, <b>F</b>	(11), 10895, <b>F</b>	(18), 11223, <b>S</b>
0.90	(2), 193, <b>F</b>	(11), 6598, <b>F</b>	(16), 206350, <b>S</b>
0.88	(2), 256, <b>F</b>	(9), 15445, <b>F</b>	(18), 984743, <b>F</b>
0.84	(2), 133, <b>F</b>	(9), 5565, <b>F</b>	(15), 232525, <b>F</b>
0.75	(2), 213, <b>F</b>	(9), 7550, <b>F</b>	(11), 100583, <b>F</b>

Table 2.4: *Min-cardinality problem, larger network*

### 2.5.4 Comparison with pure enumeration

Here we compare our algorithm with the pure enumeration approach. As noted before, even though the controller’s problem (2.29)-(2.32) is a mixed-integer program, modern commercial solvers handle it with ease. Thus the enumeration approach, where we enumerate all possible attacks of a given cardinality, should be applicable at least in case of small problems. When a successful attack of the cardinality under consideration exists, the enumeration approach might “get lucky” and find it quickly; on the other hand when the given cardinality is insufficient to defeat the controller *all* attacks will need to be enumerated.

In order to effect a comparison, we first estimated, for each network, the time needed to solve one controller’s problem by choosing 1000 random attacks and averaging their solution time. We then multiplied this estimated average time by the number of cases that need to be enumerated.

In table 2.5 we tabulate the projected time(in seconds) it would take if a pure enumeration approach was used. The column ‘time per *MIP*’ indicates the average time (in seconds) taken by *CPLEX* to solve one instance of controller *MIP*. The following table summarizes our results; the numbers in parentheses indicate the total number of enumerations required, while each cell entry indicates the projected total CPU time.

		Attack cardinality		
		2	3	4
		(20706)	(1394204)	(70058751)
<b>10 generators</b>				
Min. throughput	Time per MIP			
<b>0.89</b>	0.051550	1067	71870	
<b>0.86</b>	0.052284	1083	72894	3662973
<b>0.84</b>	0.052853	1094	73687	3702811
<b>0.82</b>	0.055451	1148	77310	3884826
<b>0.75</b>	0.077676	1608	108296	5441916
<b>0.60</b>	0.110078	2279	153471	7711957
<b>12 generators</b>				
Min. throughput	Time per MIP			
<b>0.94</b>	0.0546667	1132	76216	
<b>0.92</b>	0.056725	1174	79086	3974116
<b>0.90</b>	0.052853	1685	113518	5704293
<b>0.88</b>	0.063490	1314	88518	4448030
<b>0.84</b>	0.090882	1881	126708	6367104
<b>0.75</b>	0.113589	2351	158365	7957849
<b>15 generators</b>				
Min. throughput	Time per MIP			
<b>0.92</b>	0.066127	1369	92195	4632806
<b>0.90</b>	0.052853	1685	113518	5704293
<b>0.88</b>	0.097627	2024	136290	6848586
<b>0.84</b>	0.116882	2420	162957	8188631
<b>0.75</b>	0.124245	2576	173496	8711927

Table 2.5: *Pure enumeration, 98 nodes 204 arcs*

### 2.5.5 One configuration problems

Min. Throughput	Min. Attack Size	Time (sec.)
0.95	2	2
0.90	3	20
0.85	4	246
0.80	5	463
0.75	6	2158
0.70	6	1757
0.65	7	3736
0.60	7	1345
0.55	8	2343
0.50	8	1328

Table 2.6: **49 nodes, 84 arcs, one configuration**

For completeness, in Table 2.6 we present results where we study *one-configuration* problems where the set of generators that the controller operates are *fixed*. For a given minimum demand throughput, the table shows the minimum attack cardinality needed to defeat the controller. Problems of this type correspond most closely to those previously studied in the literature. Here we applied the mixed-integer programming formulation (2.42)-(2.46) restricted to the single configuration  $\mathcal{C} = \mathcal{G}$ . Rather than use our algorithm, we simply solved these problems using Cplex, with default settings.

The table shows the CPU time needed to solve the minimum-cardinality problem corresponding to the minimum throughput shown in the first column. The point here is that our formulation (2.42)-(2.46) proves significantly effective in relation to previous methods.

Not surprisingly, the problem becomes *easier* as the attack cardinality increases – more candidates (for optimal attack) exist.

## Chapter 3

# A continuous, nonlinear attack problem

In this chapter we study a new attack model. Our goals are twofold:

- First, we want to more explicitly capture how the flow conservation equations (1.7) interact with the power-flow law (1.8) in order to produce flows in excess of capacities. More generally, we are interested in directly incorporating the interaction of the laws of physics with the graph-theoretic structure of the network into an algorithmic procedure. It is quite clear that the complexity of combinatorial problems on power flows, such as the min-cardinality attack problem, is primarily due to this interaction.
- Second, there are ways other than the outright disabling of a power line, in

which the functioning of the line could be hampered. There is a sense (see e.g. [35]) that recent real-world blackouts were not simply the result of discrete line failures; rather the system as a whole was already under “stress” when the failures took place. In fact, the operation of a power grid can be viewed as a noisy process, this in addition to the fact that even the AC power flow model is an approximation. Rather than attempting to model the noise and complexity in detail, we seek a generic modeling methodology that can serve to expose system vulnerabilities.

The approach we take relies on the fact that one can approximate a variety of complex physical phenomena that (negatively) affect the performance of a line by simply perturbing that line’s resistance (or, for AC models, the conductance, susceptance, etc.). In particular, by significantly increasing the resistance of an arc we will, in general, force the power flow on that line to zero. This modeling approach becomes particularly effective, from a system perspective, when the resistances of many arcs are simultaneously altered in an *adversarial* fashion.

Accordingly, our second model works as follows:

- (I) The attacker *sets* the resistance  $x_{ij}$  of any arc  $(i, j)$ .
- (II) The attacker is constrained: we must have  $x \in F$  for a certain known set  $F$ .
- (III) The output of each generator  $i$  is fixed at a given value  $P_i$ , and similarly each

demand value  $D_i$  is also fixed at a given value.

- (IV) The objective of the attacker is to maximize the overload of any arc, that is to say, the attacker wants to solve

$$\max_{x \in F} \max_{ij} \left\{ \frac{|f_{ij}|}{u_{ij}} \right\}, \quad (3.1)$$

where the  $f_{ij}$  are the resulting power flows.

In view of Lemma 1.3.1, (III) implies that in (d) the vector  $f$  is unique for each choice of  $x$ ; thus the problem is well-posed.

In future work we plan to relax (III). But (I), (II), (IV) already capture a great deal of the inherent complexity of power flows. Moreover, suppose that e.g. the value of (3.1) equals 1.25. Then even if we allow demands to be reduced, but insist that this be done under a *fair* demand-reduction discipline (one that decreases all demands by the same factor) the system will lose 25% of the total demand if overloads are to be avoided. Thus we expect that the impact of (III), under this model, may not be severe.

For technical reasons, it will become more convenient to deal with the inverses of resistances, the so-called “conductances.” For each  $(i, j) \in E$ , write  $y_{ij} = 1/x_{ij}$ , and let  $y$  be the vector of  $y_{ij}$ . Then we are interested in a problem of the form

$$\max_{y \in \Gamma} \max_{ij} \left\{ \frac{|f_{ij}(y)|}{u_{ij}} \right\}, \quad (3.2)$$

where  $\Gamma$  is an appropriate set, and as just discussed the notation  $f_{ij}(y)$  is justified.

A relevant example of a set  $\Gamma$  is that given by:

$$\sum_{ij} \frac{1}{y_{ij}} \leq B, \quad \frac{1}{x_{ij}^U} \leq y_{ij} \leq \frac{1}{x_{ij}^L} \quad \forall (i, j), \quad (3.3)$$

where  $B$  is a given 'budget', and, for any arc  $(i, j)$ ,  $x_{ij}^L$  and  $x_{ij}^U$  indicates a minimum and maximum value for the resistance at  $(i, j)$ . Suppose the initial resistances  $x_{ij}$  are all equal to some common value  $\bar{x}$ , and we set  $x_{ij}^L = \bar{x}$  for every  $(i, j)$ , and  $B = k\theta\bar{x} + (|E| - k)\bar{x}$ , where  $k > 0$  is an integer and  $\theta > 1$  is large. Then, roughly speaking, we are approximately allowing the adversary to make the resistance of (up to)  $k$  arcs "very large", while not decreasing any resistance, a problem closely reminiscent of the classical  $N - K$  problem. We will make this statement more precise later.

If the objective in (3.2) is convex then the optimum will take place at some extreme point. In general, the objective is not convex; but computational experience shows that we tend to converge to points that are either extreme points, or very close to extreme points (see the computational section).

Obviously, the problem we are describing differs from the standard N-k problem (though in Section 3.2 we present some comparisons). However, in our opinion we obtain a more effective approach for handling modeling noise; the much better scalability of the solution method provides further encouragement.

### 3.1 Solution methodology

Problem (3.2) is not smooth. However, it is equivalent to:

$$\max_{y,p} \sum_{ij} \frac{f_{ij}(y)}{u_{ij}} (p_{ij} - q_{ij}) \quad (3.4)$$

$$\text{s.t.} \quad \sum_{ij} (p_{ij} + q_{ij}) = 1, \quad (3.5)$$

$$y \in \Gamma, \quad p, q \geq 0. \quad (3.6)$$

In order to work with this formulation we need to develop a more explicit representation of the functions  $f_{ij}(y)$ . This will require a sequence of technical results given in the following section; however a brief discussion of our approach follows.

We sketch a proof of the equivalence. Suppose  $(y^*, p^*, q^*)$  is an optimal solution to (3.4-3.6); let  $(\hat{i}, \hat{j})$  be such that  $|f_{\hat{i}\hat{j}}(y^*)|/u_{\hat{i}\hat{j}} = \max_{ij} |f_{ij}(y^*)|/u_{ij}$ . Then without loss of generality if  $f_{\hat{i}\hat{j}}(y^*) > 0$  (resp.,  $f_{\hat{i}\hat{j}}(y^*) \leq 0$ ) we will have  $p_{\hat{i}\hat{j}}^* = 1$  (resp.,  $q_{\hat{i}\hat{j}}^* = 1$ ) and all other  $p^*, q^*$  equal to zero. This proves the equivalence once way and the converse is similar.]

Problem (3.4), although smooth, is not concave. A relatively recent research thrust has focused on adapting techniques of (convex) nonlinear programming to nonconvex problems. This work has resulted in a very large literature with interesting and useful results; see [18], [16]. Since one is attempting to solve non-convex minimization (and thus, NP-hard) problems, there is no guarantee that a global optimum will be

found by these techniques. One can sometimes assume that a global optimum is approximately known; and the techniques then are likely to converge to the optimum from an appropriate guess.

In any case, (a) the use of nonlinear models allows for much richer representation of problems, (b) the very successful numerical methodology backing convex optimization is brought to bear, and (c) even though only a local optimum may be found, at least one is relying on an agnostic, “honest” optimization technique as opposed to a pure heuristic or a method that makes structural assumptions about the nature of the optimum in order to simplify the problem.

In our approach we will indeed rely on this methodology – items (a)-(c) precisely capture the reasons for our choice. Points (a) and (c) are particularly important in our blackout context: we are very keen on modeling the nonlinearities, and on using a truly agnostic algorithm to root out hidden weaknesses in a network. And from a computational perspective, the approach does pay off, because we are able to comfortably handle problems with on the order of 1000 arcs.

As a final point, note that in principle one could rely on a branch-and-bound procedure to actually find the global optimum. This will be a subject for future research.

### 3.1.1 Some comments

As noted above, research such that described in [18], [16] has led to effective algorithms that adapt ideas from convex nonlinear programming to nonconvex settings. Suppose we consider a linearly constrained problem of the form  $\min \{\mathcal{F}(x) : Ax \geq b\}$ . Implementations such as LOQO [17] or IPOPT [19] require, in addition to some representation of the linear constraints  $Ax \geq b$ , subroutines for computing, at any given point  $\hat{x}$ ,

- (1) The functional value  $\mathcal{F}(\hat{x})$ ,
- (2) The gradient  $\nabla F(\hat{x})$ , and, ideally,
- (3) The Hessian  $\nabla^2 F(\hat{x})$ .

If routines for e.g. the computation of the Hessian are not available, then automatic differentiation (potentially incurring a computational cost). At each iteration the algorithms will evaluate the subroutines and perform additional work, i.e. matrix computations. Possibly, the cumulative run-time accrued in the computation of (1)-(3) could represent a large fraction of the overall run-time. Accordingly, there is a premium on developing fast routines for the three computations given above, especially in large-scale settings. This a major goal in the developments given below.

Additionally, a given optimization problem may admit many mathematically equivalent formulations. However, different formulations may lead to vastly different con-

vergence rates and run-times. This can become especially critical in large-scale applications. Broadly speaking, one can seek two (sometimes opposing) goals:

- (a) Compactness, i.e. “small” size of a formulation. This is important in the sense that numerical linear algebra routines (such as computation of Cholesky factorizations) is a very significant ingredient in the algorithms we are concerned with. A large reduction in problem size may well lead to significant reduction in run-times.
- (b) “Representativity”. Even if two formulations are equivalent, one of them may more directly capture the inherent structure of the problem, in particular, the interaction between the objective function and constraints.

Our techniques achieve *both* (a) and (b). We will construct an explicit representation of the functions  $f_{ij}(y)$  given above, such that the three evaluation steps discussed in (1)-(3) indeed admit efficient implementations using sparse linear algebra techniques. Moreover, the approach is “compact” in that, essentially, the only variables we deal with are the  $y_{ij}$  – we do not use the straightforward indirect representation involving not just the  $y$  variables, but also variables for the flows and the angles  $\theta$ . As we will argue below, our approach does indeed pay off. Our techniques lead to fast convergence, both in terms of the overall run-time and in terms of the iteration count, even in cases where the number of lines is on the order of 1000.

In what follows, we will first provide a review of some relevant material in linear algebra (Section 3.1.2). This material is used to make some structural remarks in Section 3.1.3. Section 3.2 presents a result relating the model to the standard N-k problem. Section 3.3 describes our algorithms for computing the gradient and Hessian of the objective function for problem (3.4-3.6). Finally, Section 3.4 presents details of our implementation, and Section 3.5 describes our numerical experiments.

### 3.1.2 Laplacians

In this section we present some background material on linear algebra and Laplacians of graphs – the results are standard but we include a proof for completeness and continuity. See [24] for relevant material.

As before we have a directed network  $G$  with  $n$  nodes and  $m$  arcs and with node-arc incidence matrix  $N$ . As before we assume  $G$  is connected. For a positive diagonal matrix  $Y \in \mathcal{R}^{m \times m}$  we will write

$$L = NYN^T, \quad J = L + \frac{1}{n} \mathbf{1}\mathbf{1}^T. \quad (3.7)$$

where  $\mathbf{1} \in \mathcal{R}^n$  is the vector  $(1, 1, \dots, 1)^T$ .  $L$  is called a *generalized Laplacian*. We have that  $L$  is symmetric positive-semidefinite. If  $\lambda_1 \leq \lambda_2 \leq \dots \leq \lambda_n$  are the eigenvalues of  $L$ , and  $v^1, v^2, \dots, v^n$  are the corresponding unit-norm eigenvectors, then

$$\lambda_1 = 0, \quad \text{but } \lambda_i > 0 \quad \text{for } i > 1, \quad (3.8)$$

because  $G$  is connected, and thus  $L$  has rank  $n - 1$ . The same argument shows that

since  $N\mathbf{1} = 0$ , we can assume  $v^1 = n^{-1/2} \mathbf{1}$ . Finally, since different eigenvectors are orthogonal, we have  $\mathbf{1}^T v^i = 0$  for  $2 \leq i \leq n$ .

**Lemma 3.1.1**  *$L$  and  $J$  have the same eigenvectors, and all but one of their eigenvalues coincide. Further,  $J$  is invertible.*

*Proof.* By (3.8),

$$Lv^1 = 0, \quad Jv^1 = \frac{1}{n} \mathbf{1}\mathbf{1}^T v^1 = v^1, \quad (3.9)$$

and further

$$Jv^i = Lv^i = \lambda_i v^i. \blacksquare \quad (3.10)$$

**Lemma 3.1.2** *Let  $b \in \mathcal{R}^n$ . Any solution to the system of equations  $L\alpha = b$  is of the form*

$$\alpha = J^{-1}b + \delta\mathbf{1},$$

for some  $\delta \in \mathcal{R}$ .

*Proof.* We have that  $L = \sum_{i=2}^n \lambda_i v_i v_i^T$ , and, by Lemma 3.1.1,  $J^{-1} = \sum_{i=2}^n \frac{1}{\lambda_i} v_i v_i^T + \frac{1}{n} \mathbf{1}\mathbf{1}^T$ . Now, the system of equations  $L\alpha = b$  is feasible if and only if  $b$  lies in the column space of matrix  $L$  and when it is so we can write  $b = \sum_{i=2}^n v_i (v_i^T b)$ . Assuming that this is the case, defining

$$\hat{\alpha} \doteq J^{-1}b = \sum_{i=2}^n \frac{1}{\lambda_i} v_i (v_i^T b) \quad (3.11)$$

we will have  $L\hat{\alpha} = b$ . Suppose that  $\bar{\alpha}$  is another vector satisfying  $L\bar{\alpha} = b$ . Then  $L(\bar{\alpha} - \hat{\alpha}) = 0$ , and consequently  $\bar{\alpha} = \hat{\alpha} + \delta\mathbf{1}$ , for some  $\delta$ . ■

Define

$$P = I - J.$$

Note that the eigenvalues of  $P$  are 0 and  $1 - \lambda_i$ ,  $2 \leq i \leq n$ ; thus if we have

$$\sum_{(u,v)} y_{uv} < 1/2, \quad \text{for all } u, \quad (3.12)$$

then it is not difficult to show that

$$0 < 1 - \lambda_i < 1, \quad \text{for all } i \geq 2. \quad (3.13)$$

(See [25] for related background). In such a case we can write

$$J^{-1} = (I - P)^{-1} = I + P + P^2 + P^3 + \dots, \quad (3.14)$$

in other words, the series in (3.14) converges to  $J^{-1}$ .

**Lemma 3.1.3** *For any integer  $k > 0$ ,  $P^k = (I - NYN^T)^k - \frac{1}{n}\mathbf{1}\mathbf{1}^T$ .*

*Proof.* We will prove the statement by induction on  $k$ , while also proving that  $(I - NYN^T)^k\mathbf{1}\mathbf{1}^T = \mathbf{1}\mathbf{1}^T$ . The case  $k = 1$  holds by definition. For the general inductive step, we have

$$\begin{aligned} P^{k+1} &= \left[ (I - NYN^T)^k - \frac{1}{n}\mathbf{1}\mathbf{1}^T \right] P \\ &= (I - NYN^T)^{k+1} - \frac{1}{n}(I - NYN^T)^k\mathbf{1}\mathbf{1}^T - \frac{1}{n}\mathbf{1}\mathbf{1}^T \left[ (I - NYN^T) - \frac{1}{n}\mathbf{1}\mathbf{1}^T \right] \\ &= (I - NYN^T)^{k+1} - \frac{1}{n}\mathbf{1}\mathbf{1}^T, \end{aligned}$$

because by induction

$$(I - NYN^T)^k \mathbf{1}\mathbf{1}^T = (I - NYN^T)^{k-1} (I - NYN^T) \mathbf{1}\mathbf{1}^T = \mathbf{1}\mathbf{1}^T,$$

and

$$\mathbf{1}\mathbf{1}^T \left[ (I - NYN^T) - \frac{1}{n} \mathbf{1}\mathbf{1}^T \right] = \mathbf{1}\mathbf{1}^T - \frac{1}{n} \mathbf{1}\mathbf{1}^T \mathbf{1}\mathbf{1}^T = 0.$$

The second inductive statement is similarly proved. ■

### 3.1.3 Observations

Consider problem (3.4)-(3.6), where, as per our modeling assumption (III),  $b$  denotes the (fixed) net supply vector, i.e.  $b_i = P_i$  for a generator  $i$ ,  $b_i = -D_i$  for a demand node  $i$ , and  $b_i = 0$  otherwise. Denoting by  $Y$  the diagonal matrix with entries  $1/y_{ij}$ , we have that given  $Y$  the unique power flows  $f$  and voltages  $\theta$  are obtained by solving the system

$$N^T \theta - Y^{-1} f = 0 \tag{3.15}$$

$$N f = b. \tag{3.16}$$

In what follows, it will be convenient to assume that condition (3.13) holds, i.e.  $1 - \lambda_i < 1$  for each  $i$ . Next we argue that without loss of generality we can assume that this holds.

As noted above, this condition will be satisfied if  $\sum_{(u,v)} y_{uv} < 1/2$  for all  $u$  (eq. (3.12) above). Suppose we were to scale all  $y_i$  by a common multiplier  $\mu > 0$ , and

instead of system (3.15-3.16), we consider:

$$N^T \theta - \mu^{-1} Y^{-1} f = 0$$

$$Nf = \mu b.$$

We have that  $(f, \theta)$  is a solution to (3.15-3.16) iff  $(\mu f, \theta)$  is a solution to (3.17-3.17).

Thus, if we assume that the set  $\Gamma$  in our formulation (3.4)-(3.6) is bounded (as is the case if we use (3.3)) then, without loss of generality, (3.12) indeed holds. Consequently, in what follows we will assume that

$$\exists r < 1 \text{ such that } 1 - \lambda_i < r \text{ for } 2 \leq i \leq n. \quad (3.17)$$

By Lemma 3.1.2 each solution to (3.15)-(3.16) is of the form

$$\theta = J^{-1}b + \delta \mathbf{1} \quad \text{for some } \delta \in \mathcal{R}, \quad (3.18)$$

$$f = YN^T J^{-1}b.$$

For each arc  $(i, j)$  denote by  $n_{ij}$  the column of  $N$  corresponding to  $(i, j)$ , i.e.,  $n_{ij} := Ne_{ij}$ , where  $e_{ij} \in \mathcal{R}^m$  is the vector with a 1 at entry  $(i, j)$  and zero otherwise. Using (3.14) we therefore have

$$\begin{aligned} f_{ij} &= y_{ij} n_{ij}^T [I + P + P^2 + P^3 + \dots] b, \quad \forall (i, j), \quad \text{and} \quad (3.19) \\ \theta_i - \theta_j &= n_{ij}^T \theta = n_{ij}^T [I + P + P^2 + P^3 + \dots] b = n_{ij}^T \sum_{k=0}^{\infty} P^k b, \end{aligned}$$

In the following we will be handling expressions with infinite series such as the above.

In order to facilitate the analysis we need a 'uniform convergence' argument, as fol-

lows. Given  $y \in \Gamma$ , note that we can write

$$P = P(y) = U(y)\Lambda(y)U(y)^T,$$

where  $U(y)$  is a unitary matrix and  $\Lambda(y)$  is the diagonal matrix containing the eigenvalues of  $P(y)$ . Hence, for any  $k \geq 1$  and any arc  $(i, j)$  (and dropping the dependence on  $y_{st}$  for simplicity),

$$|n_{ij}^T P^k b| = |n_{ij}^T U \Lambda^k U^T b| < \nu^k, \quad (3.20)$$

for some  $\nu < 1$ , by (3.17). We will rely on this bound below.

## 3.2 Relationship to the standard N-k problem

As a first consequence of (3.20) we have the following result, showing that appropriate assumptions the continuous model we consider is related to the network vulnerability models in Section 2.

**Lemma 3.2.1** *Let  $S$  be a set of arcs whose removal does not disconnect  $G$ . Suppose we fix the values  $y_{ij} = 1/x_{ij}$  for each arc  $(i, j) \notin S$ , and we likewise set  $y_{st} = \epsilon$  for each arc  $(s, t) \in S$ . Let  $(f(y), \theta(y))$  denote the resulting power flow, and let  $(\bar{f}, \bar{\theta})$  the solution to the power flow problem on  $G - S$ .*

*Then*

(a)  $\lim_{\epsilon \rightarrow 0} f_{st}(y) = 0$ , for all  $(s, t) \in S$ ,

(b) For any  $(u, v) \notin S$ ,  $\lim_{\epsilon \rightarrow 0} f_{uv}(y) = \bar{f}_{uv}$ .

(c) For any  $(u, v)$ ,  $\lim_{\epsilon \rightarrow 0} (\theta_u(y) - \theta_v(y)) = \bar{\theta}_u - \bar{\theta}_v$ .

*Proof.* (a) Let  $\tilde{G} = G - (s, t)$ , let  $\tilde{N}$  be node-arc incidence matrix of  $\tilde{G}$ ,  $\tilde{Y}$  the restriction of  $Y$  to  $E - (s, t)$ , and  $\tilde{P} = I - \tilde{N}\tilde{Y}\tilde{N}^T - \frac{1}{n}\mathbf{1}\mathbf{1}^T$ .

For any integer  $k \geq 1$  we have by Lemma 3.1.3

$$\lim_{\epsilon \rightarrow 0} P^k = \lim_{\epsilon \rightarrow 0} (I - NYN^T)^k - \frac{1}{n}\mathbf{1}\mathbf{1}^T = (I - \tilde{N}\tilde{Y}\tilde{N}^T)^k - \frac{1}{n}\mathbf{1}\mathbf{1}^T = \tilde{P}^k.$$

Consequently, by (3.19), for any  $(s, t) \in S$ ,

$$\lim_{\epsilon \rightarrow 0} f_{st} = \lim_{\epsilon \rightarrow 0} \left[ y_{st} n_{st}^T \left( \sum_{k=0}^{\infty} P^k \right) b \right] = \sum_{k=0}^{\infty} \left[ \lim_{\epsilon \rightarrow 0} y_{st} (n_{st}^T P^k b) \right] = 0,$$

where the exchange between summation and limit is valid because of (3.20). The proof of (b), (c) are similar. ■

Lemma 3.2.1 can be interpreted as describing a particular type of attack that is feasible for the adversary under our models. Our computational experiments show that the pattern assumed by the Lemma is approximately correct: given an attack budget, the attacker tends to concentrate most of the attack on a small number of arcs (essentially, making their resistance very large), while at the same time attacking a larger number of lines with a small portion of the budget.

### 3.3 Efficient computation of the gradient and Hessian

In the following set of results we determine efficient closed-form expressions for the gradient and Hessian of the objective in (3.2). As before, we denote by  $n_{ij}$  the column of the node-arc incidence matrix of the network corresponding to arc  $(i, j)$ . First we present a technical result. This will be followed by the development of formulas for the gradient (eqs. (3.22 - 3.23)) and the Hessian (eqs. (3.24-3.26)).

**Lemma 3.3.1** *For any integer  $k > 0$ , and any arc  $(i, j)$*

$$(a) \quad \mathbf{1}^T P^k = 0,$$

$$(b) \quad \frac{\partial}{\partial y_{ij}} [P^k b] = P \frac{\partial}{\partial y_{ij}} [P^{k-1} b] - n_{ij} n_{ij}^T P^{k-1} b.$$

*Proof.* Note that  $\mathbf{1}^T P = \mathbf{1}^T (I - J) = \mathbf{1}^T (I - NYN^T - \frac{1}{n} \mathbf{1} \mathbf{1}^T) = 0$ . Hence  $\mathbf{1}^T P^k = 0$ <sup>1</sup>.

---

<sup>1</sup>Continued on next page ...

$$\begin{aligned}
\frac{\partial}{\partial y_{ij}} [P^k b] &= \frac{\partial}{\partial y_{ij}} [P P^{k-1} b] \\
&= \frac{\partial}{\partial y_{ij}} \left[ \left( I - \sum_{(u,v) \in E} y_{uv} n_{uv} n_{uv}^T - \frac{1}{n} \mathbf{1}\mathbf{1}^T \right) P^{k-1} b \right] \\
&= \frac{\partial}{\partial y_{ij}} [P^{k-1} b] - \frac{\partial}{\partial y_{ij}} \left[ \left( \sum_{(u,v) \in E} y_{uv} n_{uv} n_{uv}^T \right) P^{k-1} b \right] - \frac{\partial}{\partial y_{ij}} \left[ \frac{1}{n} \mathbf{1}\mathbf{1}^T P^{k-1} b \right] \\
&= \frac{\partial}{\partial y_{ij}} [P^{k-1} b] - \frac{\partial}{\partial y_{ij}} \left[ \left( \sum_{(u,v) \in E} y_{uv} n_{uv} n_{uv}^T \right) P^{k-1} b \right] \\
&= \frac{\partial}{\partial y_{ij}} [P^{k-1} b] - \sum_{(u,v) \in E} \frac{\partial}{\partial y_{ij}} [y_{uv} n_{uv} n_{uv}^T P^{k-1} b] \\
&= \frac{\partial}{\partial y_{ij}} [P^{k-1} b] - \sum_{(u,v) \in E} \left[ \frac{\partial y_{uv}}{\partial y_{ij}} \right] n_{uv} n_{uv}^T P^{k-1} b - \sum_{(u,v) \in E} y_{uv} \frac{\partial}{\partial y_{ij}} [n_{uv} n_{uv}^T P^{k-1} b] \\
&= \frac{\partial}{\partial y_{ij}} [P^{k-1} b] - n_{ij} n_{ij}^T P^{k-1} b - \sum_{(u,v) \in E} y_{uv} n_{uv} n_{uv}^T \frac{\partial}{\partial y_{ij}} [P^{k-1} b] \\
&= \left[ I - \sum_{(u,v) \in E} y_{uv} n_{uv} n_{uv}^T \right] \frac{\partial}{\partial y_{ij}} [P^{k-1} b] - n_{ij} n_{ij}^T P^{k-1} b \\
&= \left[ P + \frac{1}{n} \mathbf{1}\mathbf{1}^T \right] \frac{\partial}{\partial y_{ij}} [P^{k-1} b] - n_{ij} n_{ij}^T P^{k-1} b \\
&= P \frac{\partial}{\partial y_{ij}} [P^{k-1} b] - n_{ij} n_{ij}^T P^{k-1} b + \frac{\partial}{\partial y_{ij}} \left[ \frac{1}{n} \mathbf{1}\mathbf{1}^T P^{k-1} b \right] \\
&= P \frac{\partial}{\partial y_{ij}} [P^{k-1} b] - n_{ij} n_{ij}^T P^{k-1} b.
\end{aligned}$$

where the third and the last equality follow from (a). ■

Using the above recursive formula we can write the following expressions:

$$\begin{aligned}
\frac{\partial}{\partial y_{ij}}[Pb] &= -n_{ij}n_{ij}^T b \\
\frac{\partial}{\partial y_{ij}}[P^2b] &= P \frac{\partial}{\partial y_{ij}}[Pb] - n_{ij}n_{ij}^T P b \\
\frac{\partial}{\partial y_{ij}}[P^3b] &= P^2 \frac{\partial}{\partial y_{ij}}[Pb] - P n_{ij}n_{ij}^T P b - n_{ij}n_{ij}^T P^2 b \\
\frac{\partial}{\partial y_{ij}}[P^4b] &= P^3 \frac{\partial}{\partial y_{ij}}[Pb] - P^2 n_{ij}n_{ij}^T P b - P n_{ij}n_{ij}^T P^2 b - n_{ij}n_{ij}^T P^3 b \\
&\vdots \\
\frac{\partial}{\partial y_{ij}}[P^k b] &= P^{k-1} \frac{\partial}{\partial y_{ij}}[Pb] - P^{k-2} n_{ij}n_{ij}^T P b - P^{k-3} n_{ij}n_{ij}^T P^2 b - \dots - n_{ij}n_{ij}^T P^{k-1} b
\end{aligned}$$

Consequently, defining

$$\tilde{\nabla}_{ij} = \frac{\partial}{\partial y_{ij}} [I + P + P^2 + \dots] b, \quad (3.21)$$

we have

$$\begin{aligned}
\tilde{\nabla}_{ij} &= [I + P + P^2 + \dots] \frac{\partial}{\partial y_{ij}} [Pb] - (I + P + P^2 + \dots) n_{ij}n_{ij}^T (P + P^2 + P^3 + \dots) b \\
&= -[I + P + P^2 + \dots] n_{ij}n_{ij}^T b - (I + P + P^2 + \dots) n_{ij}n_{ij}^T (I + P + P^2 + \dots - I) b \\
&= -(I + P + P^2 + \dots) n_{ij}n_{ij}^T (I + P + P^2 + \dots) b \\
&= -J^{-1} n_{ij}n_{ij}^T \theta,
\end{aligned}$$

where the last equality follows from (3.18) and (3.14), and the fact that  $n_{ij}^T \mathbf{1} = 0$ .

Using (3.19), the gradient of function  $f_{uv}(y)$  with respect to the variables  $y_{ij}$  can be written as:

$$\begin{aligned} \frac{\partial f_{uv}}{\partial y_{ij}} &= y_{uv} n_{uv}^T \frac{\partial}{\partial y_{ij}} [I + P + P^2 + P^3 + \dots] b = y_{uv} n_{uv}^T \tilde{\nabla}_{ij}, \quad (i, j) \neq (u, v) \\ \frac{\partial f_{ij}}{\partial y_{ij}} &= n_{ij}^T [I + P + P^2 + P^3 + \dots] b + y_{ij} n_{ij}^T \frac{\partial}{\partial y_{ij}} [I + P + P^2 + P^3 + \dots] b \\ &= n_{ij}^T \tilde{\nabla}_{ij} + y_{ij} n_{ij}^T \tilde{\nabla}_{ij}. \end{aligned} \quad (3.23)$$

We similarly develop closed-form expressions for the second-order derivatives. For  $(u, v) \neq (i, j), (u, v) \neq (h, k)$ , we have the following :

$$\begin{aligned} \frac{\partial^2 f_{uv}}{\partial y_{ij} \partial y_{hk}} &= y_{uv} n_{uv}^T [(I + P + P^2 + P^3 + \dots) n_{ij} n_{ij}^T (I + P + P^2 + P^3 + \dots) n_{hk} n_{hk}^T \\ &\quad + (I + P + P^2 + P^3 + \dots) n_{hk} n_{hk}^T (I + P + P^2 + P^3 + \dots) n_{ij} n_{ij}^T] \\ &= -y_{uv} n_{uv}^T J^{-1} [n_{ij} n_{ij}^T \tilde{\nabla}_{hk} + n_{hk} n_{hk}^T \tilde{\nabla}_{ij}]. \end{aligned} \quad (3.24)$$

Similarly, the remaining terms are:

$$\frac{\partial^2 f_{uv}}{\partial y_{uv}^2} = 2 n_{uv}^T \tilde{\nabla}_{uv} - 2 y_{uv} n_{uv}^T J^{-1} n_{uv} n_{uv}^T \tilde{\nabla}_{uv}, \quad (3.25)$$

$$\frac{\partial^2 f_{uv}}{\partial y_{uv} \partial y_{ij}} = n_{uv}^T \tilde{\nabla}_{ij} - y_{uv} n_{uv}^T J^{-1} [n_{ij} n_{ij}^T \tilde{\nabla}_i + n_{uv} n_{uv}^T \tilde{\nabla}_{ij}] \quad (3.26)$$

### 3.4 Implementation details

We use LOQO [17] to solve problem (3.4)-(3.6), using  $\Gamma = \left\{ y \geq 0 : \sum_{ij} \frac{1}{y_{ij}} \leq B \right\}$  with values of  $B$  that we selected. LOQO is an infeasible primal-dual, interior-point method applied to a sequence of quadratic approximations to the given problem. The

procedure stops if at any iteration the primal and dual problems are feasible and with objective values that are *close* to each other, in which case a local optimal solution is found. For numerical reasons, LOQO additionally uses an upper bound on the overall number of iterations to perform.

At each iteration of the method applied by LOQO, it requires the Hessian and gradient of the objective function and the constraints. The latter are easy to derive. Note that using (3.22), (3.23), (3.24)-(3.26) one can obtain compact, closed-form expressions for the Hessian and gradient of the objective. This approach requires the computation of quantities  $n_{uv}^T J^{-1} n_{ij}$  for each pair of arcs  $(i, j)$ ,  $(u, v)$ . At any given iteration, we compute and (appropriately) store these quantities (which can be done in  $O(n^2 + nm)$  space).

In order to compute  $n_{uv}^T J^{-1} n_{ij}$ , for given  $(i, j)$  and  $(u, v)$ , we simply solve the sparse linear system on variables  $\kappa$ ,  $\lambda$ :

$$N^T \kappa - Y^{-1} \lambda = 0 \quad (3.27)$$

$$N \lambda = n_{ij}. \quad (3.28)$$

As in (3.18), we have  $\kappa = J^{-1} n_{ij} + \delta \mathbf{1}$  for some real  $\delta$ . But then  $n_{uv}^T \kappa = n_{uv}^T J^{-1} n_{ij}$ , the desired quantity. In order to solve (3.27)-(3.28) we use Cplex (to solve a nominal linear program).

We point out that, alternatively, LOQO can perform symbolic differentiation in order to directly compute the Hessian and gradient. We could in principle follow this approach in order to solve a problem with objective (3.4), constraints (3.5), (3.6) and (1.7), (1.8). We prefer our approach because it employs fewer variables (we do not need the flow variables or the angles) and primal feasibility is far simpler.

In our implementation, we fix a value for the iteration limit, but apply additional stopping criteria:

- (1) If both primal and dual are feasible, we consider the relative error between the primal and dual values,  $\epsilon = \frac{PV - DV}{DV}$ , where 'PV' and 'DV' refer to primal and dual values respectively. If the relative error  $\epsilon$  is less than some desired threshold we stop, and report the solution as “ $\epsilon$ -locally-optimal.”
- (2) If on the other hand we reach the iteration limit without a stopping as in [(1)], then we consider the last iteration at which we had both primal and dual feasible solutions. If such an iteration exists, then we report the corresponding configuration of resistances along with the associated congestion value. If such an iteration does not exist, then the report the run as unsuccessful.

Finally, we provide to LOQO the starting point  $x_{ij} = x_{ij}^L$  for each arc  $(i, j)$ .

## 3.5 Experiments

In the experiments reported in this section we used a 2.66 GHz Xeon machine with 2 MB L2 cache and 16 GB RAM. All experiments were run using a single core. Altogether we report on 37 runs of the algorithm.

### 3.5.1 Data sets

For our tests we used the 58- and 118-bus test cases as in Section 2.5 with some variations on the capacities; as well as the 49-node “square grid” example and three larger networks created using the replication technique described at the start of Section 2.5: a 300-node, 409-arc network, a 600-node, 990-arc network, and a 619-node, 1368-arc network. Additional artificial networks were created to test specific conditions. All data sets are available for download.

We considered several three constraint sets  $\Gamma$  as in (3.3):

- (1)  $\Gamma(\mathbf{1})$ , where for all  $(i, j)$ ,  $x_{ij}^L = 1$  and  $x_{ij}^U = 5$ ,
- (2)  $\Gamma(\mathbf{2})$ , where for all  $(i, j)$ ,  $x_{ij}^L = 1$  and  $x_{ij}^U = 10$ ,
- (3)  $\Gamma(\mathbf{3})$ , where for all  $(i, j)$ ,  $x_{ij}^L = 1$  and  $x_{ij}^U = 20$ .

In each case, we set  $B = \sum_{(i,j)} x_{ij}^L + \Delta B$ , where  $\Delta B$  represents an “excess budget”. Note that for example in the case  $\Delta B = 30$ , under  $\Gamma(2)$ , the attacker can increase (from their minimum value) the resistance of up to 3 arcs by a factor of 10 (with 3

units of budget left over). And under  $\Gamma(1)$ , up to 6 arcs can have their resistance increased by a factor of 5. In either case we have a situation reminiscent of the  $N - k$  problem, with small  $k$ .

### 3.5.2 Focus of the experiments

In these experiments, we first study how the algorithm scales as network size increases (up to on other order of 1000) and as  $\Delta B$  increases. A second point of focus is the stability of the underlying (nonlinear) solver – e.g., does our algorithm frequently produce poor results because the solver experiences numerical difficulties.

Next, is there significant impact of alternate starting point choices for the algorithm, and does that constitute evidence of lack of robustness.

An important point we want to study concerns the *structure* of the solutions produced by the algorithm – what is the distribution of the  $x_{ij}$  obtained at termination, and is there a logic to that distribution?

A final set of experiments carry out a comparison with results obtained using the standard  $N - k$  model.

### 3.5.3 Basic run behavior

Tables 3.1-3.6 present results for different networks and scenarios. Each column corresponds to a different value of  $\Delta B$ . For each run, “**Max Cong**” is the numerical value of the maximum arc congestion (as in (3.1)) at termination. Additionally, we

present the CPU time (in seconds) taken by the algorithm, the number of iterations, and the termination criterion, which is indicated by “Exit Status”, with the following interpretation:

- (1) ' **$\epsilon$ -L-opt.**': the algorithm computed an  $\epsilon$ -locally-optimal solution.
- (2) '**PDfeas, Iter: lastItn**': the algorithm reached the iteration limit without finding an  $\epsilon$ -locally-optimal solution, but there was an iteration at which both primal and dual problems were feasible. 'lastItn' gives the last iteration at which both primal and dual solutions were feasible.
- (3) '**opt.**': the algorithm attained LOQO's internal optimality tolerance.

Tables 3.1 and 3.2 contain results for the 57- and 118-bus networks, respectively, both using set  $\Gamma(2)$ . Tables 3.3 and 3.4 handle the 49-node, 84-arc network, with 14 demand nodes and 4 generators that we considered in section 2.5, using sets  $\Gamma(1)$  and  $\Gamma(2)$  respectively.

Table 3.5 presents similar results for the network with 300 nodes, 409 arcs (42 generators and 172 loads). Note that for the runs  $\Delta B \geq 20$  the maximum load value is identical; the optimal solution values  $x_{ij}$  were nearly identical, independent of the initial point given to LOQO.

Table 3.6 contains the results for the network with 600 nodes, and 990 arcs (344 demand nodes and 98 generators) under set  $\Gamma(2)$ . We observed an interesting issue in the case where  $\Delta B = 10$ . Here, LOQO terminated with a solution in which for

Table 3.1: *57 nodes, 78 arcs,  $\Gamma(2)$* 

Iteration Limit: 700, $\epsilon = 0.01$				
	$\Delta B$			
	9	18	27	36
<b>Max Cong</b>	1.070	1.190	1.220	1.209
<b>Time (sec)</b>	8	19	19	19
<b>Iterations</b>	339	Limit	Limit	Limit
<b>Exit Status</b>	$\epsilon$ -L-opt.	PDfeas. Iter: 700	PDfeas. Iter: 700	PDfeas. Iter: 700

some arc  $(i, j)$ , both  $p_{ij} > 0$  and  $q_{ij} > 0$  (refer to formulation (3.4)-(3.6)). The value in parenthesis indicates the true value of the maximum congestion obtained by solving the network controller's problem if we were to use the resistance values  $(x_{ij})$  given by LOQO.

Finally, Table 3.7 presents experiments on the network with 649 nodes and 1368 arcs. Here, exit status 'DF' means that dual feasibility was achieved, but not primal feasibility. In such a case, the budget constraint (3.3) was violated – the largest

Table 3.2: *118 nodes, 186 arcs,  $\Gamma(2)$* 

**Iteration Limit: 700,  $\epsilon = 0.01$**

	$\Delta B$			
	9	18	27	36
<b>Max Cong</b>	1.807	2.129	2.274	2.494
<b>Time (sec)</b>	88	200	195	207
<b>Iterations</b>	Limit	578	Limit	Limit
<b>Exit Status</b>	PDfeas. Iter: 302	$\epsilon$ -L-opt.	PDfeas. Iter: 700	PDfeas. Iter: 700

(scaled) violation we observed was  $1e - 03$ . Even though this is a small violation, LOQO's threshold for primal feasibility is  $1e - 06$ ; we simply scaled down any resistance value  $x_{ij} > x_{ij}^{min}$  so as to obtain a solution satisfying (3.3). In Table 3.7, the quantity following the parenthesis in the "Max Cong" line indicates the resulting maximum congestion, obtained by solving a controller's problem on the network using the reduced resistance values.

Table 3.3: *49 nodes, 84 arcs, constraint set  $\Gamma(1)$* 

**Iteration Limit: 800,  $\epsilon = 0.01$**

	$\Delta B$					
	5	10	15	20	25	30
<b>Max Cong</b>	0.673054	0.750547	0.815623	0.865806	0.901453	0.951803
<b>Time (sec)</b>	12	15	18	19	28	22
<b>Iterations</b>	258	347	430	461	Limit	492
<b>Exit Status</b>	$\epsilon$ -L-opt.	$\epsilon$ -L-opt.	$\epsilon$ -L-opt.	$\epsilon$ -L-opt.	PDfeas Iter: 613	$\epsilon$ -L-opt.

**Comments:** The algorithm appears to scale, fairly reliably, to cases with approximately 1000 arcs; at that point the internal solver (LOQO) starts to develop some difficulties.

For any given network, note that the computed solution does vary as a function of the parameter  $\Delta B$ , and in the expected manner, as reflected by the “Max Cong” values. However the performance of the algorithm (running time or number of iterations) appears stable as a function of  $\Delta B$ . By “stable” what we mean is

Table 3.4: *49 nodes, 84 arcs, constraint set  $\Gamma(2)$* Iteration Limit: 800,  $\epsilon = 0.01$ 

	$\Delta B$					
	5	10	15	20	25	30
<b>Max Cong</b>	0.67306	0.751673	0.815584	0.8685	0.91523	0.9496
<b>Time (sec)</b>	9	13	34	3	29	30
<b>Iterations</b>	177	295	Limit	Limit	Limit	Limit
<b>Exit Status</b>	$\epsilon$ -L-opt.	$\epsilon$ -L-opt.	PDfeas Iter: 800	PDfeas Iter: 738	PDfeas Iter: 624	PDfeas Iter: 656

Table 3.5: *300 nodes, 409 arcs, constraint set  $\Gamma(2)$* Iteration Limit: 500,  $\epsilon = 0.01$ 

	$\Delta B$			
	9	18	27	36
<b>Max Cong</b>	0.590690	0.694101	0.771165	0.771165
<b>Time (sec)</b>	208	1248	981	825
<b>Iterations</b>	91	Limit	406	320
<b>Exit Status</b>	opt.	PDfeas Iter: 318	opt.	opt

that even though larger  $\Delta B$  values correspond to larger numbers of arcs that could be maximally interdicted, the workload incurred by the algorithm *does not* increase “combinatorially” as function of  $\Delta B$ . In our opinion, this is a significant distinction between this algorithm and the algorithm presented above for the  $N - k$  problem.

To put it differently, the algorithm in this section appears to allow for practicable analysis of the impact of multiple choices  $\Delta B$ ; this is a critical feature in that parameterizes the risk-aversion of the model.

Table 3.6: *600 nodes, 990 arcs, constraint set  $\Gamma(2)$* 

Iteration Limit: 300, $\epsilon = 0.01$					
	$\Delta B$				
	10	20	27	36	40
<b>Max Cong</b>	0.082735 (0.571562)	1.076251	1.156187	1.088491	1.161887
<b>Time (sec)</b>	11848	7500	4502	11251	7800
<b>Iterations</b>	Limit	210	114	Limit	208
<b>Exit Status</b>	PDfeas Iter: 300	$\epsilon$ -L-opt.	$\epsilon$ -L-opt.	PDfeas Iter: 300	$\epsilon$ -L-opt.

The above tables appear to show scalability, but what can be considered typical convergence behavior for the algorithm? Figure 3.1 presents a different view on the progress on a typical run. This run concerns the network in Table 3.6 (600 nodes, 990 arcs). The chart shows the primal value computed by LOQO on the last 299 iterations (the previous iterations include some values out of scale). It appears that the algorithm computes several local optima and then settles for a long hill climb.

Table 3.7: *649 nodes, 1368 arcs,  $\Gamma(2)$* 

**Iteration Limit: 500,  $\epsilon = 0.01$**

	$\Delta B$			
	20	30	40	60
<b>Max Cong</b>	(0.06732) 1.294629	1.942652	(0.049348) 1.395284	2.045111
<b>Time (sec)</b>	66420	36274	54070	40262
<b>Iterations</b>	Limit	374	Limit	Limit
<b>Exit Status</b>	DF	$\epsilon$ -L-opt.	DF	PDfeas Iter: 491

### 3.5.4 Alternative starting points

The question we consider here is how the final solution computed by the algorithm varies as a function of the starting point.

Table 3.8 shows runs using the network with 49 nodes and 90 arcs, using set  $\Gamma(3)$  with  $\Delta B = 57$ . For each run we list the maximum congestion at termination, and the top six arcs interdicted arcs, with the corresponding resistance values in parentheses. Four different choices of starting point were considered.




Figure 3.1: Primal values approaching termination.

For the first test the starting point was constructed by setting all resistances values to their lower bounds, i.e.,  $x_{ij} = 1$ . For the second, we set the resistance of three randomly selected arcs to the maximum value, while the remaining arcs were set to the lower bound, i.e  $x_{ij} = 20$ ,  $(i, j) \in I \subset E$ ,  $|I| = 3$ ,  $x_{kl} = 1$ ,  $(k, l) \in E \setminus I$ .

For the third test, we set the resistance of six randomly chosen arcs to half of the maximum, and the resistance of the remaining arcs were set to the minimum value, i.e,  $x_{ij} = 10$ ,  $(i, j) \in I \subset E$ ,  $|I| = 6$ ,  $x_{kl} = 1$ ,  $(k, l) \in E \setminus I$ . For the last test, we used, as starting point, the solution found in the test using the third starting point.

We note that there is a difference of (at most) 1.5% in the resulting congestion

value; while at the same time, and more crucially, the *set* of heavily interdicted arcs does not change. Results such as these are typical of what we have found in our experiments.

Table 3.8: *Impact of changing the starting point*

	Test			
	1	2	3	4
<b>Max Cong</b>	2.149673	2.127635	2.164906	2.181400
	29(7.79), 27(7.20)	29(7.79), 27(7.23)	29(8.73), 27(8.21)	29(8.37), 27(7.80)
<b>Top 6 Arcs</b>	41(7.03), 67(7.02)	41(6.91), 67(7.97)	41(7.03), 67(7.02)	41(7.57), 67(7.54)
	54(6.72), 79(5.71)	54(6.58), 79(5.53)	54(7.52), 79(6.48)	54(7.24), 79(6.26)

### 3.5.5 Distribution of attack weights

A significant question in the context of our model and algorithm concerns the structure of the attack chosen by the adversary. The adversary is choosing continuous values and has great leeway in how to choose them; potentially, for example, the

adversary could choose them uniformly equal (which, we would argue, would make the model quite uninteresting). The experiments in this section address these issues.

Table 3.9 describes the distribution of  $x_{ij}$  values at termination of the algorithm, for a number of networks and attack budgets. For each test we show first (in parentheses) the number of nodes and arcs, followed by the the attack budget and constraint set. The data for each test shows, for each range of resistance values, the number of arcs whose resistance falls in that range.

Table 3.9: **Solution histogram**

(49, 90) $\Delta B = 57, \Gamma(3)$		(300, 409) $\Delta B = 27, \Gamma(2)$		(600, 990) $\Delta B = 36, \Gamma(2)$	
Range	Count	Range	Count	Range	Count
[1, 1]	8	[1, 1]	1	[1, 1]	14
(1, 2]	72	(1, 2]	405	(1, 2]	970
(2, 3]	4	(2, 9]	0	(2, 5]	3
(5, 6]	1	(9, 10]	3	(5, 6]	0
(6, 7]	1			(6, 7]	1
(7, 8]	4			(7, 9]	0
(8, 20]	0			(9, 10]	2

Note that in each test case the adversary can increase the resistance of up to (roughly) three arcs to their maximum value. The pattern we observe in the table

is that in all three cases (i) many resistances take relatively small values and (ii) a small number of arcs have high resistance. Recall that for set  $\Gamma(2)$  we always have  $x_{ij}^{max} = 10$ , thus in the case of the (300, 409) network exactly three arcs are in the top range, while for the (600, 990) network two are in the top range and one more has relatively high resistance. In the case of the small network there is also a concentration 'at the top' though not in the very highest segment. We have observed this type of behavior in many runs.

### 3.5.6 Comparison with the minimum-cardinality attack model

The experiments in this section have as a first goal to effect a comparison with the  $N - k$  model as embodied by the mixed-integer programming approach considered in Section 2.2. A direct comparison on a case-by-case basis is not possible for a number of reasons (more on this below) but the purpose of the tests is to investigate whether on "similar" data the two models behave in similar ways.

A second goal of the experiments is to investigate the impact of one of our modeling assumptions (assumption (III) in Section 3), namely that demands and supplies are fixed. Ideally, our model should be *robust*, that is to say, the attack computed in a run of the algorithm should remain effective even if the controller has the power to adjust demands (so-called "load-shedding") .

A common thread runs through both goals. Turning to the first goal, it turns out

that the modeling assumption (III) is, in fact, what makes a direct comparison with the  $N - k$  model difficult. In principle, in the model in Section 2.2 one could set the desired minimum throughput to 100%, i.e. set  $T^{min} = 1.0$ . But in that case an attack that disconnects a demand node, even one with tiny demand, would be considered a success for the attacker.

To deal with these issues and still obtain a meaningful comparison, we set an example with 49 nodes and 90 arcs, in which no demand or generator node can be disconnected from the rest by removing up to three arcs. In each case there are 4 generators and 14 demand nodes. A family of problem instances was then obtained by scaling up all capacities by a common constant.

In terms of the mixed-integer programming model, in each instance we constructed one-configuration problem (generator lower bounds = 0) with  $T^{min} = 1$ , with the goal of investigating its vulnerability should up to three arcs be removed. Here we remind the reader that the algorithms 2.2 seek a minimum-cardinality attack that defeat the controller, and not the most severe attack of a given cardinality. Once our problem is solved the optimal attack is certified to be successful (and of minimum-cardinality), but not necessarily *the* most severe attack of *that* cardinality. Nevertheless, by adjusting our formulation (2.42)-(2.46) we can search for *a* successful

attack of any given cardinality, if it exists. The problem we obtain is:

$$t^* = \max t \quad (3.29)$$

$$\text{Subject to:} \quad \sum_{(i,j)} z_{ij} \leq k, \quad (3.30)$$

$$w_{\mathcal{C}}^T \psi^{\mathcal{C}} - t \geq 0, \quad \forall \mathcal{C} \subseteq \mathcal{G}, \quad (3.31)$$

$$A\psi^{\mathcal{C}} + Bz \leq b + B \quad \forall \mathcal{C} \subseteq \mathcal{G}, \quad (3.32)$$

$$z_{ij} = 0 \text{ or } 1, \quad \forall (i, j). \quad (3.33)$$

where  $k$  ( $= 3$ ) is a the number of arcs that the attacker can be remove. However, all this formulation guarantees is that  $t^* > 1$  if and only if a successful attack of cardinality  $\leq k$  exists – because of the nature of our formulation, when  $t^* > 1$  then  $t^*$  will be an approximation (in general, close) to the highest severity. A final detail is that since 3 lines will not disconnect the demands from the generators, the “severity” of an attack as per formulation (3.30)-(3.33) is the maximum arc congestion post-attack; thus putting the problem on a common ground with the nonlinear models we consider.

For our experiments we used  $\Gamma(1)$  (which allows resistances to increase by up to a factor of 20) with an excess budget of 60, on the network with 49 nodes, 90 arcs, 4 generators and 14 demand nodes. Note that the parameters allow the attacker to concentrate the budget on three arcs.

Table 3.10 contains the results. Each row corresponds to a different experiment,

where the value indicated by  $\sigma$  was used to scale all capacities (with respect to the original network). As  $\sigma$  increases the network becomes progressively more difficult to interdict.

In the 'MIP' section, the column headed 'Cong' indicates the congestion (max. arc overload) in the network obtained by removing the arcs produced by the mixed-integer programming model, and the column headed 'ATTACK' indicates which arcs were removed by the MIP.

In the 'NONLINEAR' section, 'Cong' indicates the maximum congestion resulting from the increase in resistances computed by the model. We also list the six arcs with highest resistance (and the resistance values).

The column headed 'Impact' indicates the maximum congestion obtained by deleting the three arcs with maximum resistance (as computed by the model), while leaving all other resistances unchanged.

We also performed additional tests with our second goal in mind, that is to say, testing the robustness of our solutions with respect to decreased demand levels. In the first test, we removed the top three (post-attack) highest resistance arcs, while keeping all other resistances unchanged, while allowing the controller to reduce total demand by up to 10% with the objective of minimizing the maximum congestion. This computation can be formulated as a linear program; the resulting minimum congestion value is shown in the column labeled 'I-10%'. Note that to some degree this test also addresses the comparison with the  $N - k$  model.

Similarly, but now using *all* resistance values as computed by the nonlinear model, and without removing any arcs, we allowed the controller to reduce total demand by up to 10%, again with the objective of minimizing the maximum congestion. The column labeled 'C-10%' shows the resulting congestion value.

Table 3.10: Comparison between models

$\sigma$	MIP		NONLINEAR				
	Cong	Attack	Cong	Top 6 Arcs	Impact	I- 10%	C- 10%
1.0	1.44088	29,32,45	2.14967	29(7.79), 27(7.20), 41(7.03), 67(7.02), 54(6.72), 79(5.71)	1.71758	1.33454	1.67145
1.2	1.43132	27,29,41	1.78687	29(8.28), 27(7.72), 41(7.32), 67(7.19), 54(6.92), 79(5.78)	1.43132	1.11211	1.38642
1.4	1.22685	27,29,41	1.55634	29(8.31), 27(7.74), 41(7.53), 67(7.48), 54(7.18), 79(6.15)	1.22685	0.95324	1.21329
1.6	1.07349	27,29,41	1.35995	29(8.18), 27(7.58), 41(7.53), 67(7.58), 54(7.22), 79(6.25)	1.07349	0.83409	1.05458
1.8	0.692489	18,57,60	1.20271	29(8.43), 27(7.90), 41(7.53), 67(7.48), 54(7.18), 79(6.12)	0.95421	0.74141	0.93595
2.0	0.68630	20,89,45	1.07733	29(7.87), 27(7.29), 41(7.04), 67(7.01), 54(6.70), 79(5.63)	0.85889	0.66727	0.83878

**Comments.** As before, we see that the solutions to the nonlinear model tend to concentrate the attack on a relatively small number of lines, while at the same time investing small portions of the attack budget on other lines. This helps highlight the significant overlap between the results from the two models. Note that in the cases for  $\sigma = 1.2, 1.4, 1.6$  the set of attacked lines show high correlation.

Moreover, the two models are consistent: the severity of the attack as measured by the maximum congestion levels (the 'Cong' parameters), for both models, decrease as the scale increases (as one should expect).

The last three columns of the table address our second set of questions – they appear to show that the solution computed by the nonlinear model is robust; even as the controller reduces total demand, the congestion level is proportionally reduced (only).

## Chapter 4

# Nonlinear Flow Model

Up to this point we have considered linearized power flow model which as discussed is an approximation to the underlying steady state dynamics of a power grid. In this chapter we consider a nonlinear power flow model and study some of its features. The nonlinear flow model is also known as “lossless” flow model (see [8], [9]) and can be thought of as a refinement to the linearized power flow model but is not as general as the AC power flow model (1.1)-(1.5).

We also consider the throughput maximization problem, which is defined as operating the power grid so as to satisfy maximum demand, when the underlying power flow model is nonlinear. Throughput maximization is an important operational problem that the network controller faces on a regular basis. Typically the network controller has access to average demand pattern at different geographical locations across the day. This demand pattern varies significantly throughout the day, both in relative

and absolute terms and hence the network controller has to solve this problem several times a day.

The throughput maximization problem is also important for contingency analysis. One approach to studying network vulnerability problem is to test the performance of network (defined in terms of fraction of total demand satisfied) against a set of pre-identified contingencies. The contingency list could be exponentially large and hence it is critical to solve this problem extremely fast.

We study both capacitated and uncapacitated versions of the problem. For the uncapacitated version we present efficient algorithms which provide lower and upper bounds to the objective values. Our computational experience with IEEE “test” cases as well as several randomly generated networks is very encouraging, both in terms of quality of solution (gap between lower and upper bounds) as well as the time taken to find the solution. We motivate why the problem is difficult for the uncapacitated version and finally prove that it is NP-hard.

## 4.1 Introduction

The dynamics of a power grid are typically modeled by a network together with equations describing power injections (generation and consumption) and power flows. Flows are governed by balance equations, and, significantly, by the laws of physics. The level of accuracy used to model the physics gives rise to several models, usually

described by nonlinear, non-convex systems of equation; the most complex of them being the so-called **AC** power flow models (1.1)-(1.5).

In chapter (1.3.2) we discussed **DC** power flow model and its salient properties. The **DC** power flow model is a linear approximation to the steady state system which has certain desirable properties from an optimization perspective. In this section, we discuss a refinement to the linear power flow model which incorporates some nonlinearities associated with the steady state **AC** power flow model. Our model which is introduced and analyzed in following sections is non-convex and nonlinear, but is not as general as the steady state **AC** power flow model.

Though a nonlinear model is a better approximation to the steady state **AC** power flow model, it comes with costs. From an optimization perspective, introducing non-convex nonlinearities makes the problem difficult specially in terms of getting guaranteed optimal solutions since all nonlinear optimizers provide solutions which are locally optimal.

In the following sections we analyze properties regarding uniqueness and non-monotonicity. We give an effective algorithm for the throughput maximization problem. Our algorithm provides lower and upper bounds for the objective function. Our computational experience shows that the algorithm that we propose is efficient on two fronts: First, the algorithm scales well to networks with thousands of arcs, and second, and perhaps more importantly, the gap between the lower and upper bounds which are found by the algorithm, is small in relative sense for large number

of instances.

## 4.2 Model Description

We consider a lossless system and assume the voltages on nodes are fixed: thus the dependence of real power injections at nodes on the phase angle variables  $\theta$  can be fully described by active power constraints, making the reactive power constraints unnecessary.

For a detailed account of lossless system we refer the interested reader to [3]. The “lossless” model has been studied in literature for identification of multiple contingencies from optimization and power systems communities. Pinar et al. [8],[9], use the “lossless” model and proposed a method that connected the feasibility boundary of power flow equations with spectral graph theory. Later, Pinar et al. [10] extended their approach to include reactive power and proposed a nonlinear programming formulation to identify critical lines, failure of which can cause severe blackouts.

We assume that the network has  $n$  nodes and  $m$  arcs. For each arc  $(i, j)$ , we use a variable  $f_{ij}$  to represent the (active power) flow on  $(i, j)$  – if  $f_{ij} > 0$  (resp.  $f_{ij} < 0$ ) indicates that power flows from  $i$  to  $j$  (resp., from  $j$  to  $i$ ). In addition, for each node  $i$  we will have a variable  $\theta_i$  (the “phase angle” at  $i$ ). Finally,  $b_i$  represents net power injection at any node  $i$ : if  $b_i > 0$ , then  $i$  represents a generator node, if  $b_i < 0$ , then  $i$  represents a demand node, and if  $b_i = 0$  then  $i$  represents a transshipment node.

The set of feasible power flows and phase angles consists of the solutions to the following system (**FEAS**):

$$\mathbf{FEAS} : \quad \sum_{(i,j) \in \delta^+(i)} f_{ij} - \sum_{(j,i) \in \delta^-(i)} f_{ji} = b_i \quad \forall i \in N \quad (4.1)$$

$$\sin(\theta_i - \theta_j) - x_{ij} f_{ij} = 0 \quad \forall (i, j) \in A \quad (4.2)$$

$$|\theta_i - \theta_j| \leq \frac{\pi}{2} \quad \forall (i, j) \in A \quad (4.3)$$

Constraint (4.1) models flow conservation, while (4.2) describes angle-equations. Constraint (4.3) is required for steady state stability of the system. Note that when the above system is feasible we must have

$$\sum_i b_i = 0.$$

Also, we note that the function  $\sin^{-1}$  has range  $[-\pi/2, \pi/2]$ ; consequently (4.2) and (4.3) and can simply be replaced by the constraints

$$\theta_i - \theta_j = \sin^{-1}(x_{ij} f_{ij}), \quad |\theta_i - \theta_j| \leq 1. \quad (4.4)$$

System **FEAS** can be thought of as a refinement to the linear (DC) power flow model, where model voltages on nodes are assumed fixed and angle difference  $\theta_i - \theta_j$  is assumed small, and thus approximated as  $\sin(\theta_i - \theta_j) \approx \theta_i - \theta_j$ . See [3] for further background.

There is a structural theorem that can be established with regards to system **FEAS**:

**Lemma 4.2.1** *Assume **FEAS** is feasible for a given demand-supply vector  $b$ . Then there is a unique vector of flows  $f_{ij}$  feasible for **FEAS**.*

In fact, there is a stronger theorem that can be shown, as follows.

**Theorem 4.2.2** *Consider the following system of equations:*

$$\mathbf{FLOW} : \quad \sum_{(i,j) \in \delta^+(i)} f_{ij} - \sum_{(j,i) \in \delta^-(i)} f_{ji} = b_i \quad \forall i \in N \quad (4.5)$$

$$\theta_i - \theta_j - h_{ij}(f_{ij}) = 0 \quad \forall (i, j) \in A \quad (4.6)$$

$$-u_{ij} \leq f_{ij} \leq u_{ij}, \quad (4.7)$$

where for each arc  $(i, j)$ ,

- $u_{ij} \geq 0$ ,
- The function  $h_{ij}$  is antisymmetric ( $h(t) = -h(-t)$ ) and strictly increasing in the range  $[-u_{ij}, u_{ij}]$ .

Then there is a unique vector of flows  $f_{ij}$  feasible for **FLOW**.

*Proof.* Let  $(f^1, \theta^1)$  and  $(f^2, \theta^2)$  be two solutions to **FLOW** and assume  $f^1 \neq f^2$ . We will show this leads to a contradiction. We can assume, without loss of generality, that

$$f_{ij}^2 \geq f_{ij}^1 \quad \text{for each arc } (i, j),$$

since any arc that does not satisfy this condition can be reversed, as previously (here we use the antisymmetry of  $h$ ).

Thus, defining  $f = f^2 - f^1$ , and  $\theta = \theta^2 - \theta^1$ , we have that  $0 \leq f$ , and

$$Nf = 0, \quad (4.8)$$

$$\theta_i - \theta_j = h_{ij}(f_{ij}^2) - h_{ij}(f_{ij}^1) \quad \text{for each } (i, j) \quad (4.9)$$

Since  $f \geq 0$  and  $f \neq 0$ , condition (4.8) shows that there is a *directed* cycle  $C$ , such that  $f_{ij} > 0$  for each arc  $(i, j) \in C$ . But the functions  $h_{ij}$  are strictly increasing; thus the right-hand side of equation (4.9) is strictly positive for each  $(i, j) \in C$ . Adding up these equations over arcs of  $C$  provides the desired contradiction. ■

Observe that if **FEAS** is feasible for a given demand-supply vector  $b$ , the capacities play no role in determining the unique flows. The **DC** power flow model also had a similar property.

**Definition 4.2.3** *Let  $N$  be the node-arc incidence matrix for the network and consider the diagonal matrix  $X \in \mathcal{R}^{m \times m} = \text{diag}(x_{ij})$ . We define the set  $S_\beta$  as follows:*

$$S_\beta := \{b \in \mathcal{R}^n \mid \exists (f, \theta) \in \mathcal{R}^{m+n} : Nf - b = 0, \\ -\sin^{-1}(Xf) + N^T\theta = 0\} \quad (4.10)$$

### 4.3 Throughput maximization

In the *throughput maximization problem* we want to choose generator outputs and demand amounts (both within limits) so as to deliver a maximum amount of total demand in a feasible way, i.e., while satisfying flow balance and angle-equations. Denoting by  $\mathcal{G}$  the set of generator nodes and by  $\mathcal{D}$  the set of demand nodes, the problem can be formulated as:

$$\mathbf{TP} : \max. \sum_{i \in \mathcal{G}} b_i \quad (4.11)$$

$$s.t. \quad b \in S_\beta \quad (4.12)$$

$$0 \leq b_i \leq \bar{b}_i \quad \forall i \in \mathcal{G} \quad (4.13)$$

$$\underline{b}_j \leq b_j \leq 0 \quad \forall j \in \mathcal{D} \quad (4.14)$$

We will use Lagrangian duality (for a comprehensive discussion, see [2]) to derive the *dual* to the problem **NC**; a convex optimization problem (i.e. minimizing a convex function over a convex set). This problem is generally easier than the original problem, both in terms of computational effort and optimality guarantees.

In the case of a convex optimization problem (subject to appropriate regularity constraints) there is “strong duality”, i.e. the value of the original problem and the dual are the same. Strong duality does not, in general, hold for non-convex optimization problems, in which case the dual merely provides a bound (a lower bound in the case of a minimization problem). The non-zero gap between the objective values of

the original problem and its dual is known as the “duality gap”, see [2].

By expanding constraints (4.12), the throughput maximization problem can be written as:

$$\mathbf{t}^* = \max \sum_{i \in \mathcal{G}} b_i \quad (4.15)$$

subject to

$$(\alpha_i) \quad \sum_{(i,j) \in \delta^+(i)} f_{ij} - \sum_{(j,i) \in \delta^-(i)} f_{ji} - b_i = 0 \quad \forall i \in N \quad (4.16)$$

$$(\beta_{ij}) \quad \theta_i - \theta_j - \sin^{-1}(x_{ij} f_{ij}) = 0 \quad \forall (i, j) \in A \quad (4.17)$$

$$(p_i^+, p_i) \quad 0 \leq b_i \leq \bar{b}_i \quad \forall i \in \mathcal{G} \quad (4.18)$$

$$(q_j, q_j^-) \quad \underline{b}_j \leq b_j \leq 0 \quad \forall j \in \mathcal{D} \quad (4.19)$$

In the formulation above we have written to the left of each constraint the corresponding Lagrange multiplier. In the case of e.g. (4.18),  $p_i$  is the multiplier for  $b_i \leq \bar{b}_i$  and  $-p_i^+$  is the multiplier for  $-b_i \leq 0$ . Thus, the Lagrangian function for **TP** is given by:

$$\begin{aligned} \mathcal{L}(b, f, \theta, \alpha, \beta, p, q, p^+, q^-) &= \mathbf{1}^T b_{\mathcal{G}} + \alpha^T (-b + Nf) + \beta^T (N^T \theta - \sin^{-1}(xf)) \\ &\quad + p^T (\bar{b}_{\mathcal{G}} - b_{\mathcal{G}}) + q^T (b_{\mathcal{D}} - \underline{b}_{\mathcal{D}}) + b_{\mathcal{G}}^T p^+ - b_{\mathcal{D}}^T q^- \end{aligned}$$

Here,  $\mathbf{1}$  is the vector of all ones of suitable dimension,  $\bar{\theta}$  is the vector with entries  $\bar{\theta}_i$  for

$i \in \mathcal{N}$ ,  $b_{\mathcal{G}}$  is the vector with entries  $b_i$  for  $i \in \mathcal{G}$  (and similarly with  $\bar{b}_{\mathcal{G}}$ ,  $b_{\mathcal{D}}$  and  $\underline{b}_{\mathcal{D}}$ ), and  $\sin^{-1}(xf)$  is the vector with entries  $\sin^{-1}(x_{ij}f_{ij})$ . We also have  $(p, q, p^+, q^-) \geq 0$ . The dual function  $l(\alpha, \beta, p, q, p^+, p^-)$  is defined as the maximum value of the Lagrangian function  $\mathcal{L}(\cdot)$  over  $(b, f, \theta)$ :

$$l(\alpha, \beta, p, q, p^+, q^-) = \sup_{b, f, \theta} \mathcal{L}(b, f, \theta, \alpha, \beta, p, q, p^+, q^-) \quad (4.20)$$

By convention, when the Lagrangian is unbounded above (as a function of  $(b, f, \theta)$ ), the dual function has value  $+\infty$ . Observe that the Lagrangian  $\mathcal{L}$  is an affine function in the dual variables  $(\alpha, \beta, p, q, p^+, q^-)$ ; thus, as is well known, since the dual function  $l(\cdot)$  is the point-wise maximum of a family of affine functions of  $(\alpha, \beta, p, q, p^+, q^-)$ , it is convex, even though problem **TP** is not.

We can use  $l(\alpha, \beta, p, q, p^+, q^-)$  to obtain upper bounds on the optimal value  $t^*$  of **TP**; for any  $(p, q, p^+, q^-) \geq 0$  and any  $\alpha, \beta$  we have :

$$l(\alpha, \beta, p, q, p^+, q^-) \geq t^* \quad (4.21)$$

[This is easy to verify by considering any feasible point  $(b, f, \theta)$  for **TP**.] Assuming  $l(\alpha, \beta, p, q, p^+, q^-) < +\infty$ , the dual function gives a nontrivial lower bound on  $t^*$  only when  $(p, q, p^+, q^-) \geq 0$  and  $(\alpha, \beta, p, q, p^+, q^-) \in \text{dom } l$ .

The best (smallest) upper bound obtained through this procedure is obtained by minimizing the dual function  $l(\cdot)$  over  $(\alpha, \beta, p, q, p^+, q^-)$  subject to  $(p, q, p^+, q^-) \geq 0$ :

$$\inf_{\alpha, \beta, p, q, p^+, q^-} l(\alpha, \beta, p, q, p^+, q^-) = \inf_{\alpha, \beta, p, q, p^+, q^-} \sup_{b, f, \theta} \mathcal{L}(b, f, \theta, \alpha, \beta, p, q, p^+, q^-)$$

Now we will construct an explicit representation of the “sup” above. Note that in the Lagrangian  $\mathcal{L}(\cdot)$ , each variable  $b_i$ , ( $i \in \mathcal{G}$ ) is free (unrestricted in sign) and its coefficient is  $1 - \alpha_i - p_i + p_i^+$ . Thus, unless

$$1 - \alpha_i - p_i + p_i^+ = 0, \quad (4.22)$$

the “sup” in (4.20) will take value  $+\infty$ . We can now use (4.22) to eliminate multiplier  $p_i^+$ . Similar conditions hold for variables  $b_j$ ,  $j \in \mathcal{D}$  and  $\theta_i$ ,  $i \in N$ . As a result, and recalling that  $p^+, q^- \geq 0$ , the following constraints can be imposed when computing the “sup” in (4.20):

$$\sum_{(i,j) \in \delta^+(i)} \beta_{ij} - \sum_{(j,i) \in \delta^-(i)} \beta_{ji} = 0 \quad \forall i \in N$$

$$\alpha_i + p_i \geq 1 \quad \forall i \in \mathcal{G}$$

$$-\alpha_j + q_j \geq 0 \quad \forall j \in \mathcal{D}$$

Next, the coefficient of variable  $f_{ij}$  in the Lagrangian  $\mathcal{L}$  is  $(\alpha_i - \alpha_j)f_{ij} - \beta_{ij} \sin^{-1}(x_{ij}f_{ij})$ . For each variable  $f_{ij}$  we need to maximize this expression for a given choice of  $(\alpha_i, \alpha_j, \beta_{ij})$  subject to the constraint that  $|x_{ij}f_{ij}| \leq 1$ . Let us formally define this function as

$$g(\alpha_i - \alpha_j, \beta_{ij}) := \max_{|x_{ij}f_{ij}| \leq 1} [(\alpha_i - \alpha_j)f_{ij} - \beta_{ij} \sin^{-1} f_{ij}].$$

Notice that since  $\alpha_i$  and  $\alpha_j$  appear in the function  $g(\cdot)$  only as the difference  $(\alpha_i - \alpha_j)$ , we can define a new variable  $\nu_{ij} := \alpha_i - \alpha_j$  and rewrite  $g(\cdot)$  as  $g(\nu_{ij}, \beta_{ij}) :=$

$$\max_{|x_{ij}f_{ij}| \leq 1} (\nu_{ij}f_{ij} - \beta_{ij} \sin^{-1}(x_{ij}f_{ij})).$$

In summary, the dual problem can be written as :

$$\mathbf{d}^* = \min_{\alpha, \beta, p, q, \nu} \sum_{i \in \mathcal{G}} p_i \bar{b}_i - \sum_{j \in \mathcal{D}} q_j \underline{b}_j + \sum_{(i,j) \in A} g(\nu_{ij}, \beta_{ij}) \quad (4.23)$$

subject to

$$\sum_{(i,j) \in \delta^+(i)} \beta_{ij} - \sum_{(j,i) \in \delta^-(i)} \beta_{ji} = 0 \quad \forall i \in N$$

$$\alpha_i + p_i \geq 1 \quad \forall i \in \mathcal{G}$$

$$-\alpha_j + q_j \geq 0 \quad \forall j \in \mathcal{D}$$

$$\alpha_i - \alpha_j - \nu_{ij} = 0 \quad \forall (i, j) \in A$$

$$p_i \geq 0 \quad \forall i \in \mathcal{G}, \quad q_j \geq 0 \quad \forall j \in \mathcal{D}$$

The function  $g(\nu_{ij}, \beta_{ij}) = \max_{|x_{ij}f_{ij}| \leq 1} (\nu_{ij}f_{ij} - \beta_{ij} \sin^{-1}(x_{ij}f_{ij}))$  is a point-wise maximum of a family of affine functions in  $(\nu_{ij}, \beta_{ij})$  and hence is convex (in  $\nu_{ij}, \beta_{ij}$ ). The next result provides an explicit representation for  $g(\nu_{ij}, \beta_{ij})$ ; for convenience we assume the arc  $(i, j)$  is given and we drop subscripts in the notation. We will also use the convention that  $0/0 = 1$ .

**Lemma 4.3.1** *The function  $g(\nu, \beta)$  is given by :*

$$g(\nu, \beta) = \begin{cases} \max \{ \nu x^{-1} \sqrt{1 - \frac{\beta^2}{\nu^2} x^2} - \beta \cos^{-1}(\frac{\beta}{\nu} x), -\nu x^{-1} + \frac{\pi}{2} \beta \} & \beta \geq 0, \nu \geq 0, \beta x \leq \nu \\ -\nu x^{-1} + \frac{\pi}{2} \beta & \beta \geq 0, \nu \geq 0, \beta x > \nu \\ -\nu x^{-1} + \frac{\pi}{2} \beta & \beta \geq 0, \nu \leq 0 \\ \max \{ -\nu x^{-1} \sqrt{1 - \frac{\beta^2}{\nu^2} x^2} + \beta \cos^{-1}(\frac{\beta}{\nu} x), \nu x^{-1} - \frac{\pi}{2} \beta \} & \beta \leq 0, \nu \leq 0, -\beta x \leq -\nu \\ \nu x^{-1} - \frac{\pi}{2} \beta & \beta \leq 0, \nu \leq 0, -\beta x > -\nu \\ \nu x^{-1} - \frac{\pi}{2} \beta & \beta \leq 0, \nu \geq 0 \end{cases} \quad (4.24)$$

*Proof.* We show the result for the case  $\beta \geq 0, \nu \geq 0, \beta \leq \nu$ , the remaining cases follow similarly. If  $\beta = \nu = 0$  the expression in (4.24) is correct as per our convention, and so we assume  $0 < \beta (\leq \nu)$ . Let  $\hat{f}$  denote the maximizer of the (univariate) function  $\hat{g}(f) := \nu f - \beta \sin^{-1}(xf)$ ; thus  $\hat{f}$  is either a stationary point or an extreme point. The stationary points for the function  $\hat{g}(f)$  are given by  $\pm x^{-1} \sqrt{1 - \frac{\beta^2}{\nu^2} x^2}$  and the extreme points are given by  $\pm x^{-1}$ . If  $\beta \geq 0, \nu \geq 0, \beta \leq \nu$ , the stationary point  $-x^{-1} \sqrt{1 - \frac{\beta^2}{\nu^2} x^2}$  and the extreme point  $x^{-1}$  can be immediately ruled out. Substituting the remaining two possible values for  $\hat{f}$  in  $\hat{g}(f)$ , we obtain  $g(\nu, \beta) = \max \left\{ \nu x^{-1} \sqrt{1 - \frac{\beta^2}{\nu^2} x^2} - \beta \cos^{-1}(\frac{\beta}{\nu} x), -\nu x^{-1} + \frac{\pi}{2} \beta \right\}$ . ■

As discussed prior to the proof,  $g(\nu, \beta)$  is convex. This can also be seen explicitly using the above representation. Next we will show how to approximate the dual problem (4.23) with a linear program.

## 4.4 Linear Programming Approximation

In the previous section we provided a (highly nonlinear) convex description for the dual (4.23). Here we will approximate that description with a linear program.

For a convex function  $h(y)$  in variable  $y$  the first-order Taylor approximation is in fact a global under-estimator of the function, i.e., for any point  $y_0$  in domain of function  $h$ ,

$$h(y) \geq \nabla h(y_0)^T (y - y_0) + h(y_0) \quad (4.25)$$

The nonlinearity arising in the dual problem (4.23) is due to functions  $g(\nu_{ij}, \beta_{ij})$  in the objective. Hence, using (4.25) and Lemma 4.3.1, each function  $g(\nu_{ij}, \beta_{ij})$  can be approximated as a maximum of several piecewise affine function in  $(\nu_{ij}, \beta_{ij})$ .

Next we show how to get a linear approximation for the function  $g(\nu_{ij}, \beta_{ij})$  (4.24).

**Lemma 4.4.1** *The first-order Taylor approximation to the function  $h(\nu, \beta) := \sqrt{1 - \frac{\beta^2}{\nu^2}} - \beta \cos^{-1}\left(\frac{\beta}{\nu}\right)$  defined on the domain:  $\beta \geq 0, \nu \geq 0, \beta \leq \nu$  at any point  $(\nu_i, \beta_i)$  such that  $\frac{\beta_i}{\nu_i} = k$  where  $k$  is a constant is given by :*

$$h(\nu, \beta) \geq -(\cos^{-1} k) \beta + (\sqrt{1 - k^2}) \nu \quad (4.26)$$

*Proof.* The gradient of the function  $h(\nu, \beta)$  is given by  $\frac{\partial h}{\partial \nu} = \sqrt{1 - \frac{\beta^2}{\nu^2}}$  and  $\frac{\partial h}{\partial \beta} = -\cos^{-1}\left(\frac{\beta}{\nu}\right)$ . ■

As mentioned earlier, in order to get a LP-approximation to the dual problem (4.23), we need to express the function  $g(\nu, \beta)$  (4.24) as a maximum of affine functions in variables  $(\nu, \beta)$ . From a computational point of view, one should look for a tight approximation using as few affine-pieces as possible. Since  $g(\nu, \beta)$  is a bi-variate function in  $(\nu, \beta)$ , the number of affine-pieces required to sufficiently approximate the function can be large as one would have to sample in both the variables  $\nu$  and  $\beta$ . Lemma (4.4.1) shows that the Taylor-series approximation to the function  $h(\nu, \beta)$  at all points of the form  $\frac{\beta}{\nu} = k$  for a given constant  $k$  is the same and given by (4.26). Hence one only needs to sample at points of the form  $\frac{\beta}{\nu} = k$  for different values of  $0 \leq k \leq 1$  and the number of pieces required to approximate the function is linear instead of quadratic.

For  $\beta \leq 0, \nu \leq 0, -\beta \leq -\nu$ , we can similarly approximate the function  $g(\nu, \beta)$  as a maximum of affine functions where the number of functions is linear. For other regions the function  $g(\nu, \beta)$  is affine, which we can simply add as constraints.

The LP-approximation to the dual problem (4.23) can now be given as:

$$\mathbf{lpd}^* = \min \sum_{i \in \mathcal{G}} \bar{b}_i p_i - \sum_{j \in \mathcal{D}} b_j q_j + \sum_{(i,j) \in A} t_{ij} \quad (4.27)$$

subject to

$$\varrho^k \nu_{ij} - \sigma^k \beta_{ij} - t_{ij} \leq 0 \quad \forall k \in K, \quad \forall (i, j) \in A \quad (4.28)$$

$$-\nu_{ij} + \frac{\pi}{2} \beta_{ij} - t_{ij} \leq 0 \quad \forall (i, j) \in A \quad (4.29)$$

$$-\varrho^k \nu_{ij} + \sigma^k \beta_{ij} - t_{ij} \leq 0 \quad \forall k \in K, \quad \forall (i, j) \in A \quad (4.30)$$

$$\nu_{ij} - \frac{\pi}{2} \beta_{ij} - t_{ij} \leq 0 \quad \forall (i, j) \in A \quad (4.31)$$

$$\sum_{(i,j) \in \delta^+(i)} \beta_{ij} - \sum_{(j,i) \in \delta^-(i)} \beta_{ji} = 0 \quad \forall i \in N \quad (4.32)$$

$$\alpha_i + p_i \geq 1 \quad \forall i \in \mathcal{G} \quad (4.33)$$

$$-\alpha_j + q_j \geq 0 \quad \forall j \in \mathcal{D} \quad (4.34)$$

$$\alpha_i - \alpha_j - x_{ij} \nu_{ij} = 0 \quad \forall (i, j) \in A \quad (4.35)$$

$$p_i \geq 0 \quad \forall i \in \mathcal{G}, \quad q_j \geq 0 \quad \forall j \in \mathcal{D}, \quad t_{ij} \geq 0 \quad \forall (i, j) \in A$$

In problem  $\mathbf{lpd}^*$  constraints (4.28)-(4.31) represent affine approximation for function  $g(\nu_{ij}, \beta_{ij})$ . The set  $K$  represents the values where  $(\nu_{ij}, \beta_{ij})$  is sampled, the constants  $\varrho^k > 0$  and  $\sigma^k > 0$  are gradients evaluated at point  $(\nu_{ij}^k, \beta_{ij}^k)$  and the variable  $t_{ij}$  estimates the function value  $g(\nu_{ij}, \beta_{ij})$ . Finally constraints (4.32)-(4.35) are the remaining affine constraints from problem  $\mathbf{d}^*$  (4.23).

We mention again that the LP-approximation to dual (4.27) is still a relaxation

of the network controller's problem (4.15). In particular, by weak-duality  $t^* \leq lpd^*$ , so the LP-approximation (4.27) gives the network controller more power in terms of demand satisfied.

## 4.5 Computational Results

Our algorithm finds upper and lower bounds to the optimal solution of the throughput maximization problem. We obtain an upper bound for **TP** by solving the *LP-approximation* to the dual problem **lpd** (we use CPLEX [15]). Having computed the solution to the linear program we can evaluate it using the exact objective for the dual; thereby obtaining an upper bound.

To obtain a *lower bound* for **TP** we use IPOPT [19] on formulation (4.11)-(4.14). IPOPT is a primal-dual interior-point algorithm with a filter line-search method for nonlinear programming; in our case IPOPT can only be guaranteed to find a *local* maximum but nevertheless we obtain a valid lower bound for **TP**.

In our experience with several instances of the problem, we observe that the duality gap is usually quite small.

We have also developed a heuristic which gives us another lower bound for **TP**. This involves linearizing the non-linear angle equation and iteratively solving a series

of linear programs. At the  $k$ -th iteration, we solve the linear program  $\mathbf{H}^k$  given by:

$$\begin{aligned} \mathbf{H}^k = \quad & \max \sum_{i \in \mathcal{G}} b_i \\ \text{subject to} \quad & \\ & \sum_{(i,j) \in \delta^+(i)} f_{ij} - \sum_{(j,i) \in \delta^-(i)} f_{ji} - b_i = 0 \quad \forall i \in N \\ & -\mathbf{d}_{ij}^k x_{ij} f_{ij} + \theta_i - \theta_j = 0 \quad \forall (i,j) \in A \\ & |\theta_i - \theta_j| \leq \pi/2 \quad \forall (i,j) \in A \\ & 0 \leq b_i \leq \bar{b}_i \quad \forall i \in \mathcal{G} \\ & \underline{b}_j \leq b_j \leq 0 \quad \forall j \in \mathcal{D} \end{aligned}$$

Here we are linearizing the angle equation :  $-x_{ij}f_{ij} + \sin(\theta_i - \theta_j) = 0$ . Formally, our heuristic algorithm proceeds as follows.

#### Heuristic for Lower Bound

**Initialize:**  $k = 1, d_{ij}^k = 1 \quad \forall (i,j) \in A$ .

**Iterate:**

1. Solve  $\mathbf{H}^k$ ; obtain angle values  $\theta_i^k \quad \forall i \in N$ .
2. Set  $d_{ij}^{k+1} = \frac{\theta_i^k - \theta_j^k}{\sin(\theta_i^k - \theta_j^k)}$  if  $\theta_i^k - \theta_j^k \neq 0$ , else  $d_{ij}^{k+1} = 1 \quad \forall (i,j) \in A$ .
3. Set  $e_{ij}^k = \frac{d_{ij}^{k+1}}{d_{ij}^k} - 1 \quad \forall (i,j) \in A$ .
- 4.a If  $\sum_{(i,j) \in A} e_{ij}^k \leq \epsilon$ , **EXIT**.
- 4.b Else  $k \leftarrow k + 1$ . **Go To** 1.

We believe that the lower bound heuristic besides providing a valid lower bound would specially be useful on very big networks (with several thousand arcs) where IPOPT may not scale very well.

Table 4.1 summarizes the results of our testing with different networks. For all networks we scaled demand and supply vectors by total demand, so the maximum demand that can be satisfied is 1. The first column gives the size of network, the column  $L_1$  gives the lower bound obtained by solving **TP** using IPOPT while  $L_2$  gives that obtained by our heuristic. The column  $U$  gives the upper bound obtained by solving the LP-relaxation to the dual problem while the last column gives the duality gap between the best found lower bound and upper bound. In each column the value in parenthesis is the time taken in seconds.

From the results, we see that the “duality” gap is quite low for most instances. The algorithm also scales well as the network size increases. The time taken to solve an instance is extremely small ranging from fraction of seconds for small networks to a few seconds on the big networks.

## 4.6 Capacitated Nonlinear Flow Model

In the previous section we considered throughput maximization problem when the underlying flow model is nonlinear. In this section we consider a slight generaliza-

Table 4.1: **Computational Results**

<b>Network Size</b>	$L_1$	$L_2$	<b>U</b>	<b>% gap</b>
<b>13 nodes, 30 arcs</b>	0.77180 (0.01)	0.77180 (0.01)	0.77914 (0.00)	0.951 %
<b>49 nodes, 84 arcs</b>	0.54800 (0.02)	0.54787 (0.03)	0.55911 (0.02)	2.027 %
<b>98 nodes, 204 arcs</b>	0.77345 (0.04)	0.77282 (0.13)	0.79076 (0.13)	2.236 %
<b>300 nodes, 409 arcs</b>	0.76749 (0.10)	0.76736 (0.19)	0.76813 (0.12)	0.083 %
<b>600 nodes, 990 arcs</b>	0.55429 (0.45)	0.55397 (0.68)	0.55999 (3.43)	1.028 %
<b>649 nodes, 1368 arcs</b>	0.67272 (1.22)	0.66756 (1.44)	0.67692 (6.94)	0.624 %

tion to the problem considered in the previous section. We look at the throughput maximization problem when the underlying flow model is nonlinear with the additional constraint that flow on every arc is within pre-specified capacity. Intuitively, the capacitated version of the throughput maximization problem seems like a minor modification to the uncapacitated one, but as we shall see, is considerably difficult in terms of finding good global solutions.

### 4.6.1 Model Description

We begin by specifying the model. As before,  $f_{ij}$  indicates power flow on arc  $(i, j)$ ,  $\theta_i$  represents “phase angle” at node  $i$ , while  $b_i$  denotes net supply emanating from node

*i*. The set of feasible power flows and phase angles consists of the solutions to the following system (**CFEAS**):

$$\mathbf{CFEAS} : \quad \sum_{(i,j) \in \delta^+(i)} f_{ij} - \sum_{(j,i) \in \delta^-(i)} f_{ji} = b_i \quad \forall i \in N \quad (4.36)$$

$$\sin(\theta_i - \theta_j) - x_{ij} f_{ij} = 0 \quad \forall (i, j) \in A \quad (4.37)$$

$$|f_{ij}| \leq u_{ij} \quad \forall (i, j) \in A \quad (4.38)$$

$$|\theta_i - \theta_j| \leq \frac{\pi}{2} \quad \forall (i, j) \in A \quad (4.39)$$

As before, constraint (4.36) models flow conservation, while (4.37) describes angle-equations. Constraint (4.38) specifies maximum flow permissible for each arc while (4.39) is required for steady state stability of the system. Observe that the system **CFEAS** reduces to the system **FEAS**((4.1)-(4.3)) if the capacity of every arc is greater than the inverse of resistance for the arc, i.e.,  $u_{ij} \geq 1/x_{ij}$  for all arc  $(i, j)$ .

Also, we note that the function  $\sin^{-1}$  has range  $[-\pi/2, \pi/2]$ ; consequently (4.37) (4.39) and (4.38) can simply be replaced by the constraints

$$\theta_i - \theta_j = \sin^{-1}(x_{ij} f_{ij}), \quad |\theta_i - \theta_j| \leq \overline{\theta}_{ij} \quad (4.40)$$

where  $\overline{\theta}_{ij} = \sin^{-1}(\min\{1, x_{ij} u_{ij}\})$ . Hence instead of capacity constraints (4.38) one can alternatively specify “phase” angle bound constraints for each arc  $(i, j)$  which can be represented by (4.40). Before going further, we define the set  $\bar{S}_\beta$ .

**Definition 4.6.1** Let  $N$  be the node-arc incidence matrix for the network and consider the diagonal matrix  $X \in \mathcal{R}^{m \times m} = \text{diag}(x_{ij})$ . The vector  $\bar{\theta} \in \mathcal{R}^m$  is the vector of all angle bounds  $\bar{\theta}_{ij}$  given by (4.40). We define the set of feasible supply-demand vectors  $\bar{S}_\beta$  as follows:

$$\begin{aligned} \bar{S}_\beta := \{b \in \mathcal{R}^n \mid \exists (f, \theta) \in \mathcal{R}^{m+n} : Nf - b = 0, \\ -\sin^{-1}(Xf) + N^T\theta = 0, |N^T\theta| \leq \bar{\theta}\} \end{aligned} \quad (4.41)$$

We further define the set of feasible supply vector  $\bar{S}_\beta^{\mathcal{G}}$  as the set  $\bar{S}_\beta$  restricted to the generator nodes  $\mathcal{G}$ .

Let  $\mathcal{G}$  be the set of generator nodes and  $\mathcal{D}$  be the set of demand nodes while  $\bar{b}_i$  be the maximum supply for generator node  $i \in \mathcal{G}$  and  $-\bar{b}_j$  be the maximum demand for demand node  $j \in \mathcal{D}$ . Similar to the uncapacitated version, we define the throughput maximization problem as following:

$$\begin{aligned} \mathbf{CTP} : \quad & \max. \sum_{i \in \mathcal{G}} b_i \\ \text{s.t.} \quad & b \in \bar{S}_\beta \\ & 0 \leq b_i \leq \bar{b}_i \quad \forall i \in \mathcal{G} \\ & \underline{b}_j \leq b_j \leq 0 \quad \forall j \in \mathcal{D} \end{aligned}$$

**Theorem 4.6.2** The capacitated version of throughput maximization problem (CPT) is NP-hard.

*Proof.* See Chapter 5.1. ■

### Non-Monotonicity

Now we try to motivate why the capacitated version of throughput maximization problem is difficult. The system of equations is highly nonlinear and non-convex, so we can not hope for an algorithm which will perform exceedingly well on all instances. Moreover, we will show by means of an example that the set  $\bar{S}_\beta$  can also be disjoint. This leads to disjunctions in the space of decision variables  $b$  (demand-supply vector). We believe this is the primary source of difficulty for solving the capacitated version of throughput maximization problem.

Consider the example in Figure 4.1: the network has 5 nodes and 6 arcs, with one source (node 0) and one sink (node 4). The resistances for arcs (0, 2) and (2, 4) are 2.50 and 4.00 respectively, while all other arcs have resistance of 1. The capacity of arc (1, 2) is 0.005 while capacity for any other arc  $(i, j)$  is chosen such that  $x_{ij}u_{ij} = 1$ .

We solve **CFEAS** given by (4.36)-(4.39) for different demand-supply values. While solving **CFEAS** we first ignore flow capacity constraints (4.38) to get unique value of flow for each arc. We then check if flow on any arc is above capacity. If that is the case then **CFEAS** is not feasible for current demand-supply value, otherwise **CFEAS** is feasible with flows as computed without capacity constraints. Since our example has a single generator and demand node, the demand-supply value is same




Figure 4.1: Non-monotone example.




Figure 4.2: Flow on arc (1,2) v Throughput.

as throughput.

Figure 4.2 presents flow on arc (1, 2) for different throughput values (computed without enforcing capacity constraints). From the plot it is evident that the flow on arc (1, 2) behaves in a non-monotonous fashion. Initially the flow increases (and is positive) but eventually decreases and changes sign as throughput value increases. Finally we apply capacity constraint (4.38) to get values of throughput for which the flow is within capacity. The set of feasible supply value is highlighted in the plot and is given by :

$$\bar{S}_\beta^{\mathcal{G}} = [0, 0.156] \cup [0.783, 0.8807] \quad (4.42)$$

In this example, the set of feasible supply values  $\bar{S}_\beta^{\mathcal{G}}$  as defined in Definition 4.6.1 is disjoint. This leads to disjunctions in the space of decision variables  $b$  (demand-supply vector). One can easily come up with examples where the feasible region is a collection of discrete points and continuous regions. The resolution of this disjunction requires either *branching* or *Integer Programming* based techniques.

# Chapter 5

## NP-completeness proof

This section outlines the proof for Theorem 4.6.2. Also refer to remark 5.1.6 at the end of the proof.

### 5.1 Proof of Theorem 4.6.2

We will use the following problem for NP-hardness proof.

**Problem 5.1.1** *We are given  $m$  clauses  $C_1, \dots, C_m$  involving  $n$  Boolean variables  $x_1, \dots, x_n$  where each clause  $C_i$  has exactly three variables. The **one-in-three 3-SAT** problem is to determine whether there exists a truth assignment to the variables so that each clause has exactly one true literal (and thus exactly two false literals).*

Given an instance of the Problem 5.1.1 we will transform it into an instance of our capacitated throughput maximization problem. Before that we need to define some

terms and introduce notations.

We define the “banana” network as following : Consider the network described by Figure 5.1: the network has 6 nodes and 7 arcs, with one source (node 0) and one sink (node 5). The resistances for arcs (0, 2) and (2, 4) are 2.50 and 4.00 respectively, while all other arcs have resistance of 1. The capacities of arcs (1, 2) and (4, 5) are 0.005 and 0.783 respectively, while capacity for any other arc  $(i, j)$  is chosen such that  $x_{ij}u_{ij} = 1$ . The network is similar to the one described by Figure 4.1 but has an additional arc ((4, 5)) and an extra node (5).




Figure 5.1: “Banana” network.

**Lemma 5.1.2** *The set of feasible supply values (as defined by 4.6.1) for the “banana” network is given by  $\bar{S}_\beta^G = [0, 0.156] \cup \{0.783\}$ .*

*Proof.* From (4.42) the set of feasible supply values for the network described by Figure 4.1 is  $[0, 0.156] \cup [0.783, 0.8807]$ . The “banana” network is same as the one described by Figure 4.1 other than the presence of an additional arc and node. Since

the extra arc  $(4, 5)$  is the only arc incident to the sink node 5, the throughput of the “banana” network is bounded by the capacity of this arc which is 0.783. Hence  $\bar{S}_\beta^G = [0, 0.156] \cup \{0.783\}$  for the “banana” network. ■

For the rest of the proof we define  $F := 0.156$  and  $G := 0.783$  as the lower and upper threshold values of throughput in the “banana” network. Hence, for the “banana” network  $\bar{S}_\beta^G = [0, F] \cup \{G\}$ .

For each variable in the one-in-three 3-SAT problem 5.1.1, we define a “variable” network (Figure 5.2) as following : Take *two* copies of the “banana” network and connect their sinks with a super-sink. The capacity of arcs incident to the super-sink is “large” while the resistance of these arcs is “small”, so that these arcs are never critical in any throughput maximization problem. The maximum demand at super-sink is  $F + G$  while the maximum supply at each of the two sources is  $G$ .

Figure 5.2 describes the “variable” network: *B-upper* and *B-lower* refer to the two copies of the “banana” network, node  $t$  is the super-sink while nodes  $s_1$  and  $s_2$  are the two sources.

**Lemma 5.1.3** *When the throughput value of the “variable” network is  $F + G$ , one of its component “banana” network carries a flow of exactly  $F$  while the other component carries a flow of exactly  $G$ .*




Figure 5.2: “Variable” network.

*Proof.* Let  $x$  and  $y$  denote the flows on the component “banana” networks. From Lemma 5.1.2 we know that the flows on component “banana” networks lie in a discontinuous interval, i.e.,  $x, y \in [0, F] \cup \{G\}$ . Since throughput is  $F + G$ , we must have  $x + y = F + G$ . The result follows immediately by using the above two in conjunction.

■

Next we define a “clause” network for every clause in the one-in-three 3-SAT problem 5.1.1. We take *three* copies of the “banana” network and connect their sinks with a super-sink. Each copy of the “banana” network refers to one of the three literals in the clause. As with the “variable” network the capacity of arcs incident to the super-sink is “large” while the resistance of these arcs is “small”. The maximum demand at super-sink is  $F + 2G$  while the maximum supply at each of the three sources is  $G$ .

Figure 5.3 describes the “clause” network. There is one “banana” network for each literal in the clause.




Figure 5.3: “Clause” network.

**Lemma 5.1.4** *When the throughput value of the “clause” network is  $F + 2G$ , one of its component “banana” network carries a flow of exactly  $F$  while the other two components carry flow of  $G$  each.*

*Proof.* Same as the proof of Lemma 5.1.3. ■

Now we define the “linking” arcs which will transform any instance of Problem 5.1.1 to our problem. For each clause we do the following:

- If a variable occurs as a *positive literal* we introduce two arcs : The first (second) arc connects the *left-most (right-most)* node of “banana” network corresponding to the given variable in the “clause” network with the *left-most (right-most)* node of the *upper* “banana” network in the “variable” network. This is illustrated in Figure 5.4.
- If a variable occurs as a *negative literal* we again introduce two arcs : The

first (second) arc connects the *left-most* (*right-most*) node of “banana” network corresponding to the given variable in the “clause” network with the *left-most* (*right-most*) node of the *lower* “banana” network in the “variable” network.

The capacity for every “linking” arc is 0 while the resistance for every such arc is 1. We will refer to the pair of “banana” networks between every clause and variable as “parallel” sub-networks. In Figure 5.4 the “banana” networks denoted by  $B$ -upper and  $x_1$  are “parallel”.




Figure 5.4: Linking Arcs.

This completes the transformation of any instance of one-in-three 3-SAT to an instance of our problem, we call the network so obtained as the “transformed” network.

Clearly the transformation was done in polynomial size in the input data.

**Lemma 5.1.5** *Any instance of one-in-three 3-SAT to our problem is satisfiable if and only if the maximum throughput value in the “transformed” network is  $n(F + G) + m(F + 2G)$ .*

*Proof.* Suppose the maximum throughput value is  $n(F + G) + m(F + 2G)$ . The “transformed” network has  $n + m$  demand nodes, one for each clause and variable. The maximum demand value at a demand node corresponding to a variable is  $F + G$  while the same for a demand node corresponding to a clause is  $F + 2G$ . Since the throughput value is  $n(F + G) + m(F + 2G)$  every demand node is being served its maximum demand value.

Since the capacities of arcs connecting the “variable” and “clause” network is zero, no amount of flow is transmitted between the two. Now, using Lemmas 5.1.3 and 5.1.4, we have that for every “variable” network one component carries a flow of  $F$  and the other carries a flow of  $G$  while for every “clause” network one component carries a flow of  $F$  and the other two carry flow of  $G$ .

Now we insist that the flow in optimal solution must have the following structure : the flow on the two components of “parallel” sub-network is same for every such “parallel” sub-network in the “transformed” network. This is illustrated by the following argument. Since the capacities of arcs connecting the components of “parallel” sub-network is zero, no amount of flow is transmitted between the two.

Moreover, by applying Ohm's Law (4.40), we must have that the angle difference between the two components of "parallel" sub-network is same. Hence the flows on the two components of "parallel" sub-network must be same.

Now we obtain a Boolean assignment by the following rule : We define the value of Boolean variable to be *TRUE* if and only if the in the "variable" network, the flow on the *upper* "banana" network is  $F$  and flow on the *lower* "banana" network is  $G$ .

We will show that the assignment so obtained is satisfiable. In each "clause" network, the literal with flow  $F$  corresponds to *TRUE* assignment while those with flow  $G$  correspond to *FALSE* assignments. Hence there is exactly one *TRUE* assignment and exactly two *FALSE* assignments.

Lets consider the case when a negative literal is given a *TRUE* assignment, which means that the corresponding variable should assume a *FALSE* assignment. For a negative literal the "parallel" sub-network is obtained by connecting the end-points of the lower "banana" network in the "variable" network to that in the "clause" network. Since the negative literal is *TRUE* the corresponding "banana" network in the "clause" network as well as the lower "banana" network in the variable network will carry a flow of  $F$ , hence the upper "banana" network in the "variable" network must carry a flow of  $G$ . Hence, from the rule defined above, the corresponding variable will be given an assignment of *FALSE*. Hence the rule is consistent with the assignment that was anticipated. Similar results can be easily shown for the remaining cases.

The other way round can be proved similarly by starting with the assignment rule and then following steps in reverse order. ■

**Remark 5.1.6** *Figure 4.2 that we plotted before showed flow on arc (1, 2) as a function of throughput of the network (described by figure 4.1). There are two basic problems with the proof:*

- (1) *In the proof, we need to assume that  $f_{12}$ , as a function of throughput, has the desired structure between the two points where the curve crosses the horizontal line (at the capacity  $u_{12}$ ). That is to say, we need to assume that the curve first increases monotonely, and then decreases monotonely. However, we plotted figure 4.2 by sampling several values of throughput and calculating  $f_{12}$  at those values.*
- (2) *In fact, the two points where the curve crosses the horizontal line probably have irrational values, so we cannot express them exactly in the NP-completeness proof.*

*Of the two problems, (2) is the harder one, but actually we can fix them both at once. The following result does the job.*

Before we show the result, lets introduce some notation : Given a solution  $(f, \theta)$ , let us denote by  $T(f, \theta)$ , or  $T$  for short, the throughput, i.e.  $f_{01} + f_{02}$ . Lets also denote the angle difference between two nodes  $i$  and  $j$  by  $\theta_{ij}$ , i.e.  $\theta_{ij} = \theta_i - \theta_j$ .

**Theorem 5.1.7** *For any  $\epsilon > 0$  there exists  $\delta > 0$  with the following property: if  $(f, \theta)$  and  $(\hat{f}, \hat{\theta})$  be feasible solutions with  $T(f, \theta) < T(\hat{f}, \hat{\theta}) < T(f, \theta) + \delta$ , then  $|f_{12} - \hat{f}_{12}| \leq \epsilon$ .*

*Proof.* We will assume that  $\delta > 0$  is given and will show later how to choose it as a function of  $\epsilon$ . So assume that  $T(f, \theta) < T(\hat{f}, \hat{\theta}) < T(f, \theta) + \delta$ . Without loss of generality assume  $\hat{\theta}_0 = \theta_0$ . Since  $T(f, \theta) < T(\hat{f}, \hat{\theta})$  we must have  $\hat{\theta}_1 < \theta_1$  or  $\hat{\theta}_2 < \theta_2$ , or both.

Assume first that  $\hat{\theta}_1 < \theta_1$  and  $\hat{\theta}_2 \geq \theta_2$  ( the symmetric case,  $\hat{\theta}_1 \geq \theta_1$  and  $\hat{\theta}_2 \leq \theta_2$ , is identical and will be skipped).

Since  $\hat{\theta}_{21} > \theta_{21}$ , we have  $\hat{f}_{21} > f_{21}$ . Also,  $\hat{f}_{01} > f_{01}$ . So  $\hat{f}_{13} > f_{13}$  and  $\hat{\theta}_{13} > \theta_{13}$ , and  $\hat{\theta}_3 < \theta_3$ . Similarly,  $\hat{f}_{34} > f_{34}$ , and so  $\hat{\theta}_{34} > \theta_{34}$ , and  $\hat{\theta}_4 < \theta_4$ . Thus thus  $\hat{\theta}_{24} > \theta_{24}$ , and  $\hat{f}_{24} > f_{24}$ .

$$\text{Now, } T(\hat{f}, \hat{\theta}) = \hat{f}_{24} + \hat{f}_{13} = \hat{f}_{24} + \hat{f}_{01} + \hat{f}_{21} > f_{24} + f_{01} + \hat{f}_{21} = T(f, \theta) + \hat{f}_{21} - f_{21}.$$

$$\text{So, } f_{21} < \hat{f}_{21} < f_{21} + \delta.$$

Assume next that  $\hat{\theta}_1 < \theta_1$  and  $\hat{\theta}_2 < \theta_2$ . Then for  $i = 1, 2$ ,  $f_{0i} < \hat{f}_{0i}$ , and so  $f_{0i} < \hat{f}_{0i} < f_{0,i} + \delta$ , and using the second-order Taylor approximation,

$$\theta_{0i} \leq \hat{\theta}_{0i} + O(\delta^{1/2})$$

(when  $|\theta_{0i}|$  is near  $\pi/2$  the first-order term goes to zero), and so

$$|\hat{\theta}_i - \theta_i| \leq O(\delta^{1/2}).$$

From this we obtain:

$$|\hat{f}_{21} - f_{21}| \leq O(\delta^{1/2}).$$

Using  $\delta = O(\epsilon^2)$  the theorem follows. ■

We constructed the curve in figure 4.2 by sampling on a fine grid. The theorem shows that the actual functional value can differ from what the curve shows, but only by very small amounts. This allows the NP-completeness proof to go through.

# Bibliography

- [1] R. K. Ahuja, T. L. Magnanti, and J. B. Orlin. *Network Flows: Theory, Algorithms, and Applications*. Prentice Hall, NJ (1993).
- [2] S. Boyd and L. Vandenberghe, *Convex Optimization*, *Cambridge University Press* (2004).
- [3] G. Andersson, *Modelling and Analysis of Electric Power Systems*. Lecture 227-0526-00, Power Systems Laboratory, ETH Zürich, March 2004. Download from <http://www.eeh.ee.ethz.ch/downloads/academics/courses/227-0526-00.pdf>.
- [4] J. Salmeron, K. Wood, and R. Baldick, Analysis of Electric Grid Security Under Terrorist Threat, *IEEE Trans. Power Systems* **19** (2004), 905–912.
- [5] R. Alvarez, Interdicting Electric Power Grids, Masters' Thesis, U.S. Naval Postgraduate School, 2004.

- [6] J. Arroyo and F. Galiana, On the Solution of the Bilevel Programming Formulation of the Terrorist Threat Problem, *IEEE Trans. Power Systems*, Vol. 20 (2005), 789–797.
- [7] D. Bienstock and S. Mattia, Using mixed-integer programming to solve power grid blackout problems , *Discrete Optimization* 4 (2007), 115–141.
- [8] A. Pinar, J. Meza, V. Donde, and B. Lesieutre, Optimization Strategies for the Vulnerability Analysis of the Power Grid, submitted to *SIAM Journal on Optimization* (2007).
- [9] V. Donde, V. Lopez, B. Lesieutre, A. Pinar, C. Yang, and J. Meza, Identification of severe multiple contingencies in electric power networks, *Proceedings of the 37th North American Power Symposium, Ames, Iowa* (2005).
- [10] A.Pinar, A. Reichert, and B.Lesieutre, Computing Criticality of Lines in Power Systems, *Lawrence Berkeley National Laboratory. Paper LBNL-61763* (2006).
- [11] B. Lesieutre, A. Pinar, and S. Roy, Power system extreme event detection: The vulnerability frontier, *Proc. 41st Hawaii International Conference on System Sciences, Hawaii* (2008).
- [12] B. Lesieutre, S. Roy, V. Donde, and A. Pinar, Power sytem extreme event screening using graph partitioning,*Proceedings of the 38th North American Power Symposium, Carbondale, Illinois* (2006).

- [13] J.F. Benders, Partitioning procedures for solving mixed variables programming problems, *Numerische Mathematik* **4** (1962), 238–252.
- [14] D. Braess, Über ein Paradox der Verkehrsplanung, *Unternehmensforschung* Vol. 12 (1968) 258–268.
- [15] ILOG CPLEX 11.0. ILOG, Inc., Incline Village, NV.
- [16] H. Y. Benson, D. F. Shanno, and R. J. Vanderbei, Interior-point methods for nonconvex nonlinear programming: jamming and comparative numerical testing, *Math. Programming* **99**, 35 – 38 (2004).
- [17] Vanderbei, R. 1997. LOQO User’s manual, *Statistics and Operations Research* Technical report No SOR-97-08, Princeton University.
- [18] R. Fletcher, N. I. M. Gould, S. Leyffer, Ph. L. Toint, and A. Wächter, Global convergence of trust-region SQP-filter algorithms for general nonlinear programming, *SIAM J. Optimization* **13**, 635–659 (2002).
- [19] A. Wächter and L. T. Biegler, On the Implementation of a Primal-Dual Interior Point Filter Line Search Algorithm for Large-Scale Nonlinear Programming, *Mathematical Programming* **106**, 25–57, (2006).
- [20] The IEEE reliability test system–1996, *IEEE Trans. Power Syst.*, vol. 14 (1999) 1010 - 1020.

- [21] S.T. DeNegre and T.K. Ralphs, A Branch-and-cut Algorithm for Integer Bilevel Linear Programs, COR@L Technical Report, Lehigh University (2008).
- [22] U. Janjarassuk and J. T. Linderoth, Reformulation and Sampling to Solve a Stochastic Network Interdiction Problem, to appear, *Networks* (2008).
- [23] C. Lim and J.C. Smith, Algorithms for Discrete and Continuous Multicommodity Flow Network Interdiction Problems, *IIE Transactions* **39**, 15-26, 2007.
- [24] S. Boyd, Convex Optimization of Graph Laplacian Eigenvalues, *Proc. International Congress of Mathematicians* **3** (2006), 1311–1319.
- [25] B. Mohar, The Laplacian spectrum of graphs, in: Y. Alavi, G. Chartrand, O. Oellermann, A. Schwenk (Eds.), *Graph Theory, Combinatorics, and Applications*, London Math. Soc. Lecture Notes, Wiley-Interscience, 871-898 (1991).
- [26] B. Carreras, V. Lynch, I. Dobson, and D. Newman, Dynamics, criticality, and selforganization in a model for blackouts in power transmission systems, *Proc. 35th Hawaii International Conference on System Sciences, Hawaii* (2002).
- [27] B. Carreras, V. Lynch, M. Sactjen, I. Dobson, and D. Newman, Modeling blackout dynamics in power transmission networks with simple structure, *Proc. 34th Hawaii International Conference on System Sciences, Maui, Hawaii* (2001).

- [28] I. Dobson, B. Carreras, V. Lynch, and D. Newman, An initial model for complex dynamics in electric power system blackouts, *Proc. 34th Hawaii International Conference on System Sciences, Maui, Hawaii* (2001).
- [29] Dynamical and probabilistic approaches to the study of blackout vulnerability of the power transmission grid, *Proc. 37th Hawaii International Conference on System Sciences, Hawaii* (2004).
- [30] I. Dobson, J. Chen, J. Thorp, B. Carreras, and D. Newman, Examining criticality of blackouts in power system models with cascading events, *Proc. 35th Hawaii International Conference on System Sciences, Hawaii* (2002).
- [31] I. Dobson, K. Wierzbicki, B. Carreras, V. Lynch, and D. Newman, An estimator of propagation of cascading failure, *Proc. 39th Hawaii International Conference on System Sciences, Hawaii* (2006).
- [32] G. Oliviera, S. Binato, L. Bahiense, L. Thome, and M. Pereira, Security-constrained transmission planning: a mixed-integer disjunctive approach, *Optimization Online* (2004).
- [33] J. F. Bard, Practical Bilevel Optimization: Algorithms and Applications, *Kluwer Academic Publishers* (1998).
- [34] H. Von Stackelberg, The Theory of Market Economy, *Oxford University Press, Oxford* (1952).

- [35] U.S.-Canada Power System Outage Task Force, *Final Report on the August 14, 2003 Blackout in the United States and Canada: Causes and Recommendations*, April 5, 2004. Download from: <https://reports.energy.gov>.
- [36] Electric Consumer Research Council (ELCON), *The Economic Impacts of the August 2003 Blackout*, February 2004.