



Family Name
Given Name
Student Number
Centre
Signature

25 June 2009

6077AC Electrical Systems Safety - Capstone Assessment

Time allowed – Three hours plus Ten minutes reading time

32 Pages in this Question Booklet

TOTAL MARKS AVAILABLE = 100

Aids to be supplied by college:

- None.

Aids to be supplied by student:

- Australian/New Zealand Wiring Rules, AS/NZS 3000:2007
- Australian/New Zealand Standard Electrical Installations – Selection of Cables, AS/NZS 3008:1:1998.
- NSW Service and Installation Rules
- Students own marginal notes, indexing and formal amendments may be included in the above regulation books.
- Pen, pencil, eraser, rule, calculator.

*With
Answers*

| Section | Possible Mark | Actual Mark |
|--------------|---------------|-------------|
| A | 15 | |
| B | 20 | |
| C | 45 | |
| D | 20 | |
| TOTAL | 100 | |

Instructions to student:

- **Mobile phones are to be turned off and removed from your person.** You cannot access a mobile phone during this test.
- All questions to be answered in the space provided on this **Question Booklet**. Answers to Section A – multi-choice questions, are to be answered on the sheet attached to this Question Booklet.
- You are not to use any other reference book in this examination.
- The whole of this paper is to be handed to the Supervisor upon completion.
- **ALL** Questions to be attempted.

Aids permitted where indicated:

| Standard Dictionaries | Bilingual Dictionaries | Technical Dictionaries | Programmable Calculators | Non-programmable Calculators | Electronic Devices |
|-----------------------|------------------------|------------------------|--------------------------|------------------------------|--------------------|
| No | No | No | No | Yes | No |

- (d) blue without colour stripe
- (c) red with black stripe
- (b) red with white stripe
- (a) red without colour stripe

The colour coding used to identify a dry chemical powder fire extinguisher is:

QUESTION 4. (1 Mark)

- (d) to ensure there is no intermix from other circuits
- (c) only on the active conductor
- (b) only on the earth conductor
- (a) to ensure conductors are not transposed

Polarity testing is performed on a socket outlet:

QUESTION 3. (1 Mark)

Figure 1



The sign shown in *Figure 1* is an example of:

QUESTION 2. (1 Mark)

- (d) do not exceed 250 V with the insulation resistance tester
- (c) join neutral to earth for socket outlets containing the surge protection devices
- (b) only use an ohmmeter on these circuits
- (a) turn off switches for socket outlets containing the surge protection devices

Which of the following steps must be followed before undertaking an insulation resistance test on a power circuit having socket outlets, which incorporate surge protection devices?

QUESTION 1. (1 Mark)

INSTRUCTIONS: Select the best answer for the following statements and place an 'X' in the appropriate box on the Answer Sheet attached to the back of this examination paper. Each correct answer is worth one (1) mark.

SECTION A – (15 Marks)

SECTION A – (Cont'd)

QUESTION 5. (1 Mark)

Equipment used in an electrical installation must:

- (a) carry the EMI compliant mark
- (b) be rated for 230V, 50Hz operation
- (c) be safe to use and not cause danger
- (d) carry the regulatory compliant mark

QUESTION 6. (1 Mark)

A major hazard with confined spaces is:

- (a) difficulty in using tools
- (b) unable to stand upright when working
- (c) only one person can work at a time
- (d) flammable contaminants and oxygen depletion

QUESTION 7. (1 Mark)

A Certificate of Compliance – Electrical Work should be completed when the installation is tested and the 'Contractors Copy' retained by the electrical contractor for a period of:

- (a) 14 days
- (b) 1 year
- (c) 5 years
- (d) 7 years

QUESTION 8. (1 Mark)

The minimum number of residual current devices required to protect two (2) lighting and two (2) power circuits in a domestic electrical installation is:

- (a) one for power circuit only
- (b) one for lighting circuit only
- (c) one for both lighting and power circuits
- (d) two residual current devices are required

- (a) Lighting points
- (b) socket outlets not protected by RCDs
- (c) socket outlets protected by RCDs
- (d) cooking appliances

It is necessary to verify earth fault-loop impedance for final sub-circuits supplying:

QUESTION 11. (1 Mark)

- (a) 20% of phase to earth prospective fault current
- (b) 20% of three-phase prospective fault current
- (c) 30% of three-phase prospective fault current
- (d) 60% of phase to earth prospective fault current

Automatic disconnection of the supply is required to limit the harmful effects of switchboard internal arcing. Protection should mitigate at a current less than:

QUESTION 10. (1 Mark)

- (a) all parts of an installation required to be earthed are connected to the general mass of earth but not to the main neutral link
- (b) all parts of an installation required to be earthed are connected to the general mass of earth and in addition are connected to the main neutral link
- (c) all parts of an installation required to be earthed are connected to the general mass of earth and in addition are connected to the main neutral link
- (d) all parts of an installation required to be earthed are connected only to the general mass of earth and the main earth link

The MEN system of earthing is where:

QUESTION 9. (1 Mark)

SECTION A - (Cont'd)

SECTION A – (Cont'd)

QUESTION 12. (1 Mark)

When selecting a cable for a final sub-circuit, its continuous current carrying capacity should be:

- (a) at least equal to demand of final sub-circuit and at least equal to circuit breaker rating
- (b) at least equal to demand of final sub-circuit and less than circuit breaker rating
- (c) less than demand of final sub-circuit and at least equal to circuit breaker rating
- (d) less than demand of the final sub-circuit and less than circuit breaker rating

QUESTION 13. (1 Mark)

A socket outlet installed for the supply of pool equipment and located a distance of 1.5 metres from the pool rim shall:

- (a) have an IP rating of at least IPX4
- (b) have an IP rating of at least IPX5
- (c) have an IP rating of at least IPX6
- (d) not be permitted

QUESTION 14. (1 Mark)

A circuit in a non-air conditioned, non-domestic installation supplies 10 A socket outlets. If the circuit comprises 4 mm² copper conductor the maximum number of single socket outlets it can supply when protected by a 25 A Type C circuit breaker is:

- (a) 10
- (b) 12
- (c) 15
- (d) 20

QUESTION 15. (1 Mark)

One method for determining the size of consumer mains and sub-mains of an electrical installation is:

- (a) safe design and construction
- (b) measuring the average current over any 15 minute period
- (c) summing current rating of isolation devices for associated circuits
- (d) summing current settings of circuit breakers protecting associated circuits

Reference ()

What are these considerations?

The design of an electrical installation must take into account a number of considerations.

QUESTION 3. (2 Marks)

Reference ()

When determining the maximum demand of an electrical installation it is necessary to consider a number of requirements. What are three considerations?

QUESTION 2. (2 Marks)

Reference ()

The requirements detailed in AS/NZS 3000:2007 are to ensure the safety of persons, livestock, and property against dangers and damage that may arise in the reasonable use of an electrical installation. What are the three major risks identified?

QUESTION 1. (2 Marks)

INSTRUCTIONS: Use AS/NZS 3000:2007 to best answer each question in the space provided showing the AS/NZS 3000:2007 references used to obtain the answer. You will be awarded 2 marks for providing the correct answer and reference. Part marks are not available.

SECTION B - (20 Marks)

SECTION B – (Cont'd)

QUESTION 4. (2 Marks)

What are the requirements for aluminium earthing conductors?

Reference (_____)

QUESTION 5. (2 Marks)

What is the maximum circuit length of a 2.5mm² TPS twin and earth cable supplying 10A socket outlets and protected by a 20A Type C circuit breaker so as not to exceed the maximum earth-fault impedance for a 230 volt installation?

Reference (_____)

QUESTION 6. (2 Marks)

What is the function of the MEN link?

Reference (_____)

Reference ()

Generally every motor shall be controlled through an isolating switch. What situations do not require motor isolating switches?

QUESTION 10. (2 Marks)

Reference ()

What are three examples of circuits that do not require over-current protection due to the opening of the circuit causing greater danger than the over-current?

QUESTION 9. (2 Marks)

Reference ()

What is the minimum number of residual current devices in domestic installation having multiple final sub-circuits?

QUESTION 8. (2 Marks)

Reference ()

What is the minimum distance required between a 50 watt, 12 volt recessed dichroic lamp and its supply transformer?

QUESTION 7. (2 Marks)

SECTION B - (Cont'd)

SECTION C – (45 Marks)

INSTRUCTIONS: This section involves calculations. Show all necessary working in the space provided, marks will be awarded accordingly. Answers are to be highlighted or underlined.

The questions in this section relate to a factory unit complex. A main switchboard supplies a number of switchboards in the complex. *Figure 2* shows the site plan and *Figure 3* details the single-line diagram for the sub-main to factory unit 4.





Figure 2

Figure 3



SECTION C - (Cont'd)

SECTION C – (Cont'd)

Use the information in Table 1 to assist in answering Question 1.

Table 1

| Conductor size (mm^2) | a.c. resistance at 50 Hz in Ω/km | | |
|----------------------------------|--|---------|----------|
| | at 75°C | at 90°C | at 110°C |
| 2.5 | 9.01 | 9.45 | 10.0 |
| 4 | 5.61 | 5.88 | 6.24 |
| 6 | 3.75 | 3.93 | 4.17 |
| 10 | 2.23 | 2.33 | 2.48 |
| 16 | 1.40 | 1.47 | 1.56 |
| 25 | 0.884 | 0.927 | 0.984 |
| 35 | 0.638 | 0.668 | 0.710 |
| 50 | 0.471 | 0.494 | 0.524 |
| 70 | 0.327 | 0.342 | 0.363 |
| 95 | 0.236 | 0.247 | 0.262 |
| 120 | 0.188 | 0.197 | 0.208 |
| 150 | 0.153 | 0.160 | 0.169 |
| 185 | 0.123 | 0.129 | 0.136 |

QUESTION 1. (4 Marks)

The 3-phase 230/400-volt consumer main to the factory comprise X-HF-110 SDI cables having circular copper conductors. The active conductors are 185 mm^2 . The Supply Authority nominates the fault level at the point of supply as 30 kA. The soil resistivity for the installation is very low. The cables have a route length of 11 metres. Calculate the fault current rating of distribution equipment located on the main switchboard given that that the supply authority does not provide short circuit protection on the supply side of the consumers main.

(Assume the return path has negligible resistance due to the low soil resistivity)

Maximum demand of the three-phase sub-main 4 is

| Load Group | Load description | Qty | Calculation | Demand (Red) | Demand (White) | Demand (Blue) | Maximum Demand |
|-------------------------------|-------------------|-----|-------------|--------------|----------------|---------------|----------------|
| Circuit 1 — Hi Bay Lighting | Hi Bay Lighting | | | | | | |
| Circuit 2 — Hi Bay | Hi Bay | | | | | | |
| Circuit 3 — Fluorescent | Fluorescent | | | | | | |
| Circuit 4 — Fluorescent | Fluorescent | | | | | | |
| Circuit 5 — 1 ph Power | 1 ph Power | | | | | | |
| Circuit 6 — 1 ph Power | 1 ph Power | | | | | | |
| Circuit 7 — 1 ph Power | 1 ph Power | | | | | | |
| Circuit 8 — 1 ph Power | 1 ph Power | | | | | | |
| Circuit 9 — 1 ph Water Heater | 1 ph Water Heater | | | | | | |
| Circuit 10 — 1 ph Motors | 1 ph Motors | | | | | | |
| Circuit 11 — 3 ph Power | 3 ph Power | | | | | | |
| Circuit 12 — 3 ph Power | 3 ph Power | | | | | | |
| Circuit 13 — 3 ph Power | 3 ph Power | | | | | | |
| Circuit 14 — 3 ph Power | 3 ph Power | | | | | | |
| Circuit 15 — 3 ph Power | 3 ph Power | | | | | | |

Complete the Table fully — marks are deducted for each incomplete or incorrect line.

Enter required information for each circuit as listed in the following Table.

contain heating or cooling.

The occupant intends to use rotating electrical machines in this area. This factory unit does not calculate the maximum demand of the 230/400 volt, three-phase sub-main to Switchboard 4.

SECTION C - (Cont'd)

QUESTION 2. (4 Marks)

SECTION C – (Cont'd)

Table 2
Circuit Breakers for Power Distribution – Electrical Characteristics

| Electrical Characteristic | Circuit Breaker Designation | | | | | | | |
|---|---|---|---|--|---|---|---|---|
| | CB1 | CB2 | CB3 | CB4 | CB5 | CB6 | CB7 | CB8 |
|  |  |  |  |  |  |  |  |  |
| Poles | 3 or 4 | 3 or 4 | 3 or 4 | 3 or 4 | 3 or 4 | 3 or 4 | 3 or 4 | 3 or 4 |
| Rated Current (A) | 100 | 160 | 200 | 250 | 320 | 400 | 500 | 630 |
| Rated Operational Voltage (V) | 500 | 500 | 500 | 500 | 500 | 500 | 500 | 500 |
| Rated Short-Circuit capacity @ 440V (kA) | 20 | 20 | 20 | 25 | 30 | 30 | 40 | 40 |
| Trip Unit | TMF | TMF | TMF | TMF | TMF | TMF | TMF | TMF |
| Category Rating (Type) | D | D | D | D | D | F | F | F |
| TMF= Thermo-magnetic trip unit with fixed thermal and magnetic threshold | | | | | | | | |

QUESTION 3. (2 Marks)

If the maximum demand of sub-main 4 was determined to be 185 A, use Table 2 (above) and the fault levels indicated below to select a suitable protective device for sub-main 4.

Fault level at point of supply: 30 kA

Fault level at main switchboard: 22 kA

Fault level at switchboard 4: 16 kA

Designation of selected device (eg CB1): _____

| | | | | | |
|----------------|----------|---------|-----------------------|--|--|
| Standard used: | Table No | Column: | Cross-sectional area: | | |
|----------------|----------|---------|-----------------------|--|--|

Earth conductor

| | | | | | |
|----------------|----------|---------|-----------------------|--|--|
| Standard used: | Table No | Column: | Cross-sectional area: | | |
|----------------|----------|---------|-----------------------|--|--|

Neutral conductor

| | | | | | |
|----------------|----------|---------|-----------------------|--|--|
| Standard used: | Table No | Column: | Cross-sectional area: | | |
|----------------|----------|---------|-----------------------|--|--|

Active conductor**Required current carrying capacity:**

| | | | | |
|----------------|----------------|---------|------------------|--|
| Standard used: | Table No used: | Column: | Derating factor: | |
|----------------|----------------|---------|------------------|--|

Derating (if applicable)

The maximum demand of the sub-main 4 was determined to be 185 Ampere. A 200 Ampere type D circuit breaker protects the sub-main at its origin. The major portion of the load connects between active and neutral conductors. What would be the minimum size of the active, neutral and earth conductors for a X-HF-90 four-core and earth cable having circular copper conductors when installed vertically on single perforated cable tray with three other sub-main circuits (that is touching)?

QUESTION 4. (5 Marks)**SECTION C - (Cont'd)**

SECTION C – (Cont'd)

QUESTION 5. (6 Marks)

The maximum demand of the 230/400 volt, sub-main 4 was determined to be 185 A, and the sub-main comprised a X-HF-90 four-core and earth cable having 70 mm² circular copper active and neutral conductors, that are protected by a 200A Type D circuit breaker. Calculate the voltage drop for this segment and state if it is within the specified limit of 2.4% when the route length of the circuit is 55 metres.

Standard used: _____

Table No: _____

mV/A.m rating: _____

- (a) Does this comply with the 2.4% specified limit?

- (b) What is the optimal copper conductor size for this cabling segment?

The maximum demand of the 230/400 volt, sub-main 4 was determined to be 185 A, and the sub-main comprised a X-HF-90 four-core and earth cable having 70 mm² circular copper active and neutral conductors with a 25 mm² earth conductor. Verify that a 200 Ampere type D circuit breaker would adequately protect the circuit with the fault-loop impedance limitations.

QUESTION 6. (2 Marks)

SECTION C - (Cont'd)

SECTION C – (Cont'd)

The remaining questions in this section relate to a multiple domestic installation comprising sixteen (16) separate occupancies.

A main switchboard for the complex supplies a switchboard in each of the occupancies. *Figure 4* shows the site plan and *Figure 5* details the single-line diagram for the sub-main to unit 9.





Figure 4

Figure 5



SECTION C - (Cont'd)

SECTION C – (Cont'd)

QUESTION 7. (3 Marks)

Calculate the maximum demand of the single-phase sub-main to Unit 9.

Enter required information for each load description as listed in the following Table.
Complete the Table fully – marks are deducted for each incomplete or incorrect line.

| Load group | Load description | Qty | Calculation | Demand |
|-----------------------|--------------------|-----|-------------|--------|
| | Lighting | | | |
| | 1 ph Power (10 A) | | | |
| | 1 ph Power (15 A) | | | |
| | Air Conditioning | | | |
| | Quick Recovery HWS | | | |
| | Cook-top | | | |
| | Wall oven | | | |
| Maximum Demand | | | | |

Maximum demand of the single-phase sub-main to Unit 9 is _____

| | | | | | |
|----------------|----------|---------|-----------------------|--|--|
| Standard used: | Table No | Column: | Cross-sectional area: | | |
|----------------|----------|---------|-----------------------|--|--|

EARTH CONDUCTOR

| | | | | | |
|----------------|----------|---------|---------------------------|--|--|
| Standard used: | Table No | Column: | CURRENT CARRYING CAPACITY | | |
|----------------|----------|---------|---------------------------|--|--|

NEUTRAL CONDUCTOR

| | | | | | |
|----------------|----------|---------|---------------------------|--|--|
| Standard used: | Table No | Column: | CURRENT CARRYING CAPACITY | | |
|----------------|----------|---------|---------------------------|--|--|

ACTIVE CONDUCTOR

REQUERIED CURRENT CARRYING CAPACITY:

| | | | | |
|----------------|----------------|---------|------------------|--|
| Standard used: | Table No used: | Column: | DERATING FACTOR: | |
|----------------|----------------|---------|------------------|--|

DERATING (IF APPLICABLE)

Conductors are touching each other?

Underground trench together with seven (7) other similar sub-main cables when all eight (8) 2-core and earth R-E-I10 cable having circular copper conductors when installed in a this cable. What would be the minimum size of the active, neutral and earth conductors for a An 80 Ampere type D circuit breaker provides over-current protection at the point of origin for The maximum demand of the 230 volt, sub-main to unit 9 was determined to be 75 Ampere.

QUESTION 8. (5 Marks)

SECTION C - (CONT'D)

SECTION C – (Cont'd)

QUESTION 9. (4 Marks)

The maximum demand of the 230 volt, sub-main to unit 9 was determined to be 75 Ampere, and the 2-core and earth R-E-110 cable had 10 mm² circular copper conductors, determine the voltage drop and state if it is within the specified limit of 3.3% when the route length is 125 metres.

Standard used: _____

Table No: _____

mV/A.m rating: _____

Does this comply with the 3.3% specified limit?

QUESTION 10. (3 Marks)

Final sub-circuit 3 supplies a load consisting of 10 A socket outlets. A 16 A Type C circuit breaker protects the circuit of 2.5 mm² V-90, TPS, 2-core and earth cable. Determine the maximum measured internal fault-loop impedance of the final sub-circuit, based on 240 V, when supply is unavailable and the ambient temperature is 20°C.

| Location | Appliance | A |
|------------------------|------------------------|------|
| Outside Unit 1 Garage | 18 W Bollard | 0.15 |
| Outside Unit 2 Garage | 18 W Bollard | 0.15 |
| Outside Unit 3 Garage | 18 W Bollard | 0.15 |
| Outside Unit 4 Garage | 18 W Bollard | 0.15 |
| Outside Unit 5 Garage | 18 W Bollard | 0.15 |
| Outside Unit 6 Garage | 18 W Bollard | 0.15 |
| Outside Unit 7 Garage | 18 W Bollard | 0.15 |
| Outside Unit 8 Garage | 18 W Bollard | 0.15 |
| Outside Unit 9 Garage | 18 W Bollard | 0.15 |
| Outside Unit 10 Garage | 18 W Bollard | 0.15 |
| Outside Unit 11 Garage | 18 W Bollard | 0.15 |
| Outside Unit 12 Garage | 18 W Bollard | 0.15 |
| Outside Unit 13 Garage | 18 W Bollard | 0.15 |
| Outside Unit 14 Garage | 18 W Bollard | 0.15 |
| Outside Unit 15 Garage | 18 W Bollard | 0.15 |
| Outside Unit 16 Garage | 18 W Bollard | 0.15 |
| RH side driveway entry | 18 W Bollard | 0.15 |
| LH side driveway entry | 18 W Bollard | 0.15 |
| Barbecue area | 500 W halogen flood | 2.7 |
| Swimming pool area | 500 W halogen flood | 2.7 |
| | 500 W halogen flood | 2.7 |
| | 500 W halogen flood | 2.7 |
| | 500 W halogen flood | 2.7 |
| | 500 W halogen flood | 2.7 |
| | 500 W halogen flood | 2.7 |
| | 500 W halogen flood | 2.7 |
| | Pool pump (hard-wired) | 4.5 |

This load connects to two single-phase meters.

Table 3 — Communal Schedule

SECTION C - (Cont'd)

SECTION C – (Cont'd)

QUESTION 11. (4 Marks)

Calculate the maximum demand of the *whole* installation detailed in *Figure 4* and *Figure 5* if each of the units has identical electrical loading and the Communal loading detailed in Table 3 is included.

Enter required information for each load description as listed in the following Table.
Complete the Table fully – marks are deducted for each incomplete or incorrect line.

| Load group | Load description | Qty | Calculation | Demand (Red) | Demand (White) | Demand (Blue) |
|-----------------------|--|-----|-------------|--------------|----------------|---------------|
| | Lighting | | | | | |
| | 1 ph Power (10 A) | | | | | |
| | 1 ph Power (15 A) | | | | | |
| | Air Conditioning | | | | | |
| | Quick Recovery HWS | | | | | |
| | Cook-top | | | | | |
| | Wall oven | | | | | |
| | Communal Circuit 1 – 18 Bollards | | | | | |
| | Communal Circuit 2 – 4 Halogen floods | | | | | |
| | Communal Circuit 3 – 4 Halogen floods | | | | | |
| | Communal Circuit 4 – swimming pool pump | | | | | |
| Maximum Demand | | | | | | |

Maximum demand of the installation is _____

Maximum demand current per phase:

Demand per phase:

| Occupancy | | | | Total |
|------------------------------|--|-----------------------------------|-------------------|-------|
| Floor area (m ²) | Average energy demand (VA/m ²) | Equipment | Occupancy | Total |
| Shop 1 | 150 | Light / power | Shop 1 | 150 |
| Shop 2 | 180 | Light / power | Shop 2 | 180 |
| Shop 3 | 180 | Light / power | Shop 3 | 180 |
| Shop 4 | 150 | Light / power Air conditioning | Shop 4 | 150 |
| Theatre | 1200 | Light / power | Theatre | 1200 |
| Tavre m | 800 | Light / power / ac | Tavre m | 800 |
| Basement car park | 1200 | Lighting | Basement car park | 1200 |

Table 4 — Shopping centre floor area

Calculate the maximum demand, based on the energy demand method, of the three-phase, 230/400 volt sub-main to a portion of a shopping complex using the floor area details in Table 4 below. Complete the maximum demand Table (Table 4)

QUESTION 12. (3 Marks)**SECTION C - (Cont'd)**

SECTION D – 20 Marks

INSTRUCTION: The questions in this section require some simple drawing. Ensure that the drawing is neat and legible. The use of pencil on the drawing is acceptable in this section only.

QUESTION 1. (4 Marks)

The diagram of *Figure 6* following represents the main switchboard in a domestic installation. The diagram also shows five (5) final sub-circuits (earthing conductors only) that the switchboard supplies. Note that the diagram does not show all equipment the switchboard supplies. Details of the installation are as follows:

The consumer mains are 3-phase 400 V comprising four (4) 25 mm² V-90 SDI cables enclosed in HDUPVC conduit. Double insulation is maintained up to the supply terminals of the service protective devices, which provide short circuit protection.

The consumer mains do not have short circuit protection on the supply side.


Single-insulated cables are used to connect the equipment on the load side of the service protective devices.

The main switchboard supplies, in part, the following circuits:

| | | |
|-------------|--------------|---|
| • Circuit 1 | Lighting | 1.5 mm ² TPS twin and earth. |
| • Circuit 2 | Power | 2.5 mm ² TPS twin and earth. |
| • Circuit 3 | Power | 2.5 mm ² TPS twin and earth. |
| • Circuit 4 | Range | 6 mm ² TPS twin and earth. |
| • Circuit 5 | Water heater | 4 mm ² TPS twin and earth. |

- Draw on the diagram all necessary **earthing** and **equipotential bonding** conductors necessary to effect the MEN system of earthing. DO NOT show active and neutral conductors.
- Identify on each cable the **minimum** conductor size.

Only correct connections, labelling and conductor sizes gain marks.

Figure 6

SECTION D – (Cont'd)

QUESTION 2. (3 Marks)

Determine the suitability of a 63 A type D circuit breaker having a tripping characteristic in the range shown in *Figure 7*. The circuit breaker is to protect a sub-main circuit having a maximum demand current of 55 A. The prospective fault current at the origin of the sub-main is 700 A. Show all working and show on the diagram how you arrived at the answer.




Figure 7

Test Sequence:
Polarity test of single pole switch using voltage indicator with supply available.

INSTRUCTIONS: Blank spaces in the following statements represent omissions. Write the appropriate word, words or information in the spaces provided.

QUESTION 3. (7 Marks)

SECTION D - (Cont'd)

SECTION D – (Cont'd)

QUESTION 4. (3 Marks)

Complete the following diagram to show how the Insulation Resistance Tester would connect when testing a single-phase circuit supplying an electric range and protected by a 32 A circuit breaker. Note that the MEN link and sub-circuit neutral are disconnected and the circuit breaker is turned off.




Figure 8

| | | | | | | | | | | | | | | | | |
|--|--|---------------|------------------|--------------|----------------------|-----------------------|--|----------------|--|---------------------|--|---------------|--|---|--|--|
| Customer: | Ted E Bear, 22 Honeyuckle Drive, Bearsville, 2299. | Cross street: | Coronation Drive | Electrician: | Ignore any reference | Installation details: | Additonal (new) power circuit comprising 8 single 10 A socket outlets in domestic residence and connected to supply. | Water service: | At water pipe entry at front of building on switchboard side of building | equipotential bond: | At water pipe entry at front of building on switchboard side of building | Test results: | Insulation resistance: 5 MΩ 0.4 MΩ 0.12 Ω 0.18 Ω Earth continuity: Main earth Immitiy Other circuits Range Water heater Main earth electrode: Directly below switchboard | Equipotential bond: Main earth bond All other equipotential bond | Earth continuity: Main earth Immitiy Other circuits Range Water heater Main earth electrode: Directly below switchboard | Insulation resistance: 5 MΩ 0.4 MΩ 0.12 Ω 0.18 Ω All other tests: |
| Complete the required sections on the Certificate of Compliance – Electrical Work of Figure 9 on the following page to satisfy the following. Note: Do NOT include any details for the electrician or tester. | | | | | | | | | | | | | | | | |

QUESTION 5. (3 Marks)

SECTION D – (Cont'd)

CERTIFICATE OF COMPLIANCE – ELECTRICAL WORK

Customer COPY

CERTIFICATE NO: 000403

CUSTOMER DETAILS

| | | | | | | |
|--------------|--|----------|--|---------------------|--|--|
| Name | | | | Telephone Contact | | |
| Address | | | | Meter No: | | |
| Cross Street | | Postcode | | NMI (if applicable) | | |

INSTALLATION WORK DETAILS Indicate the type of installation and types of work performed under this Notice

| | | | | | |
|----------------------|--|---------------------------------------|---|------------------------------------|---|
| Type of Installation | <input type="checkbox"/> Residential | <input type="checkbox"/> Commercial | <input type="checkbox"/> Industrial | <input type="checkbox"/> Rural | <input type="checkbox"/> Other |
| Special Conditions | <input type="checkbox"/> over 100 amps | <input type="checkbox"/> High Voltage | <input type="checkbox"/> Hazardous Area | <input type="checkbox"/> Generator | <input type="checkbox"/> Unmetered Supply |

CERTIFICATE MUST BE ISSUED TO THE CUSTOMER FOR ALL ELECTRICAL WORK

Work of the following type must ALSO be notified to the **ELECTRICITY DISTRIBUTOR (DNSP)**

- | | |
|--|---|
| <input type="checkbox"/> New Installation | <input type="checkbox"/> Network connection or metering |
| <input type="checkbox"/> Additions or alterations to a switchboard or associated equipment | <input type="checkbox"/> Defect Rectification No: |

DETAILS OF EQUIPMENT *Describe the equipment and estimate load increase of the work affected by this Notice.* *If insufficient space attach separate sheets.*

| EQUIPMENT | RATING | No. | PARTICULARS OF WORK |
|---|--------|-----|--|
| <input type="checkbox"/> Switchboards | | | |
| <input type="checkbox"/> Circuits | | | |
| <input type="checkbox"/> Lighting | | | |
| <input type="checkbox"/> Socket-outlets | | | |
| <input type="checkbox"/> Appliances | | | |
| Estimated increase in load A/ph | | | <input type="checkbox"/> Increased load is within capacity of installation/service mains |
| | | | <input type="checkbox"/> Work is not connected to supply pending inspection by DNSP |

The work has been carried out or supervised by:

Licence No:

TEST REPORT *Indicate the relevant tests and checks that have been performed on the work.* *If test records are provided attach as separate sheets.*

| | |
|--|--|
| <input type="checkbox"/> Earthing system integrity Ω | <input type="checkbox"/> Residual current device operation |
| <input type="checkbox"/> Insulation resistance MΩ | <input type="checkbox"/> Visual check that installation is suitable for connection to supply |
| <input type="checkbox"/> Polarity | <input type="checkbox"/> Stand-alone power system complies with AS 4509 |
| <input type="checkbox"/> Correct circuit connections | <input type="checkbox"/> Fault loop impedance (if necessary) |

I confirm that I have carried out the above tests and visually checked that the installation work described in this Certificate complies with AS/NZS 3000 and is suitable for its intended use.

Name:

Licence No:

Signature:

Date of Testing:

CERTIFICATION

I, the Electrical Contractor give notice to the Customer and
(Name of DNSP or OFT), that the work described in this Certificate has been completed in accordance with the
Electricity (Consumer Safety) Regulation 2006

Name:

Licence No:

Signature:

Date of Notice:

Address:

Telephone No.

ELECTRICITY DISTRIBUTOR (DNSP) REMARKS

Inspected by:

or Other Contact

Comments:

Date




Figure 9

END OF EXAMINATION

Total Marks Section A: / 15

| Question | A | B | C | D | Total Correct Section A |
|----------|---|---|---|---|-------------------------|
| Totals | | | | | |
| | | | | | 15 |
| | | | | | 14 |
| | | | | | 13 |
| | | | | | 12 |
| | | | | | 11 |
| | | | | | 10 |
| | | | | | 9 |
| | | | | | 8 |
| | | | | | 7 |
| | | | | | 6 |
| | | | | | 5 |
| | | | | | 4 |
| | | | | | 3 |
| | | | | | 2 |
| | | | | | 1 |

- Place an X in box of your choice. If you make a mistake circle your answer and choose again.
- Enter your personal details in the top right hand corner of this sheet.

INSTRUCTIONS:

6077AC Electrical Systems Safety - Capstone Assessment

25 June 2009

ANSWER SHEET - Section A (Multi-choice Questions)

..... Signature

..... Centre

..... Student Number

..... Given Name

..... Family Name



MARKING GUIDE

Module/Unit No: **6077 AC**

Module/Unit Name: **Electrical Systems
Safety - Capstone
Assessment**

Exam Date: **25/06/09**

Number of Pages: **34 (including this page)**

| No | No | No | Yes |
|-----------------------|------------------------|--------------------------|------------------------------|
| Dictionaries | Bilingual Dictionaries | Programmable Calculators | Non-programmable Calculators |
| Standard Dictionaries | Technical Dictionaries | Calculators | Calculators |

Aids permitted where indicated:

- The whole of this paper is to be handed to the Supervisor upon completion.
- You are not to use any other reference books in this examination.
- All questions to be answered in the space provided on this **examination paper**. Answers to Section A – multi-choice questions, are to be recorded on the Answer Sheet attached to this examination paper.
- Mobile phones are to be turned off and removed from your person. You cannot access a mobile phone during this examination.

Instructions to Students:

- Pen, pencil, eraser, rule, calculator.
- above regulation books.
- Students own marginal notes, indexing and formal amendments may be included in the NSW Service and Installation Rules
- AS/NZS 3008.1.1:1998
- Australian/New Zealand Standard Electrical Installations – Selection of Cables Part 1.1
- Australian/New Zealand Wiring rules AS/NZS 3000:2007

Aids to be supplied by student:

| | |
|---------|---------------|
| TOTAL | 100 |
| D | 20 |
| C | 45 |
| B | 20 |
| A | 15 |
| Section | Possible Mark |
| | Actual Mark |

TOTAL MARKS AVAILABLE = 100

ALL Questions to be attempted

33 37 Pages in this Question Booklet

Time allowed - Three hours plus Ten minutes reading time

6077AC Electrical Systems Safety

25 June 2009

Signature

Centre

Student Number

Given Name

Ramsey Name



SECTION A – (15 Marks)

INSTRUCTIONS: Select the best answer for the following statements and place an 'X' in the appropriate box on the Answer Sheet attached to the back of this examination paper. Each correct answer is worth one (1) mark.

QUESTION 1. (1 Mark)

Which of the following steps must be followed before undertaking an insulation resistance on a power circuit having socket outlets, which incorporate surge protection devices?

- (a) turn off switches for socket outlets containing the surge protection devices
- (b) only use an ohmmeter on these circuits
- (c) join neutral to earth for socket outlets containing the surge protection devices
- (d) do not exceed 250 V with the insulation resistance tester

QUESTION 2. (1 Mark)

The sign shown in *Figure 1* is an example of:

- (a) prohibition sign
- (b) mandatory sign
- (c) restriction sign
- (d) warning sign



Figure 1

QUESTION 3. (1 Mark)

Polarity testing is performed on a socket outlet:

- (a) to ensure conductors are not transposed
- (b) only on the earth conductor
- (c) only on the active conductor
- (d) to ensure there is no intermix from other circuits

QUESTION 4. (1 Mark)

The colour coding used to identify a dry chemical powder fire extinguisher is:

- (a) red without colour stripe
- (b) red with white stripe
- (c) red with black stripe
- (d) blue without colour stripe

- (d) two residual current devices are required
 (c) one for both lighting and power circuits
 (b) one for lighting circuit only
 (a) one for power circuit only

The minimum number of residual current devices required to protect two (2) lighting and two (2) power circuits in a domestic electrical installation is:

QUESTION 8. (1 Mark)

- (d) 7 years
 (c) 5 years
 (b) 1 year
 (a) 14 days

for a period of:

A Certificate of Compliance - Electrical Work should be completed when the installation is tested and the 'Contractors Copy' retained by the electrical contractor

QUESTION 7. (1 Mark)

- (d) flammable combustibles and oxygen depletion
 (c) only one person can work at a time
 (b) unable to stand upright when working
 (a) difficulty in using tools

A major hazard with confined spaces is:

QUESTION 6. (1 Mark)

- (d) carry the regulatory compliant mark
 (c) be safe to use and not cause damage
 (b) be rated for 230V, 50Hz operation
 (a) carry the EMI compliant mark

Equipment used in an electrical installation must:

QUESTION 5. (1 Mark)

SECTION A - (Cont'd)

SECTION A – (Cont'd)

QUESTION 9. (1 Mark)

The MEN system of earthing is where:

- (a) all parts of an installation required to be earthed are not connected to the general mass of earth but are connected to the main neutral link
- (b) all parts of an installation required to be earthed are connected to the general mass of earth but not to the main neutral link
- (c) all parts of an installation required to be earthed are connected to the general mass of earth and in addition are connected to the main neutral link
- (d) all parts of an installation required to be earthed are connected only to the general mass of earth and the main earth link

QUESTION 10. (1 Mark)

Automatic disconnection of the supply is required to limit the harmful effects of switchboard internal arcing. Protection should initiate at a current less than:

- (a) 20% of phase to earth prospective fault current
- (b) 20% of three-phase prospective fault current
- (c) 30% of three-phase prospective fault current
- (d) 60% of phase to earth prospective fault current

QUESTION 11. (1 Mark)

It is necessary to verify earth fault-loop impedance for final sub-circuits supplying:

- (a) lighting points
- (b) socket outlets not protected by RCDs
- (c) socket outlets protected by RCDs
- (d) cooking appliances

- (d) summing current settings of circuit breakers protecting associated circuits
- (c) summing current rating of isolation devices for associated circuits
- (b) measuring the average current over any 15 minute period
- (a) safe design and construction

One method for determining the size of consumer mains and sub-mains of an electrical installation is:

QUESTION 15. (1 Mark)

- (d) 20
- (c) 15
- (b) 12
- (a) 10

A circuit in a non-air conditioned, non-domestic installation supplies 10 A socket outlets. If the circuit comprises 4 mm² copper conductor the maximum number of outlets. In single socket outlets it can supply when protected by a 25 A Type C circuit breaker is:

QUESTION 14. (1 Mark)

- (d) not be permitted
- (c) have an IP rating of at least IPX6
- (b) have an IP rating of at least IPX9
- (a) have an IP rating of at least IPX4

1.5 metres from the pool rim shall:

A socket outlet installed for the supply of pool equipment and located a distance of

QUESTION 13. (1 Mark)

- (d) less than demand of the final sub-circuit and less than circuit breaker rating
- (c) less than demand of final sub-circuit and at least equal to circuit breaker rating
- (b) at least equal to demand of final sub-circuit and less than circuit breaker rating

When selecting a cable for a final sub-circuit, its continuous current carrying capacity should be:

QUESTION 12. (1 Mark)

SECTION A - (Cont'd)

SECTION B – (20 Marks)

INSTRUCTIONS: Use AS/NZS 3000:2007 to best answer each question in the space provided showing your answer. You will be assessed on the quality of your answer.

- | | |
|---|--|
| <input checked="" type="checkbox"/> | Award 2 marks for correct answer and reference |
| <input type="checkbox"/> | No marks for all other cases |
| Other references may be accepted if correct | |

QUESTION 1. (2 Marks)

The requirements detailed in AS/NZS 3000:2007 are to ensure the safety of persons, livestock, and property against dangers and damage that may arise in the reasonable use of an electrical installation. What are the three major risks identified?

Shock current, Excessive temperatures, and Explosive atmospheres

OR

Electric shock, fire and physical injury hazards

Reference (1.5.1)

OR 1-1 Scope

QUESTION 2. (2 Marks)

When determining the maximum demand of an electrical installation it is necessary to consider a number of requirements. What are three considerations?

Capacity, physical distribution and intended use of electrical equipment in the installation

and the manner in which the presentation requirements might vary

Reference (1.6.3)

Note: Clause 2.2.2 is not acceptable

QUESTION 3. (2 Marks)

The design of an electrical installation must take into account a number of considerations. What are these considerations?

Protect persons, livestock and property from harmful effects

Function correctly as intended

Connect, operate safely and be compatible with the supply source to which it connects

Minimise inconvenience in event of a fault

Facilitate safe operation, inspection, testing, and maintenance

Reference (1.6.1)

Ques 1. 4-E6

Reference (5.3.5.1)

terminal on the main neutral link

conductor by means of a connection from the main earth connection to the earthing

To connect the earthing system within the electrical installation to the supply neutral

What is the function of the MEN link?

QUESTION 6. (2 Marks)

Reference (Table B1)

68 metres

maximum earth-fault impedance for a 230 volt installation?

What is the maximum circuit length of a 2.5mm^2 TPS twin and earth cable supplying 10A socket outlets and protected by a 20A Type C circuit breaker so as not to exceed the

QUESTION 5. (2 Marks)

Reference (5.3.2.1.2)

Not installed underground or damp situations

Take care to provide satisfactory termination and prevent corrosion of conductor

Minimum Conductor size of 16 mm^2 for main earth

Conductors $< 10\text{ mm}^2$ must be solid

What are the requirements for aluminium earthing conductors?

QUESTION 4. (2 Marks)

SECTION B - (Cont'd)

SECTION B – (Cont'd)

QUESTION 7. (2 Marks)

What is the minimum distance required between a 50 watt, 12 volt recessed dichroic lamp and its supply transformer?

50 mm

Reference (4.5.2.3 / Figure 4.7)

QUESTION 8. (2 Marks)

What is the minimum number of residual current devices in domestic installation having multiple final sub-circuits?

Two

Reference (2.6.3.2 (c))

also 2.6.2.4(c)

QUESTION 9. (2 Marks)

What are three examples of circuits that do not require over-current protection due to the opening of the circuit causing greater danger than the over-current?

Certain safety system supplies

Lifting magnets

Exciter circuits of machines and secondary circuits of current transformers

Reference (2.5.1.3 Note 1)

also 7.5.9.2(c)


QUESTION 10. (2 Marks)

Generally every motor shall be controlled through an isolating switch. What situations do not require motor isolating switches?

Motor connected by plug and socket or incorporated in an appliance having no exposed moving parts or rated not more than 150 VA

Reference (4.13.1.1 Exception 2)

Figure 2




The questions in this section relate to a factory unit complex. A main switchboard supplies a number of switchboards in the complex. Figure 2 shows the site plan and Figure 3 details the single-line diagram for the sub-main to factory unit 4.

INSTRUCTIONS: This section involves calculations. Show all necessary working in the space provided, marks will be awarded accordingly. Answers are to be highlighted or underlined.

SECTION C - (45 Marks)

SECTION C – (Cont'd)



| Circuit | Description | Qty | Rating |
|---------|---------------------------------|-----|-------------|
| 1 | Hi Bay Lighting | 6 | 3.8 A each |
| 2 | Hi Bay Lighting | 6 | 3.8 A each |
| 3 | Fluorescent Lighting | 15 | 0.85 A each |
| 4 | Fluorescent Lighting | 12 | 0.85 A each |
| 5 | 1-ph single socket outlet | 10 | 10 A each |
| 6 | 1-ph single socket outlet | 9 | 10 A each |
| 7 | 1-ph double socket outlet | 5 | 10 A each |
| 8 | 1-ph socket outlet | 1 | 15 A |
| 9 | 1-ph instantaneous water heater | 1 | 9.5 A |
| 10 | 1-ph motor | 3 | 3.5 A each |
| 11 | 3-phase socket outlet | 1 | 32 A |
| 12 | 3-phase socket outlet | 1 | 32 A |
| 13 | 3-phase socket outlet | 1 | 25 A |
| 14 | 3-phase socket outlet | 1 | 25 A |
| 15 | 3-phase socket outlet | 1 | 15 A |

Figure 3

| | | | |
|---|--|-----------------------------------|--|
| <input checked="" type="checkbox"/> 1 mark. | Student must show correct working and answer | <input type="checkbox"/> 2 marks. | Student must show correct working and answer |
|---|--|-----------------------------------|--|

$$\begin{aligned}
 Z_{\text{Source}} &= \frac{V_{\text{Phase}}}{I_{\text{Fault}}} & Z &= \frac{\text{Length} \times \sigma}{V_{\text{km}}} \\
 I_{\text{Fault}} &= \frac{I_{\text{Fault}}}{Z_{\text{Source}} + Z_{\text{Active}}} & I_{\text{Fault}} &= \frac{1000}{11 \times 0.136} = 230 \text{ A} \\
 Z_{\text{Active}} &= \frac{V_{\text{Phase}}}{I_{\text{Fault}}} & & = 0.00767 + 0.0015 \\
 &= \frac{30 \times 10^3}{230} & & = 25.1 \text{ kA} \\
 &= 0.0015 \Omega & & = 0.00767 \Omega
 \end{aligned}$$

(Assume the return path has negligible resistance due to the low soil resistivity)
 consumers main.
 that the supply authority does not provide short circuit protection on the supply side of the fault current rating of distribution equipment located on the main switchboard given that
 the installation is very low. The cables have a route length of 11 metres. Calculate the
 Authoraty nominates the fault level at the point of supply as 30 kA. The soil resistivity for
 having circular copper conductors. The active conductors are 185 mm^2 . The Supply
 The 3-phase 230/400-volt consumer main to the factory comprise X-HF-110 SDI cables

QUESTION 1. (4 Marks)

| Conductor size (mm^2) | at 75°C | at 90°C | at 110°C | a.c. resistance at 50 Hz in Ω/km | size (mm^2) | 0.123 | 0.129 | 0.136 |
|----------------------------------|---------|---------|----------|--|------------------------|-------|-------|-------|
| 2.5 | 9.01 | 9.45 | 10.0 | | 185 | | | |
| 4 | 5.61 | 5.88 | 6.24 | | 150 | 0.153 | 0.160 | 0.169 |
| 6 | 3.75 | 3.93 | 4.17 | | 120 | 0.188 | 0.197 | 0.208 |
| 10 | 2.23 | 2.33 | 2.48 | | 95 | 0.236 | 0.247 | 0.262 |
| 16 | 1.40 | 1.47 | 1.56 | | 70 | 0.327 | 0.342 | 0.363 |
| 25 | 0.884 | 0.927 | 0.984 | | 50 | 0.471 | 0.494 | 0.524 |
| 35 | 0.638 | 0.668 | 0.710 | | 35 | 0.638 | 0.668 | 0.710 |
| 50 | 0.471 | 0.494 | 0.524 | | 25 | 0.884 | 0.927 | 0.984 |
| 70 | 0.327 | 0.342 | 0.363 | | 16 | 1.40 | 1.47 | 1.56 |
| 95 | 0.236 | 0.247 | 0.262 | | 10 | 2.23 | 2.33 | 2.48 |
| 120 | 0.188 | 0.197 | 0.208 | | 6 | 3.75 | 3.93 | 4.17 |
| 150 | 0.153 | 0.160 | 0.169 | | 4 | 5.61 | 5.88 | 6.24 |
| 185 | 0.123 | 0.129 | 0.136 | | 2.5 | 9.01 | 9.45 | 10.0 |

Table 1

Use the information in Table 1 to assist in answering Question 1.

SECTION C - (Cont'd)

SECTION C – (Cont'd)

QUESTIONS

- Deduct 1 mark for each incorrect line or part thereof
 Calculations
 Allocation of load to different phase than that shown is acceptable.

Switchboard 4. The occupant intends to use rotating electrical machines in this area. This factory unit does not contain heating or cooling.

Enter required information for each circuit as listed in the following Table.

Complete the Table fully – marks are deducted for each incomplete or incorrect line.

| Load group | Load description | Qty | Calculation | Demand (Red) | Demand (White) | Demand (Blue) |
|-----------------------|----------------------------------|-----|---------------------------------|--------------|----------------|---------------|
| A | Circuit 1 — Hi Bay Lighting | 6 | 6×3.8 | 22.8 | | |
| A | Circuit 2 — Hi Bay Lighting | 6 | 6×3.8 | | 22.8 | |
| A | Circuit 3 — Fluorescent Lighting | 15 | 15×0.85 | | | 12.8 |
| A | Circuit 4 — Fluorescent Lighting | 12 | 12×0.85 | | | 10.2 |
| B(i) | Circuit 5 — 1 ph Power 10A | 10 | $(1000 + (9 \times 750)) / 230$ | 33.7 | | |
| B(ii) | Circuit 6 — 1 ph Power 10A | 9 | $(1000 + (8 \times 750)) / 230$ | | | 30.4 |
| B(ii) | Circuit 7 — 1 ph Power 10A | 5 | $(1000 + (9 \times 750)) / 230$ | | 33.7 | |
| B(iii) | Circuit 8 — 1 ph Power 15A | 1 | 0.75×15 | | | 11.3 |
| C | Circuit 9 — 1 ph Water Heater | 1 | — | | 9.5 | |
| D | Circuit 10 — 1 ph Motors | 3 | $(1 + 0.75 + 0.5) \times 3.5$ | 7.9 | | |
| B(iii) | Circuit 11 — 3 ph Power 32 A | 1 | — | 32.0 | 32.0 | 32.0 |
| B(iii) | Circuit 12 — 3 ph Power 32 A | 1 | 0.75×32 | 24.0 | 24.0 | 24.0 |
| B(iii) | Circuit 13 — 3 ph Power 25 A | 1 | 0.75×25 | 18.8 | 18.8 | 18.8 |
| B(iii) | Circuit 14 — 3 ph Power 25 A | 1 | 0.75×25 | 18.8 | 18.8 | 18.8 |
| B(iii) | Circuit 15 — 3 ph Power 15 A | 1 | 0.75×15 | 11.3 | 11.3 | 11.3 |
| Maximum Demand | | | | 169.3 | 170.9 | 169.6 |

Deduct 1 mark for each incorrect Maximum demand.

Maximum demand of the three-phase sub-main 4 is 170.9A

No parallel paths

Designation of selected device: CB4 [note CB3 does not have required fault level]

Fault level at point of supply: 30 kA
 Fault level at main switchboard: 22 kA
 Fault level at main switchboard: 16 kA
 Fault level at sub-main: *
 and the fault levels indicated below to select a suitable protective device for sub-main 4.
 If the maximum demand of sub-main 4 was determined to be 185 A, use Table 2 (above)

QUESTION 3. (2 Marks)

| Circuit Breaker Distribution | | | | | | | | Circuit Breakers for Power Distribution - Electrical Characteristics | |
|------------------------------|--------|--------|--------|--------|--------|--------|--------|--|---|
| Electrical Characteristic | CB1 | CB2 | CB3 | CB4 | CB5 | CB6 | CB7 | CB8 | |
| | | | | | | | | | TMF=Thermo-magnetic trip unit with fixed thermal and magnetic threshold @ 440V (kA) |
| | 20 | 20 | 20 | 25 | 30 | 30 | 40 | 40 | Rated Short-Circuit Capacity (A) @ 440V (kA) |
| | 500 | 500 | 500 | 500 | 500 | 500 | 500 | 500 | Rated Operational Voltage (V) |
| | 100 | 160 | 200 | 250 | 320 | 400 | 500 | 630 | Rated Current (A) |
| | 3 or 4 | Poles |
| | | | | | | | | | Trip Unit |
| | TMF | Category Rating (Type) |

Table 2

SECTION C - (Cont'd)

SECTION C – (Cont'd)

QUESTION 4. (5 Marks)

The maximum demand of the sub-main 4 was determined to be 185 Ampere. A 200 Ampere type D circuit breaker protects the sub-main at its origin. The major portion of the load connects between active and neutral conductors. What would be the minimum size of the active, neutral and earth conductors for a X-HF-90 four-core and earth cable having circular copper conductors when installed vertically on single perforated cable tray with three other sub-main circuits (th

No part marks

Every step and reference must be correct

Units must be correct eg mm^2 and Ampere

Ref: T2(1) Item 10

Derating (if applicable)

| Standard used: | Table No used: | Column: | Derating factor: |
|-----------------|----------------|---------|-------------------|
| AS/NZS 3008.1.1 | 24 | 8 | 0.77 [item No 19] |

Required current carrying capacity: $200 / 0.77 = 260 \text{ A}$

Active conductor

| Standard used: | Table No used: | Column: | Cross-sectional area: | Current carrying capacity |
|-----------------|----------------|---------|-----------------------|---------------------------|
| AS/NZS 3008.1.1 | 13 | 2 | 95 mm^2 | 285 Ampere |

Neutral conductor

| Standard used: | Table No used: | Column: | Cross-sectional area: | Current carrying capacity |
|-----------------|----------------|---------|-----------------------|---------------------------|
| AS/NZS 3008.1.1 | 13 | 2 | 95 mm^2 | 285 Ampere |

Refer AS/NZS 3000:2007 Clause 3.5.2

Earth conductor

| Standard used: | Table No used: | Column: | Cross-sectional area: |
|----------------|----------------|---------|-----------------------|
| AS/NZS 3000 | 5.1 | 2 | 25 mm^2 |

* No part marks

No part
marks

$$V_c = \frac{1000 \times V_e}{L \times I}$$

$$= \frac{1000 \times 9.6}{55 \times 185}$$

$$= 0.943 \text{ mV/A.m}$$

so from Table 42 optimum size is 50 mm^2

(b) What is the optimal copper conductor size for this cabling segment?

2.4% of $400 \text{ V} = 9.6 \text{ V}$ So this arrangement is acceptable

(a) Does this comply with the 2.4% specified limit?

$$V_d = \frac{L \times I \times V_e}{1000}$$

$$= \frac{55 \times 185 \times 0.609}{1000}$$

$$= 6.2 \text{ V}$$

mV/A.m rating: 0.609

| | | | | |
|--|----------------------|------------|--------------|--|
| <input checked="" type="checkbox"/> No part marks. | AS/NZS 3008.1.1:1998 | hard used: | Table No: 42 | Every step and reference must be correct |
|--|----------------------|------------|--------------|--|

The maximum demand of the $230/400$ volt, sub-main 4 was determined to be 185 A , and the sub-main comprised a X-HF-90 four-core and earth cable having 70 mm^2 circular copper active and neutral conductors, that are protected by a 200A Type D circuit breaker. Calculate the voltage drop for this segment and state if it is within the specified limit of 2.4% when the route length of the circuit is 55 metres.

QUESTION 5. (6 Marks)

SECTION C - (Cont'd)

SECTION C – (Cont'd)

QUESTION 6. (2 Marks)

Length of submain = 55 m
(see page 10)

The maximum demand of the 230/400 volt, sub-main 4 was determined to be 185 A, and the sub-main comprised a X-HF-90 four-core and earth cable having 70 mm² circular copper active and neutral conductors with a 25 mm² earth conductor. Verify that a 200 Ampere type D circuit breaker would adequately protect the circuit with the fault-loop impedance limitations.

$$\begin{aligned} - L_{\max} &= \frac{0.8 \times U_0 \times S_{PH} \times S_{PE}}{I_a \times \rho \times (S_{PH} + S_{PE})} \\ - &= \frac{0.8 \times 230 \times 70 \times 25}{(12.5 \times 200) \times (22.5 \times 10^{-3}) \times (70 + 25)} \\ - &= 60.2 \text{ metres} \end{aligned}$$

TB1

OR


70 mm² Act 25 mm² Earth
200A Type D C/B

Length = 60m

As the actual circuit length is 55 metres this arrangement IS suitable

No part marks. Student must show calculation and plausible explanation


Figure 4



The remaining questions in this section relate to a multiple domestic installation comprising sixteen (16) separate occupancies. A main switchboard for the complex supplies a switchboard in each of the occupancies. Figure 4 shows the site plan and Figure 5 details the single-line diagram for the sub-main to unit 9.

SECTION C - (Cont'd)

SECTION C – (Cont'd)



| Circuit | Description | Qty | Rating |
|---------|------------------------------|---------------------|---------------|
| 1 | Lighting | 16 | 60W each |
| 2 | Lighting | 18 | 60W each |
| 3 | 1-ph single socket outlet | 8 double | 10 A each |
| 4 | 1-ph single socket outlet | 5 double + 6 single | 10 A each |
| 5 | 1-ph single socket outlet | 6 double + 4 single | 10 A each |
| 6 | 1-ph single socket outlet | 1 | 15 A |
| 7 | 1-ph air conditioner | 1 | 9.5 A |
| 8 | 1-ph 180 litre, 3.45kW QRHWS | 1 | 15 A @ 230V |
| 9 | 1-ph cook top | 1 | 8.6 kW @ 230V |
| 10 | 1-ph wall oven | 1 | 4.2 kW @ 230V |

Figure 5

Deduct 1 mark for each incorrect line or part thereof up to total available marks for this question.

Maximum demand of the single-phase sub-main to Unit 9 is 77.8A + 7.1A

| Load Group | Load description | Qty | Calculation | Demand | Maximum Demand |
|------------|--------------------|---------------|---|--------|----------------|
| C | Wall oven | 1 | 0.5×4200 | 230 | 9.1 |
| C | Cook-top | 1 | 0.5×8600 | 230 | 18.7 |
| F | Quick Recovery HWS | 1 | Under 100w / 114w | — | 15.0 |
| GI | Air Conditioning | 1 | Included in the above 9.5×0.75 | 0.0 | 7.1 |
| GI | 1 ph Power (15 A) | 1 | — | — | 10.0 |
| GI | 1 ph Power (10 A) | $16+16+16=48$ | $10+5+5$ | 20.0 | |
| GI | Lighting | $16+18=34$ | $3+2$ | 5.0 | |
| Total | | | | | <u>77.8</u> |

Complete the Table fully - marks are deducted for each incomplete or incorrect line.
Enter required information for each load description as listed in the following Table.
Calculate the maximum demand of the single-phase sub-main to Unit 9.

QUESTION 7. (3 Marks)

SECTION C - (Cont'd)

SECTION C – (Cont'd)

QUESTION 8. (5 Marks)

The maximum demand of the 230 volt, sub-main to unit 9 was determined to be 75 Ampere. An 80 Ampere type D circuit breaker provides over-current protection at the point of origin for this cable. What would be the minimum size of the active, neutral and earth conductors for a 2-core and earth R-E-110 cable having circular copper conductors when installed in an underground trench together with seven (7) other similar sub-main cables when all eight (8) conduits are touching each other.

No part marks.

Every step and reference must be correct

Ref: TZ(4) Item 3

Derating (if applicable)

| Standard used: | Table No used: | Column: | Derating factor: |
|-----------------|----------------|---------|------------------|
| AS/NZS 3008.1.1 | 26(2) | 2 | 0.70 |

Required current carrying capacity: $80 / 0.7 = 114.3 \text{ A}$

Active conductor

| Standard used: | Table No used: | Column: | Cross-sectional area: | Current carrying capacity |
|-----------------|----------------|---------|-----------------------|---------------------------|
| AS/NZS 3008.1.1 | 11 | 8 | 16 mm ² | 115 Ampere |

Neutral conductor

| Standard used: | Table No used: | Column: | Cross-sectional area: | Current carrying capacity |
|-----------------|----------------|---------|-----------------------|---------------------------|
| AS/NZS 3008.1.1 | 11 | 8 | 16 mm ² | 115 Ampere |

Refer AS/NZS 3000:2007 Clause 3.5.2

Earth conductor

| Standard used: | Table No used: | Column: | Cross-sectional area: |
|----------------|----------------|---------|-----------------------|
| AS/NZS 3000 | 5.1 | 2 | 6 mm ² |

* No part marks

$$Z_s = 1.23 \times \frac{240}{230} = 1.28\Omega$$

$$Z_s = 1.23\Omega$$

Q/B

T8.1 f6. a 16A Type C

OR

No part marks.

$$= 1.29\Omega$$

$$= 1.24 \times \frac{240}{230}$$

$$- Z_m \text{ measured} = R_{PHE} \times \frac{U_o}{U_i}$$

(2.00 is from Table 8.2 of AS/NZS 3000)

Final sub-circuit 3 supplies a load consisting of 10 A socket outlets. A 16 A Type C circuit breaker protects the circuit of $2.5 \text{ mm}^2 \text{ V-90, TPS, 2-core and earth cable.}$ Determine the maximum measured internal fault-loop impedance of the final sub-circuit based on 240 V , when supply is unavailable and the ambient temperature is 20°C .

QUESTION 10. (3 Marks)

3.3% of $230 \text{ V} = 7.59 \text{ V}$ So this arrangement is NOT acceptable

Does this comply with the 3.3% specified limit?

$$V_d = \frac{L \times I \times V_e}{1000} = \frac{125 \times 75 \times 4.95}{1000} = 46.4 \text{ V}$$

mV/A.m rating: 4.29 3-phase = 4.95 1-phase

4.29x1.153

Table No:

No part marks.

Every step and reference id used: must be correct

AS/NZS 3008.1.1:1998

when the route length is 125 metres.

The maximum demand of the 230 volt, sub-main to unit 9 was determined to be 75 Ampere, and the 2-core and earth R-E-110 cable had 10 mm^2 circular copper conductors, determine the voltage drop and state if it is within the specified limit of 3.3%

QUESTION 9. (4 Marks)

SECTION C - (Cont'd)

SECTION C – (Cont'd)

Table 3 — Communal Schedule

This load connects to two single-phase meters.

| Location | Appliance | A |
|------------------------|------------------------|------|
| Outside Unit 1 Garage | 18 W Bollard | 0.15 |
| Outside Unit 2 Garage | 18 W Bollard | 0.15 |
| Outside Unit 3 Garage | 18 W Bollard | 0.15 |
| Outside Unit 4 Garage | 18 W Bollard | 0.15 |
| Outside Unit 5 Garage | 18 W Bollard | 0.15 |
| Outside Unit 6 Garage | 18 W Bollard | 0.15 |
| Outside Unit 7 Garage | 18 W Bollard | 0.15 |
| Outside Unit 8 Garage | 18 W Bollard | 0.15 |
| Outside Unit 9 Garage | 18 W Bollard | 0.15 |
| Outside Unit 10 Garage | 18 W Bollard | 0.15 |
| Outside Unit 11 Garage | 18 W Bollard | 0.15 |
| Outside Unit 12 Garage | 18 W Bollard | 0.15 |
| Outside Unit 13 Garage | 18 W Bollard | 0.15 |
| Outside Unit 14 Garage | 18 W Bollard | 0.15 |
| Outside Unit 15 Garage | 18 W Bollard | 0.15 |
| Outside Unit 16 Garage | 18 W Bollard | 0.15 |
| RH side driveway entry | 18 W Bollard | 0.15 |
| LH side driveway entry | 18 W Bollard | 0.15 |
| Barbecue area | 500 W halogen flood | 2.7 |
| | 500 W halogen flood | 2.7 |
| | 500 W halogen flood | 2.7 |
| | 500 W halogen flood | 2.7 |
| Swimming pool area | 500 W halogen flood | 2.7 |
| | 500 W halogen flood | 2.7 |
| | 500 W halogen flood | 2.7 |
| | 500 W halogen flood | 2.7 |
| | Pool pump (hard-wired) | 4.5 |

Deduct 1 mark for incorrect Maximum demand.

$$\text{Maximum demand of the installation is } 111.3A + 35.6 = 146.9A$$

Deduct 1 mark for each incorrect line or part thereof up to total available marks for this

| Load group | Load description | Qty | Calculation | Demand (Red) | Demand (White) | Demand (Blue) | Units |
|------------|--|-------|---|--------------|----------------|---------------|-------|
| A1 | Lighting | 5,5,6 | $5 + (6 \times 0.25)$ | 6.0 | 6.0 | 6.5 | |
| B1 | 1 ph Power (10 A) | 5,5,6 | $10 + (5 \times 5)$ $15 + (6 \times 3.75)$ | 35.0 | 35.0 | 37.5 | |
| B2 | 1 ph Power (15 A) | 5,5,6 | — | 10.0 | 10.0 | 10.0 | |
| C | Cook-top | 5,5,6 | 6×2.8 | 15.0 | 15.0 | 16.8 | |
| C | Wall oven | 5,5,6 | Included above | 0.0 | 0.0 | 0.0 | |
| H | Communal Circuit 1 - 18 Bolards | 18 | 18×0.15 | 2.7 | | | |
| H | Communal Circuit 2 - 4 Halogen floods | 4 | 4×2.7 | 10.8 | | | |
| H | Communal Circuit 3 - 4 Halogen floods | 4 | 4×2.7 | 10.8 | | | |
| I | Communal Circuit 4 - Swimming pool pump | 1 | 1×2 | 4.5 | | | |
| | | | | 10.3 | 10.3 | 10.8 | |
| | | | | 109.5 | 109.5 | 111.3 | |
| | | | | 106.8 | 106.8 | 106.8 | |

Complete the Table fully - marks are deducted for each incomplete or incorrect line.
 Enter required information for each load description as listed in the following Table.
 Table 3 is included.

If each of the units has identical electrical loading and the Communal loading detailed in Table 3 is included.
 Calculate the maximum demand of the whole installation detailed in Figure 4 and Figure 5

QUESTION 11. (4 Marks)

SECTION C - (Cont'd)

SECTION C – (Cont'd)

QUESTION 12. (3 Marks)

Calculate the maximum demand, based on the energy demand method, of the three-phase, 230/400 volt sub-main to a portion of a shopping complex using the floor area details in Table 4 below. Complete the maximum demand Table (Table 4)

Table 4 — Shopping centre floor area

| Occupancy | Floor area (m ²) | Equipment | Average energy demand (VA/m ²) | Total energy demand (kVA/m ²) |
|--|------------------------------|--------------------|--|---|
| Shop 1 | 150 | Light / power | $150 \times 70 = 10\,500$ | 15 |
| | | Air conditioning | $150 \times 30 = 4\,500$ | |
| Shop 2 | 180 | Light / power | $180 \times 70 = 12\,600$ | 18 |
| | | Air conditioning | $180 \times 30 = 5\,400$ | |
| Shop 3 | 180 | Light / power | $180 \times 70 = 12\,600$ | 18 |
| | | Air conditioning | $180 \times 30 = 5\,400$ | |
| Shop 4 | 150 | Light / power | $150 \times 70 = 10\,500$ | 15 |
| | | Air conditioning | $150 \times 30 = 4\,500$ | |
| Theatre | 1200 | Light / power | 1200×100 | 120 |
| Tavern | 800 | Light / power / ac | 800×80 | 64 |
| Basement car park | 1200 | Lighting | 1200×15 | 18 |
| <input checked="" type="checkbox"/> Deduct 1 mark for each incorrect line or part thereof up to total available marks for this question. | | | Total: | 268 |

Demand per phase: 89.3 kVA [268 ÷ 3]

Maximum demand current per phase: 388 A [89.3 x 10³ ÷ 230]

Deduct 1 mark for incorrect Maximum demand.

Only correct connections, labelling and conductor sizes gain marks.

(b) Identify on each cable the minimum conductor size.

active and neutral conductors.

(a) Draw on the diagram all necessary earthing and equipotential bonding conductors necessary to effect the MEN system of earthing. DO NOT show conductors necessary to effect the MEN system of earthing. DO NOT show

| | | | |
|-------------|--------------|--|--------------------|
| • Circuit 5 | Water heater | 4 mm^2 TPS twin and earth. | 2.5 mm^2 |
| • Circuit 4 | Range | 6 mm^2 TPS twin and earth. | 2.5 mm^2 |
| • Circuit 3 | Power | 2.5 mm^2 TPS twin and earth. | 2.5 mm^2 |
| • Circuit 2 | Power | 2.5 mm^2 TPS twin and earth. | 2.5 mm^2 |
| • Circuit 1 | Lighting | 1.5 mm^2 TPS twin and earth. | 1.5 mm^2 |

The main switchboard supplies, in part, the following circuits:

1.5.1

Single-insulated cables are used to connect the equipment on the load side of the service protective devices.

Consumer mains do not have short circuit protection on the supply side.

Terminals of the service protective devices, which provide short circuit protection, enclosed in HDUPVC conduit. Double insulation is maintained up to the supply

The consumer mains are 3-phase 400 V comprising four (4) 25 mm^2 V-90 SDI cables

switchboard supplies. Details of the installation are as follows:

The diagram of Figure 6 following represents the main switchboard in a domestic installation. The diagram also shows five (5) final sub-circuits (earthing conductors only) that the switchboard supplies. Note that the diagram does not show all equipment the

QUESTION 1. (4 Marks)

acceptable in this section only.

Ensure that the drawing is neat and legible. The use of pencil on the drawing is acceptable in this section only.

INSTRUCTIONS: The questions in this section require some simple drawing.

SECTION D - 20 Marks




Figure 6

* CM's are not protected

* Deduct 1 mark for
each error *

Therefore, the C/B is suitable.

maximum-5 seconds — Class 1-E.S.S.3(d)(ii).

Disconnection time for sub-main is -


2 mark for answer

Circuit breaker would trip between 0.7 second to 5 second making it suitable

under 0.4
tripset

Figure 7

$$I_{FAT} = 700A \quad 63 \times 12.5 = 788A$$



1 mark for plotting on graph

answer.

Determine the suitability of a 63 A type D circuit breaker having a tripping characteristic in the range shown in Figure 7. The circuit breaker is to protect a sub-main circuit having a maximum demand current of 55 A. The prospective fault current at the origin of the sub-main is 700 A. Show all working and show on the diagram how you arrived at the answer.

QUESTION 2. (3 Marks)

SECTION D - (Cont'd)

SECTION D – (Cont'd)

Test is outlined on page 28 of AS/NZS 3017:2007

QUESTION 3. (7 Marks) There are 11 responses required

Deduct 1 mark for each incorrect response

NO part marks (ie 1 or 0)

INSTRUCTIONS: Bla

Write the appropriate word, words or information in the spaces provided.

Test:

Polarity test of single pole switch using voltage indicator with supply available.

Test sequence:


1. Check operation of Voltage Indicator.
2. Energise the circuit
3. Connect one test lead to a known Earth.
4. Connect the other test lead to one Terminal of the switch under test.
5. Operate the switch.
6. Move the test lead to the other Terminal.
7. Operate the switch.
8. Test results should indicate:

With switch on Supply. Voltage at Both terminals

With switch off Supply. Voltage at One of the terminals
OR zero volts at the other terminal,

9. Disconnect the test leads.

Figure 8



Complete the following diagram to show how the Insulation Resistance Tester would connect when testing a single-phase circuit supplying an electric range and protected by a 32 A circuit breaker. Note that the MEN link and sub-circuit neutral are disconnected and the circuit breaker is turned off.

QUESTION 4. (3 Marks)

SECTION D - (Cont'd)

Figure 9 on the following page to satisfy the following. Note: Do NOT include any details for the electrician or tester.

Customer: Ted E Bear,
22 Honeysuckle Drive,
Bearsville. 2299.

Cross street: Coronation Drive

Meter number: 12345

Electrician: Ignore any reference

Installation details Additional (new) power circuit comprising 8 single 10 A socket outlets in domestic residence and connected to supply.

Consumer mains: Four by 16mm² SDI

Main earth electrode: Directly below switchboard

Water service equipotential bond: At water pipe entry at front of building on switchboard side of building

Test results:

| | | |
|------------------------|--------------------|----------|
| Insulation resistance: | Water heater | 5 MΩ |
| | Range | 0.4 MΩ |
| | Other circuits | Infinity |
| Earth continuity: | Main earth | 0.12 Ω |
| | Equipotential bond | 0.18 Ω |
| | All other | <0.8 Ω |
| All other tests: | Correct | |

Figure 9

| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|---|--|--|--|--|--|---|---|---|--|--|--|--|--|---|---|---|---|---|--|---|---|---|--|---|---|--|---|--|--|---|---|--|--|-----------------------------------|-------------------------------------|-----------------------------------|--|---------------------------------|--|--|---|---|--|---|---|--|--|---|---|--|---|---|---|--|---|---|--|---|---|---|---|--|---|--|---|--|-----------------------------------|---|---|--|--|--|--|--|--|--|---|--|--|--|---|--|--|--|-----------------------------|--|
| CERTIFICATE OF COMPLIANCE - | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| ELECTRICAL WORK | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| CERTIFICATE NO: 000403 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Customer COPY | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| CUSTOMER DETAILS | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <p>Name: Ted E Bear Telephone Contact: [Redacted]</p> <p>Address: 22 Honeyuckle Drive, Bearsville. Meter No: 12345 Cross Street: NMI (if applicable)</p> | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <p>INSTALATION DETAILS Indicate the type of installation and types of work performed under this Notice</p> <table border="1"> <tr> <td>Type of Installation</td> <td><input checked="" type="checkbox"/> Residential</td> <td><input type="checkbox"/> Commercial</td> <td><input type="checkbox"/> Industrial</td> <td><input type="checkbox"/> Rural</td> <td><input type="checkbox"/> Other</td> </tr> <tr> <td>Special</td> <td><input type="checkbox"/> Additions or alterations to a switchboard or associated equipment</td> <td><input type="checkbox"/> Network connection or metering</td> </tr> <tr> <td>Conditions</td> <td><input type="checkbox"/> Work is not connected to supply</td> <td><input type="checkbox"/> Increased load is within capacity of installation/service mains</td> </tr> <tr> <td>Appliances</td> <td><input type="checkbox"/> Estimated increase in load A/ph [Redacted]</td> <td><input type="checkbox"/> Actual load is within capacity of installation/service mains</td> </tr> <tr> <td>Lighting</td> <td><input type="checkbox"/> Circuits</td> <td><input type="checkbox"/> Switchboards</td> </tr> <tr> <td>Sockets-outlets</td> <td><input type="checkbox"/> Cables</td> <td><input type="checkbox"/> Rating No. [Redacted]</td> </tr> <tr> <td colspan="2" style="text-align: center;">PARTICULARS OF WORK</td> </tr> <tr> <td colspan="2"> <p>DETAILS OF EQUIPMENT Describe the equipment and estimate load affected by this Notice.</p> <table border="1"> <tr> <td><input type="checkbox"/> New installation</td> <td><input type="checkbox"/> Work of the following type must ALSO be notified to the ELECTRICITY DISTRIBUTOR (DNP)</td> </tr> <tr> <td><input type="checkbox"/> Additions or alterations to a switchboard or associated equipment</td> <td><input type="checkbox"/> Direct Recertification No:</td> </tr> </table> </td> </tr> <tr> <td colspan="2"> <p>EQUIPMENT RATING No. PARTICULARS OF WORK</p> <table border="1"> <tr> <td><input type="checkbox"/> Sockets-outlets</td> <td><input type="checkbox"/> Lighting</td> <td><input type="checkbox"/> Appliances</td> <td><input type="checkbox"/> Circuits</td> <td><input type="checkbox"/> Sockets-outlets</td> <td><input type="checkbox"/> Cables</td> <td><input type="checkbox"/> Rating No. [Redacted]</td> </tr> <tr> <td><input type="checkbox"/> Work is connected to supply</td> <td><input type="checkbox"/> Estimated increase in load A/ph [Redacted]</td> <td><input type="checkbox"/> Actual load is within capacity of installation/service mains</td> <td><input type="checkbox"/> Work is not connected to supply</td> <td><input type="checkbox"/> Estimated increase in load A/ph [Redacted]</td> <td><input type="checkbox"/> Actual load is within capacity of installation/service mains</td> <td><input type="checkbox"/> Work has been carried out</td> </tr> <tr> <td><input type="checkbox"/> Work is not connected to supply</td> <td><input type="checkbox"/> Estimated increase in load A/ph [Redacted]</td> <td><input type="checkbox"/> Actual load is within capacity of installation/service mains</td> <td><input type="checkbox"/> Work is connected to supply</td> <td><input type="checkbox"/> Estimated increase in load A/ph [Redacted]</td> <td><input type="checkbox"/> Actual load is within capacity of installation/service mains</td> <td><input type="checkbox"/> Work has been supervised by:</td> </tr> <tr> <td><input type="checkbox"/> Work is not connected to supply</td> <td><input type="checkbox"/> Estimated increase in load A/ph [Redacted]</td> <td><input type="checkbox"/> Actual load is within capacity of installation/service mains</td> <td><input type="checkbox"/> Work is connected to supply</td> <td><input type="checkbox"/> Estimated increase in load A/ph [Redacted]</td> <td><input type="checkbox"/> Actual load is within capacity of installation/service mains</td> <td><input type="checkbox"/> Work has been supervised by:</td> </tr> </table> </td> </tr> <tr> <td colspan="2"> <p>TEST REPORT Indicate the relevant tests and checks that have been performed on the work.</p> <table border="1"> <tr> <td><input type="checkbox"/> Earthling system integrity Q</td> <td><input type="checkbox"/> Residual current device operation</td> </tr> <tr> <td><input type="checkbox"/> Installation resilience Mo</td> <td><input type="checkbox"/> Visual check that installation is suitable for connection to supply</td> </tr> <tr> <td><input type="checkbox"/> Polarity</td> <td><input type="checkbox"/> Ground-line power system complies with AS 4509</td> </tr> <tr> <td><input type="checkbox"/> Correct outlet connections</td> <td><input type="checkbox"/> Fault loop impedance (if necessary) OPTONAL</td> </tr> <tr> <td><input type="checkbox"/> Certificate complies with AS/NZS 3000 and is suitable for its intended use.</td> <td><input type="checkbox"/> Certificate complies with AS/NZS 3000 and is suitable for its intended use.</td> </tr> </table> </td> </tr> <tr> <td colspan="2"> <p>CERTIFICATION I, the Electrical Contractor give notice to the Customer and (Name of DNP or OFT), that the work described in this Certificate has been completed in accordance with the Electrical Contract (Consumer Safety) Regulation 2006.</p> </td> </tr> <tr> <td colspan="2"> <p>I confirm that I have carried out the above tests and visually checked that the installation work described in this Certificate complies with AS/NZS 3000 and is suitable for its intended use.</p> </td> </tr> <tr> <td colspan="2"> <p>Signature: [Redacted] Date of Notice: [Redacted]</p> </td> </tr> <tr> <td colspan="2"> <p>Name: [Redacted] Licence No: [Redacted]</p> </td> </tr> <tr> <td colspan="2"> <p>Address: [Redacted] Telephone No: [Redacted]</p> </td> </tr> <tr> <td colspan="2"> <p>Date: [Redacted] Other Contractor: [Redacted]</p> </td> </tr> <tr> <td colspan="2"> <p>Comments: [Redacted]</p> </td> </tr> </table> | | Type of Installation | <input checked="" type="checkbox"/> Residential | <input type="checkbox"/> Commercial | <input type="checkbox"/> Industrial | <input type="checkbox"/> Rural | <input type="checkbox"/> Other | Special | <input type="checkbox"/> Additions or alterations to a switchboard or associated equipment | <input type="checkbox"/> Network connection or metering | Conditions | <input type="checkbox"/> Work is not connected to supply | <input type="checkbox"/> Increased load is within capacity of installation/service mains | Appliances | <input type="checkbox"/> Estimated increase in load A/ph [Redacted] | <input type="checkbox"/> Actual load is within capacity of installation/service mains | Lighting | <input type="checkbox"/> Circuits | <input type="checkbox"/> Switchboards | Sockets-outlets | <input type="checkbox"/> Cables | <input type="checkbox"/> Rating No. [Redacted] | PARTICULARS OF WORK | | <p>DETAILS OF EQUIPMENT Describe the equipment and estimate load affected by this Notice.</p> <table border="1"> <tr> <td><input type="checkbox"/> New installation</td> <td><input type="checkbox"/> Work of the following type must ALSO be notified to the ELECTRICITY DISTRIBUTOR (DNP)</td> </tr> <tr> <td><input type="checkbox"/> Additions or alterations to a switchboard or associated equipment</td> <td><input type="checkbox"/> Direct Recertification No:</td> </tr> </table> | | <input type="checkbox"/> New installation | <input type="checkbox"/> Work of the following type must ALSO be notified to the ELECTRICITY DISTRIBUTOR (DNP) | <input type="checkbox"/> Additions or alterations to a switchboard or associated equipment | <input type="checkbox"/> Direct Recertification No: | <p>EQUIPMENT RATING No. PARTICULARS OF WORK</p> <table border="1"> <tr> <td><input type="checkbox"/> Sockets-outlets</td> <td><input type="checkbox"/> Lighting</td> <td><input type="checkbox"/> Appliances</td> <td><input type="checkbox"/> Circuits</td> <td><input type="checkbox"/> Sockets-outlets</td> <td><input type="checkbox"/> Cables</td> <td><input type="checkbox"/> Rating No. [Redacted]</td> </tr> <tr> <td><input type="checkbox"/> Work is connected to supply</td> <td><input type="checkbox"/> Estimated increase in load A/ph [Redacted]</td> <td><input type="checkbox"/> Actual load is within capacity of installation/service mains</td> <td><input type="checkbox"/> Work is not connected to supply</td> <td><input type="checkbox"/> Estimated increase in load A/ph [Redacted]</td> <td><input type="checkbox"/> Actual load is within capacity of installation/service mains</td> <td><input type="checkbox"/> Work has been carried out</td> </tr> <tr> <td><input type="checkbox"/> Work is not connected to supply</td> <td><input type="checkbox"/> Estimated increase in load A/ph [Redacted]</td> <td><input type="checkbox"/> Actual load is within capacity of installation/service mains</td> <td><input type="checkbox"/> Work is connected to supply</td> <td><input type="checkbox"/> Estimated increase in load A/ph [Redacted]</td> <td><input type="checkbox"/> Actual load is within capacity of installation/service mains</td> <td><input type="checkbox"/> Work has been supervised by:</td> </tr> <tr> <td><input type="checkbox"/> Work is not connected to supply</td> <td><input type="checkbox"/> Estimated increase in load A/ph [Redacted]</td> <td><input type="checkbox"/> Actual load is within capacity of installation/service mains</td> <td><input type="checkbox"/> Work is connected to supply</td> <td><input type="checkbox"/> Estimated increase in load A/ph [Redacted]</td> <td><input type="checkbox"/> Actual load is within capacity of installation/service mains</td> <td><input type="checkbox"/> Work has been supervised by:</td> </tr> </table> | | <input type="checkbox"/> Sockets-outlets | <input type="checkbox"/> Lighting | <input type="checkbox"/> Appliances | <input type="checkbox"/> Circuits | <input type="checkbox"/> Sockets-outlets | <input type="checkbox"/> Cables | <input type="checkbox"/> Rating No. [Redacted] | <input type="checkbox"/> Work is connected to supply | <input type="checkbox"/> Estimated increase in load A/ph [Redacted] | <input type="checkbox"/> Actual load is within capacity of installation/service mains | <input type="checkbox"/> Work is not connected to supply | <input type="checkbox"/> Estimated increase in load A/ph [Redacted] | <input type="checkbox"/> Actual load is within capacity of installation/service mains | <input type="checkbox"/> Work has been carried out | <input type="checkbox"/> Work is not connected to supply | <input type="checkbox"/> Estimated increase in load A/ph [Redacted] | <input type="checkbox"/> Actual load is within capacity of installation/service mains | <input type="checkbox"/> Work is connected to supply | <input type="checkbox"/> Estimated increase in load A/ph [Redacted] | <input type="checkbox"/> Actual load is within capacity of installation/service mains | <input type="checkbox"/> Work has been supervised by: | <input type="checkbox"/> Work is not connected to supply | <input type="checkbox"/> Estimated increase in load A/ph [Redacted] | <input type="checkbox"/> Actual load is within capacity of installation/service mains | <input type="checkbox"/> Work is connected to supply | <input type="checkbox"/> Estimated increase in load A/ph [Redacted] | <input type="checkbox"/> Actual load is within capacity of installation/service mains | <input type="checkbox"/> Work has been supervised by: | <p>TEST REPORT Indicate the relevant tests and checks that have been performed on the work.</p> <table border="1"> <tr> <td><input type="checkbox"/> Earthling system integrity Q</td> <td><input type="checkbox"/> Residual current device operation</td> </tr> <tr> <td><input type="checkbox"/> Installation resilience Mo</td> <td><input type="checkbox"/> Visual check that installation is suitable for connection to supply</td> </tr> <tr> <td><input type="checkbox"/> Polarity</td> <td><input type="checkbox"/> Ground-line power system complies with AS 4509</td> </tr> <tr> <td><input type="checkbox"/> Correct outlet connections</td> <td><input type="checkbox"/> Fault loop impedance (if necessary) OPTONAL</td> </tr> <tr> <td><input type="checkbox"/> Certificate complies with AS/NZS 3000 and is suitable for its intended use.</td> <td><input type="checkbox"/> Certificate complies with AS/NZS 3000 and is suitable for its intended use.</td> </tr> </table> | | <input type="checkbox"/> Earthling system integrity Q | <input type="checkbox"/> Residual current device operation | <input type="checkbox"/> Installation resilience Mo | <input type="checkbox"/> Visual check that installation is suitable for connection to supply | <input type="checkbox"/> Polarity | <input type="checkbox"/> Ground-line power system complies with AS 4509 | <input type="checkbox"/> Correct outlet connections | <input type="checkbox"/> Fault loop impedance (if necessary) OPTONAL | <input type="checkbox"/> Certificate complies with AS/NZS 3000 and is suitable for its intended use. | <input type="checkbox"/> Certificate complies with AS/NZS 3000 and is suitable for its intended use. | <p>CERTIFICATION I, the Electrical Contractor give notice to the Customer and (Name of DNP or OFT), that the work described in this Certificate has been completed in accordance with the Electrical Contract (Consumer Safety) Regulation 2006.</p> | | <p>I confirm that I have carried out the above tests and visually checked that the installation work described in this Certificate complies with AS/NZS 3000 and is suitable for its intended use.</p> | | <p>Signature: [Redacted] Date of Notice: [Redacted]</p> | | <p>Name: [Redacted] Licence No: [Redacted]</p> | | <p>Address: [Redacted] Telephone No: [Redacted]</p> | | <p>Date: [Redacted] Other Contractor: [Redacted]</p> | | <p>Comments: [Redacted]</p> | |
| Type of Installation | <input checked="" type="checkbox"/> Residential | <input type="checkbox"/> Commercial | <input type="checkbox"/> Industrial | <input type="checkbox"/> Rural | <input type="checkbox"/> Other | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Special | <input type="checkbox"/> Additions or alterations to a switchboard or associated equipment | <input type="checkbox"/> Network connection or metering | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Conditions | <input type="checkbox"/> Work is not connected to supply | <input type="checkbox"/> Increased load is within capacity of installation/service mains | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Appliances | <input type="checkbox"/> Estimated increase in load A/ph [Redacted] | <input type="checkbox"/> Actual load is within capacity of installation/service mains | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Lighting | <input type="checkbox"/> Circuits | <input type="checkbox"/> Switchboards | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Sockets-outlets | <input type="checkbox"/> Cables | <input type="checkbox"/> Rating No. [Redacted] | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| PARTICULARS OF WORK | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <p>DETAILS OF EQUIPMENT Describe the equipment and estimate load affected by this Notice.</p> <table border="1"> <tr> <td><input type="checkbox"/> New installation</td> <td><input type="checkbox"/> Work of the following type must ALSO be notified to the ELECTRICITY DISTRIBUTOR (DNP)</td> </tr> <tr> <td><input type="checkbox"/> Additions or alterations to a switchboard or associated equipment</td> <td><input type="checkbox"/> Direct Recertification No:</td> </tr> </table> | | <input type="checkbox"/> New installation | <input type="checkbox"/> Work of the following type must ALSO be notified to the ELECTRICITY DISTRIBUTOR (DNP) | <input type="checkbox"/> Additions or alterations to a switchboard or associated equipment | <input type="checkbox"/> Direct Recertification No: | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <input type="checkbox"/> New installation | <input type="checkbox"/> Work of the following type must ALSO be notified to the ELECTRICITY DISTRIBUTOR (DNP) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <input type="checkbox"/> Additions or alterations to a switchboard or associated equipment | <input type="checkbox"/> Direct Recertification No: | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <p>EQUIPMENT RATING No. PARTICULARS OF WORK</p> <table border="1"> <tr> <td><input type="checkbox"/> Sockets-outlets</td> <td><input type="checkbox"/> Lighting</td> <td><input type="checkbox"/> Appliances</td> <td><input type="checkbox"/> Circuits</td> <td><input type="checkbox"/> Sockets-outlets</td> <td><input type="checkbox"/> Cables</td> <td><input type="checkbox"/> Rating No. [Redacted]</td> </tr> <tr> <td><input type="checkbox"/> Work is connected to supply</td> <td><input type="checkbox"/> Estimated increase in load A/ph [Redacted]</td> <td><input type="checkbox"/> Actual load is within capacity of installation/service mains</td> <td><input type="checkbox"/> Work is not connected to supply</td> <td><input type="checkbox"/> Estimated increase in load A/ph [Redacted]</td> <td><input type="checkbox"/> Actual load is within capacity of installation/service mains</td> <td><input type="checkbox"/> Work has been carried out</td> </tr> <tr> <td><input type="checkbox"/> Work is not connected to supply</td> <td><input type="checkbox"/> Estimated increase in load A/ph [Redacted]</td> <td><input type="checkbox"/> Actual load is within capacity of installation/service mains</td> <td><input type="checkbox"/> Work is connected to supply</td> <td><input type="checkbox"/> Estimated increase in load A/ph [Redacted]</td> <td><input type="checkbox"/> Actual load is within capacity of installation/service mains</td> <td><input type="checkbox"/> Work has been supervised by:</td> </tr> <tr> <td><input type="checkbox"/> Work is not connected to supply</td> <td><input type="checkbox"/> Estimated increase in load A/ph [Redacted]</td> <td><input type="checkbox"/> Actual load is within capacity of installation/service mains</td> <td><input type="checkbox"/> Work is connected to supply</td> <td><input type="checkbox"/> Estimated increase in load A/ph [Redacted]</td> <td><input type="checkbox"/> Actual load is within capacity of installation/service mains</td> <td><input type="checkbox"/> Work has been supervised by:</td> </tr> </table> | | <input type="checkbox"/> Sockets-outlets | <input type="checkbox"/> Lighting | <input type="checkbox"/> Appliances | <input type="checkbox"/> Circuits | <input type="checkbox"/> Sockets-outlets | <input type="checkbox"/> Cables | <input type="checkbox"/> Rating No. [Redacted] | <input type="checkbox"/> Work is connected to supply | <input type="checkbox"/> Estimated increase in load A/ph [Redacted] | <input type="checkbox"/> Actual load is within capacity of installation/service mains | <input type="checkbox"/> Work is not connected to supply | <input type="checkbox"/> Estimated increase in load A/ph [Redacted] | <input type="checkbox"/> Actual load is within capacity of installation/service mains | <input type="checkbox"/> Work has been carried out | <input type="checkbox"/> Work is not connected to supply | <input type="checkbox"/> Estimated increase in load A/ph [Redacted] | <input type="checkbox"/> Actual load is within capacity of installation/service mains | <input type="checkbox"/> Work is connected to supply | <input type="checkbox"/> Estimated increase in load A/ph [Redacted] | <input type="checkbox"/> Actual load is within capacity of installation/service mains | <input type="checkbox"/> Work has been supervised by: | <input type="checkbox"/> Work is not connected to supply | <input type="checkbox"/> Estimated increase in load A/ph [Redacted] | <input type="checkbox"/> Actual load is within capacity of installation/service mains | <input type="checkbox"/> Work is connected to supply | <input type="checkbox"/> Estimated increase in load A/ph [Redacted] | <input type="checkbox"/> Actual load is within capacity of installation/service mains | <input type="checkbox"/> Work has been supervised by: | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <input type="checkbox"/> Sockets-outlets | <input type="checkbox"/> Lighting | <input type="checkbox"/> Appliances | <input type="checkbox"/> Circuits | <input type="checkbox"/> Sockets-outlets | <input type="checkbox"/> Cables | <input type="checkbox"/> Rating No. [Redacted] | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <input type="checkbox"/> Work is connected to supply | <input type="checkbox"/> Estimated increase in load A/ph [Redacted] | <input type="checkbox"/> Actual load is within capacity of installation/service mains | <input type="checkbox"/> Work is not connected to supply | <input type="checkbox"/> Estimated increase in load A/ph [Redacted] | <input type="checkbox"/> Actual load is within capacity of installation/service mains | <input type="checkbox"/> Work has been carried out | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <input type="checkbox"/> Work is not connected to supply | <input type="checkbox"/> Estimated increase in load A/ph [Redacted] | <input type="checkbox"/> Actual load is within capacity of installation/service mains | <input type="checkbox"/> Work is connected to supply | <input type="checkbox"/> Estimated increase in load A/ph [Redacted] | <input type="checkbox"/> Actual load is within capacity of installation/service mains | <input type="checkbox"/> Work has been supervised by: | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <input type="checkbox"/> Work is not connected to supply | <input type="checkbox"/> Estimated increase in load A/ph [Redacted] | <input type="checkbox"/> Actual load is within capacity of installation/service mains | <input type="checkbox"/> Work is connected to supply | <input type="checkbox"/> Estimated increase in load A/ph [Redacted] | <input type="checkbox"/> Actual load is within capacity of installation/service mains | <input type="checkbox"/> Work has been supervised by: | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <p>TEST REPORT Indicate the relevant tests and checks that have been performed on the work.</p> <table border="1"> <tr> <td><input type="checkbox"/> Earthling system integrity Q</td> <td><input type="checkbox"/> Residual current device operation</td> </tr> <tr> <td><input type="checkbox"/> Installation resilience Mo</td> <td><input type="checkbox"/> Visual check that installation is suitable for connection to supply</td> </tr> <tr> <td><input type="checkbox"/> Polarity</td> <td><input type="checkbox"/> Ground-line power system complies with AS 4509</td> </tr> <tr> <td><input type="checkbox"/> Correct outlet connections</td> <td><input type="checkbox"/> Fault loop impedance (if necessary) OPTONAL</td> </tr> <tr> <td><input type="checkbox"/> Certificate complies with AS/NZS 3000 and is suitable for its intended use.</td> <td><input type="checkbox"/> Certificate complies with AS/NZS 3000 and is suitable for its intended use.</td> </tr> </table> | | <input type="checkbox"/> Earthling system integrity Q | <input type="checkbox"/> Residual current device operation | <input type="checkbox"/> Installation resilience Mo | <input type="checkbox"/> Visual check that installation is suitable for connection to supply | <input type="checkbox"/> Polarity | <input type="checkbox"/> Ground-line power system complies with AS 4509 | <input type="checkbox"/> Correct outlet connections | <input type="checkbox"/> Fault loop impedance (if necessary) OPTONAL | <input type="checkbox"/> Certificate complies with AS/NZS 3000 and is suitable for its intended use. | <input type="checkbox"/> Certificate complies with AS/NZS 3000 and is suitable for its intended use. | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <input type="checkbox"/> Earthling system integrity Q | <input type="checkbox"/> Residual current device operation | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <input type="checkbox"/> Installation resilience Mo | <input type="checkbox"/> Visual check that installation is suitable for connection to supply | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <input type="checkbox"/> Polarity | <input type="checkbox"/> Ground-line power system complies with AS 4509 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <input type="checkbox"/> Correct outlet connections | <input type="checkbox"/> Fault loop impedance (if necessary) OPTONAL | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <input type="checkbox"/> Certificate complies with AS/NZS 3000 and is suitable for its intended use. | <input type="checkbox"/> Certificate complies with AS/NZS 3000 and is suitable for its intended use. | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <p>CERTIFICATION I, the Electrical Contractor give notice to the Customer and (Name of DNP or OFT), that the work described in this Certificate has been completed in accordance with the Electrical Contract (Consumer Safety) Regulation 2006.</p> | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <p>I confirm that I have carried out the above tests and visually checked that the installation work described in this Certificate complies with AS/NZS 3000 and is suitable for its intended use.</p> | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <p>Signature: [Redacted] Date of Notice: [Redacted]</p> | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <p>Name: [Redacted] Licence No: [Redacted]</p> | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <p>Address: [Redacted] Telephone No: [Redacted]</p> | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <p>Date: [Redacted] Other Contractor: [Redacted]</p> | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <p>Comments: [Redacted]</p> | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

QUESTION 5
(2 marks)