

PULLING CABLES IN TO CONDUIT

T_0 = TENSION AT THE COMMENCEMENT OF A SECTION (N)

T = TENSION AT THE END OF A SECTION (N)

m = MASS OF CABLE PER UNIT LENGTH (kg m^{-1})

w = EQUIVALENT CABLE FORCE PER UNIT LENGTH = 9.81 $\text{m} (\text{N m}^{-1})$

μ = COEFFICIENT OF FRICTION IN A GIVEN SECTION


L = LENGTH OF STRAIGHT LEVEL SECTION (m) (OR)

LENGTH OF INCLINED SECTION (m)


R = RADIUS OF HORIZONTAL BEND (m)

θ = ANGLE OF SUBTENDED ARC IN BEND (RADIAN)

F = SIDE WALL FORCE (N m^{-1})




Straight Section




$$T = T_0 + \mu WL$$

Upward Inclined




$$T = T_0 + WL (\sin\theta + \mu \cos\theta)$$

Downward Incline



$$T = T_0 - WL (\sin\theta - \mu \cos\theta)$$


Horizontal Bend



$$T = T_0 \cosh \frac{\theta}{R} + \sqrt{(T_0)^2 + (wR)^2} \sin \frac{\theta}{R}$$


$$\cosh \theta = \frac{e^{\frac{\theta}{R}} + e^{-\frac{\theta}{R}}}{2}$$

Upward Curve



$$T = T_0 e^{\frac{\theta}{R}} +$$

UPWARD CONVEX BEND




$$T = T_0 e^{\frac{\mu\alpha}{2}} + \frac{WR}{1+\mu^2}$$

$$\sqrt{T^2 - \mu^2 \cos^2 \alpha}$$

$$\sqrt{(T_0)^2 + (WR)^2 \sin^2(\mu\alpha)}$$

$$\frac{\alpha - \alpha_0}{C + e}$$


UPWARD CONCAVE BEND



$$T = T_0 e^{\frac{\mu\alpha}{2}} + (1-\mu^2) \left(T_0 e^{-\frac{\mu\alpha}{2}} \right)$$

$$T = T_0 e^{\frac{\mu\alpha}{2}} - \frac{WR}{1+\mu^2} \quad [2]$$


DOWNTWARD CONVEX BEND



$$T = T_0 e^{\frac{\mu\alpha}{2}} + \frac{WR}{1+\mu^2} \left[2\mu \sin \alpha - (1-\mu^2) \left(e^{-\frac{\mu\alpha}{2}} - \cos \alpha \right) \right]$$

DOWNTWARD CONCAVE BEND





SPECIFICATION


THE CONTRACTOR MUST APPLY APPROPRIATE TENSION OF

THE CONSULT WITH RESPECTIVE INSTALLATION ARRANGEMENTS.

FORMULA:

$$T = T_0 e^{-\frac{\mu \alpha}{1+\mu^2}} \left[2\mu \sin \alpha - (1-\mu^2)(e^{-\alpha \cos \alpha}) \right]$$

DOWNTWARD CONCAVE BEND



$$T = T_0 e^{-\frac{\mu \alpha}{1+\mu^2}} \left[2\mu e^{\alpha \sin \alpha} + (1-\mu^2)(1-e^{\alpha \cos \alpha}) \right]$$

$$\alpha - (1-\mu^2)(e^{-\alpha \cos \alpha})$$


SPECIFICATION

THE CONTRACTOR MUST APPLY APPROPRIATE TENSION OF CABLE TO PULL THE CABLE IN TO

THE CONDUIT WITH RESPECTIVE INSTALLATION ARRANGEMENTS BY USING THE GIVEN

FORMULAE.

$$\left[\frac{F_0}{\rho g} e^{\sin \alpha} + (1 - \mu^2) \left(1 - e^{-\cos \alpha} \right) \right]$$




SEALING OF CABLES - ALL POWER AND CONTROL CABLE SHALL BE PROTECTED AGAINST MOISTURE INGRESS AT ALL TIMES.

SEALING - USE OF SUITABLE HEAT SHRINK END CAP.

SHORING OF CABLE LAYING

MULTI CORE CABLES

THE CONDUCTORS OF MULTI CORE CABLES SHALL BE SHORED OUT USING
CLOUTS AND 10 TURNS OF 1.63mm² TINNED COPPER WIRE



- CABLE LAYING OPERATIONS SHALL EMPLOY SUFFICIENT
CONTROL TO ENSURE THAT NO DAMAGE IS CAUSED TO
NEWLY LAID CABLES (or) TO EXISTING CABLE INFRASTRUCTURE.
- CABLE JOINTS SHALL BE INSTALLED IN A STRAIGHT SECTION
OF TRENCH WITH AT LEAST 2 METRES OF STRAIGHT CABLE
AT EITHER SIDE OF THE JOINT. REFER NS172

- THE FOLLOWING TABLE MUST BE UTILIZED TO DETERMINE THE BENDING RADIUS.

MINIMUM INTERNAL BENDING RADIUS

CABLE TYPE	DURING INSTALLATION	AFTER INSTALLATION
LESS THAN OR EQUAL TO 25mm DIAMETER	6D	4D
GREATER THAN 25mm dia:	4D	6D
ALL LOW VOLTAGE CABLES	12D	8D
11 KV PVC	18D	12D
11 KV NYLON SHEATHED CABLE	30D	20D
11 KV MULTI CORE LEAD SHEATHED HOPE OUTER SHEATHED	25D	15D

MUST BE UTILIZED TO DETERMINE THE BENDING RADIUS.

MINIMUM INTERNAL BENDING RADIUS

	DURING INSTALLATION	AFTER INSTALLATION
WIRE	6D	4D
WIRE & BRAID	9D	6D
CABLES	12D	8D
	18D	12D
SHEATHED	30D	20D
2E	25D	15D
H&D		
A&T H&D		

MINIMUM INTERNAL BENDING RADIUS

11 kV XLPE

300 AL (3X2 mm Cu) (ws) 2 40 | 350 560
mm ↓

500 AL 3G TRYQ G35 Cu (ws) 2 40 | 350 630
mm ↓

ELECTRICAL CONTRACTING

MANAGEMENT AND PLANNING

SERVICE WORK

SERVICE WORK IS NOT FOR EVERY CONTRACTOR NOR CAN IT BE DONE WELL IN EVERY LOCATION. IT IS IMPORTANT TO MAKE A BOLD DISTINCTION BETWEEN SERVICE WORK AND NEW CONSTRUCTION WORK.

CERTAINLY THEY BOTH INVOLVE INSTALLING ELECTRICAL MATERIALS.

- IT NEEDS A LARGE ENOUGH MARKET TO SUSTAIN A SERVICE BUSINESS
USUALLY THIS REQUIRES A POPULATION OF AT LEAST 250,000 IN YOUR AREA

COMPETITION CAN MAKE IT DIFFICULT TO GET A STEADY WORK

- YOU NEEDS TO HAVE AN ELECTRICIAN WHO CAN HANDLE THE PRESSURE THAT SERVICE WORK PLACE UPON THEM
- IT NEEDS TO HANDLE MORE PAPER WORKS FOR SERVICE WORK
- IT NEEDS A GOOD ESTIMATOR / SALES PERSON TO HANDLE THE LARGE NUMBER OF ESTIMATES
 - GOOD ESTIMATOR
 - GOOD PUBLIC RELATION SKILL

GETTING WORK

- ADVERTISING
- PHONE YELLOW BOOK
- ADVERTISING NEEDS PEOPLE ATTENTION

CREATIVITY IN ADVERTISING
COST EFFECTIVENESS
GOOD SALESMANSHIP
PUNCTUAL SOCIALIZATION
FINANCIAL BACKGROUND
BANK GUARANTEE.

DOING THE WORK

- URGENT
 - ENOUGH TOOLS TO HANDLE DIVERSE RANGE OF JOBS
 - ELECTRICAL + MECHANICAL + ELECTRONICS EQUIPMENTS / Tools
 - RELATED FIELDS & MULTI SKILLS

E-9 → ELECTRICAL + PLUMBING
WATER CAB

ELECTRICAL + PLUMBING
HOUSE WIRING + DATA CABLING + TELECOM : CABLING
ELECTRICAL FITTING + SHEET METAL + MECHANICAL FITTING ETC
CALL FOR INFORMATION.

- ELECTRICAL FITTING

 - DIVERSED RANGE OF CATALOGUES AND SUPPLIER INFORMATIONS
 - SOURCE OF SPARE PARTS AND ORDERING INFORMATION.
 - MATERIAL REQUEST PREPARATION SKILLS.

MATERIAL REQUEST

CONCRETE CONSTRUCTION WORK

ALL CONCRETE SHALL BE IN ACCORDANCE WITH THE REQUIREMENTS OF AS 3600.

(a) CEMENT

CEMENT SHALL BE TYPE GP GENERAL PURPOSE PORTLAND CEMENT (OR)
EQUIVALENT COMPLYING WITH AS 3972.

(b) FINE AGGREGATE

FINE AGGREGATE MUST BE CLEAN, SHARP, HARD, DURABLE GRAIN.
UNIFORM IN QUALITY AND FREE FROM HARMFUL AMOUNT OF SOFT (OR)
FLAKY PARTICLES, DUST, LUMPS, LOAM, CLAY, SLAG, ORGANIC OR
OTHER DETERIORIOUS SUBSTANCES COMPLYING WITH AS 2758.1

(c) COARSE AGGREGATES

COARSE AGGREGATES SHALL COMPLY WITH AS 2758

(d) TESTING AGGREGATES

TESTING AGGREGATES SHALL COMPLY WITH AS 1141

(e) WATER

WATER SHALL COMPLY WITH THE PROVISIONS OF AS 3600.

(f) REINFORCEMENT

REINFORCEMENT SHALL BE EITHER STEEL BARS COMPLYING
WITH AS 4671 (OR) HARD DRAWN STEEL WIRE
COMPLYING WITH AS 4671.

REINFORCEMENT SHALL BE ACCURATELY CUT TO SIZE AND
BENT TO SHAPE AND SHALL BE FREE FROM SCALE
OIL AND LOOSE RUST.

SITE MIXED CONCRETE

CONCRETE MIXING CARRIED OUT ON SITE SHALL BE BY ROTATING BATCH MIXERS ONLY, UNLESS SPECIFICALLY APPROVED ON SITE BY SITE BASIS

READY MIXED CONCRETE

READY-MIXED CONCRETE FROM AN APPROVED CENTRAL MIXING SHALL BE ACCEPTABLE THAT BOTH ITS USE AND PROPERTIES COMPLY WITH AS1379.

CONCRETE CONSTRUCTION

(a) FORM WORK

FORM WORK SHALL COMPLY WITH AS3610. FORMS SHALL CONFORM TO THE SHAPES, LINES AND DIMENSIONS SHOWN ON THE DRAWINGS. ALL FORMS AND SUPPORTS SHALL BE SOUND TIMBER (OR) STEEL, PLYWOOD (OR) SIMILAR MATERIALS OF SUFFICIENT STRENGTH AND BE ADEQUATELY TIGHT TO PREVENT LEAKAGE OF MORTAR. FORM WORK TIES SHALL BE USED TO MAINTAIN CORRECT SEPARATION OF VERTICAL SURFACES.

TIMBER FORM WORK FOR EXPOSED SURFACES SHALL BE DRESSED. ALL FORMING SURFACES SHALL BE COATED WITH APPROVED FORM RELEASE AGENT BEFORE POURING COMMENCES. COATING SHALL BE DONE BEFORE ANY

REINFORCEMENT IS FIXED IN POSITION

CONCRETE TESTING

TESTING OF CONCRETE SHALL COMPLY WITH AS 3600.

TEST CYLINDERS · SLUMP TEST SHALL BE TAKEN

CONSTRUCTION JOINTS

BEFORE FRESH CONCRETE IS PLACED AGAINST
HARDENED CONCRETE AT CONSTRUCTION JOINTS, THE
JOINT SURFACE OF THE HARDENED CONCRETE
SHALL BE CLEANSED BY REMOVING ALL LOOSE AND
SOFT MATERIALS.

CONCRETE FINISHING

UNRENDERED OFF FORM SURFACES SHALL
COMPLY WITH THE TOLERANCES AND SURFACE
FINISH REQUIREMENTS DESCRIBED IN CLASS 3

FORM WORK OF AS 3610. SURFACE FINISH
SHALL COMPLY WITH CLASS 4 FORM WORK OF AS 3610

CABLE PULLING

THE PULLING TENSION OF POWER CABLE SHALL NOT EXCEED CABLE MANUFACTURER'S SPECIFICATION

INSTALLING CABLES IN SUB STATIONS & SWITCHING STATIONS

NOTICE FOR ACCESS MUST BE REQUESTED.

NECESSARY SCREENS (OR) PROTECTIVE DEVICES SHALL BE INSTALLED.

WEATHER PROOF LABELS SHALL BE ATTACHED TO ALL CABLE ENDS INSTALLED IN
SUB STATIONS.

INSTALLING CABLES IN KIOSK TYPE SUBSTATION

ALL CABLES SHALL BE LAID SO THAT THEY ENTER PERPENDICULAR TO H.V & L.V

ACCESS DOORS OF THE KIOSK.

INTERNAL BENDING RADIUS SHALL NOT BE LESS THAN MANUFACTURER'S SPECIFICATION

INSTALLING CABLES IN CABLE RISERS

CABLES INSTALLED IN CABLE RISERS SHALL BE CLAMPED AT A MAXIMUM OF 1M²/R

INTERVALS. CABLE CLAMPS SHALL BE NON FERROUS MATERIALS AND DIRECTLY BOLTED

TO CABLE RISER WALLS

(UNSEALED WITH BOLTS, NUTS, WASHERS OF)

CABLE JOINING
NS 129/177

CABLE TEST
NS 161

BACK FILL MATERIALS

THE BACK FILL MATERIALS SHOULD RESTORE THE SUBGRADE OF ORIGINAL CONDITION WHICH MAY BE ACHIEVED BY REPLACING THE EXCAVATED MATERIALS IN THE SAME POSITION FROM WHICH THEY WERE EXCAVATED.

RTA, LOCAL COUNCIL MUST SATISFY BACK FILL MATERIALS.
BUILDING MATERIALS (Eg. CONCRETE, BRICKS, PAVING, ROCK,
ROOFING TILGS, RUBBLE) AND CONTAMINATED SUBSTANCES
INCLUDING HAZARDOUS MATERIALS MUST NOT BE USED IN BACK FILLS.

ELECTRICAL CONTRACTING

SPECIALITY WORK

SPECIALITY WORK IS ALMOST ALWAYS MORE PROFITABLE THAN
REGULAR ELECTRICAL INSTALLATION ON A PERCENTAGE BASIS.

THERE ARE TWO DIVISIONS OF SPECIALITY WORK

- ① SPECIAL TYPES OF INSTALLATIONS
- ② SPECIAL SERVICE TO SPECIFIC TYPES OF CUSTOMERS.

SPECIAL TYPES OF INSTALLATION

TELEPHONE WORK

FIRE ALARM SYSTEMS

SECURITY SYSTEMS

TELEVISION SYSTEM (CLOSED CIRCUIT T.V.)

LIGHTNING PROTECTION SYSTEM

TRAFFIC LIGHTING INSTALLATIONS.

HIGH VOLTAGE WORK

LIGHTING MAINTENANCE SERVICE

EMERGENCY MANAGEMENT AND PROGRAMMABLE CONTROLLERS

GROWING AREAS OF SPECIALIST WORKS

- EMERGENCY MANAGEMENT
 - LIGHTNING PROTECTION - GREATLY DETERMINED BY GEOGRAPHY
 - FIRE ALARM WORK - (RELATED TO BUILDING INDUSTRY)
 - TELEPHONE WORK / CABLE
T.V TELECOMMUNICATION
-

DESIGN AND BUILD WORK

- THE AMOUNT OF COMPETITION FOR JOB IS FAR LESS, SOMETIMES NON EXISTENT
- THE ELECTRICAL CONTRACTOR IS COMPENSATED FOR PROVIDING THE DESIGN SERVICE THAT ARE USUALLY DONE BY AN ENGINEER.
- THE CUSTOMER USUALLY GETS A BETTER PRICE FOR THE SAME QUALITY OF WORK BY USING A QUALIFIED DESIGN / BUILD CONTRACTOR
- CO-OPERATION DURING THE CONSTRUCTION PROCESS IS USUALLY BETTER ON DESIGN / BUILD PROJECTS THAN ON CONTRACT BID PROJECTS
- DESIGN / BUILD WORK USUALLY CARRIES LESS RISK THAN OTHER TYPES OF ELECTRICAL CONTRACTING.

REQUIREMENTS

- THE CONTRACTOR MUST DEVELOP A GREAT DEAL OF TRUST IN HIS CUSTOMERS
 - THE CONTRACTOR MUST OFFER THE CUSTOMER A BETTER VALUE FOR MONEY
 - THE INSTALLATION MUST BE DONE IN A FIRST CLASS MANNER
 - THE CONTRACTOR AND ALL OF HIS PERSONNELS MUST MAINTAIN A HIGH STANDARDS OF COURTESY TO THE CUSTOMERS
 - THE CUSTOMER'S INTEREST MUST TAKE PRIORITY OVER THE CONTRACTOR'S
- ※ THE PROJECT MUST MEET ALL LOGICS
- ※ THE ELECTRICAL CONTRACTOR MUST HAVE ABILITY TO PERFORM INSTALLATION PROPERLY
- # THE ELECTRICAL CONTRACTOR'S ABILITY TO HANDLE ALL DETAILS OF DESIGNS.