

SPECIFICATIONS FOR HIGH VOLTAGE OVER HEAD CONDUCTORS

www.powersemester4.zoomshare.com

E071

(1) Class notes + Flexible for Electrical contracting & Estimating

Est Estimating 1 / 2 / 3

(2A) Class Teaching notes references for specifications

E071 Design HV OH conductor

—— L.V OH conductor

—— Hazard Identification

—— General wiring

—— UG cable

—— Telecom + Datacom

Switching

Design Std for

OH Development

om

Electrical Contracting & Estimating

References for specifications

H conductor

for

conductor

Switching design std for OH development

om

(2B) Flexible study notes & ref. for specification



CONSTRUCTION REQUIREMENT FOR
11KV OH CONDUCTOR.



COVERED CONDUCTOR (CCT) ↔ AS 3695

BARE CONDUCTOR (BC) ↔ AS 1222, AS 3607, AS 1531, AS 1746

AERIAL BUNDLED CABLE (ABC) ↔ AS 3599.1, AS 3599.2,



CONSTRUCTION

- COVERING → XLPE (CROSS LINK POLYETHYLENE), HDPE (HIGH DENSITY POLYETHYLENE)
- WATER BLOCKING COMPOUND ↔ GREASING IN JOINTS.
- CONDUCTOR ALLOY ↔ AAAC / 1120 ALUMINIUM ALLOY



MINIMUM 500 mm PHASE TO PHASE SPACING.


ENE), HDPE (HIGH DENSITY POLYETHYLENE)




LOCATION	CLEARANCE
OVER THE CARRIAGE WAY OF ROADS	7.5m
OVER THE GROUND OTHER THAN THE CARRIAGE WAY OF ROADS	6m
NO ACCESS FOR VEHICLE OR MOBILE PLANTS	5m

INSULATORS


MORLYNN PIN POST



NGK PIN POST



NGK STRAIN ROD




LIGHTNING PROTECTION

SURGE ARRESTERS

10 KV POLY METRIC ARRESTOR

11 KV CURRENT LIMITING ARRESTOR HORN



ELECTRODE BARS FOR
SURGE ARRESTERS

CSA

H.V SURGE ARRESTERS - 10mm²

POLE TRANSFORMER H.V
ARRESTOR - 16mm²

CURRENT LIMITING



ADJUSTABLE
ARCS HORN

CURRENT
LIMITING
ARRESTOR

INSULATION


AS 18

PROTECTION

ARRESTERS

6 KV POLY METRIC ARRESTER

11 KV CURRENT LIMITING ARCING HORN



ARRESTER
ARRESTER


ELECTRODE BARS FOR SURGE ARRESTERS

C.SA

H.V SURGE ARRESTERS - 10mm²

POLE TRANSFORMER H.V ARRESTER - 16mm²

CURRENT LIMITING ARCING HORN



INSULATION COORDINATION

AS 1824.1, AS 1824.2

INSULATING COVERS AND FITTINGS

INSULATORS

MORLYNN PIN POST



NGK PIN POST



NGK STRAIN ROD




LIGHTNING PROTECTION

SURGE ARRESTERS

10 KV POLY METRIC ARRESTER

11 KV CURRENT LIMITING ARCING HORN




ELECTRODE BARS FOR
SURGE ARRESTERS

H.V SURGE ARRESTERS - 10mm^2

POLE TRANSFORMER H.V
ARRESTOR - 16mm^2

CURRENT LIMITING



ADJUSTABLE
NOTCH
HORN

CURRENT
LIMITING
ELEMENT


INSULATION

AS 18

C.SA - CROSS

4 METRIC ARRESTER
CURRENT LIMITING ARCING HORN
LINE CONNECTION CABLE

CURRENT LIMITING ARCING HORN



INSULATING COVERS AND FITTINGS

80 mm² / 120 mm² STRAIN CLAMPS & COVER

PARALLEL GROOVE CLAMP AND COVER

EARTH POINT COVER

MAIN CONDUCTOR
7/3.75 → 19/3.5

TAPPING CONDUCTOR
7/3.75 → 19/3.5

EARTH CABLE

INSULATION COORDINATION


AS 1824.1, AS 1824.2

ELECTRODE BARS FOR SURGE ARRESTERS

C.S.A - CROSS SECTIONAL AREA

H.V SURGE ARRESTERS - 10 mm²

DOUBLE TRANSFORMER H.V ARRESTER - 16 mm²



POLE TOP SWITCHES


— NON ENCLOSED ISOLATING SWITCHES

LOAD BREAK INTERRUPTERS

POLE TRANSFORMERS

POLE TRANSFORMERS CAN ONLY BE CONNECTED TO
CROSS-ARM MOUNTED COVERED CONDUCTORS.

ANGLE OF DEVIATION SPECIFICATIONS



ANGLE OF DEVIATION

VERTICAL CONSTRUCTION

$> 30^\circ$

DEVIATION

REQ

STRAIN

STRAIN

HORIZONTAL CONSTRUCTION

$\leq 25^\circ$ DEVIATION

$> 25^\circ$ BUT $\leq 50^\circ$

$> 50^\circ$

PIN PO

PIN PO

STRAIN

ROD A

ANGLE OF DEVIATION

REQUIRED CONSTRUCTION

VERTICAL CONSTRUCTION

$> 30^\circ$

DEVIATION

STRAIN CLAMP AND

STRAIN ROD ARRANGEMENT

HORIZONTAL CONSTRUCTION

$< 25^\circ$ DEVIATION

PIN POST (SINGLE CROSS ARM)

$> 25^\circ$ BUT $< 50^\circ$


PIN POST (DOUBLE CROSS ARM)

$> 50^\circ$



STRAIN CLAMP AND STRAIN

ROD ARRANGEMENT

HIGH VOLTAGE AERIAL BUNDLED CABLES



- AS 1222 (STEEL CONDUCTORS & STAYS - BARE OVER HEAD)
- AS 1531 (CONDUCTORS - BARE OVER HEAD, ALUMINIUM, ALUMINIUM ALLOY)
- AS 1746 (CONDUCTORS - BARE OVER HEAD, HARD DRAWN COPPER)
- AS 3607 (CONDUCTORS - BARE OVER HEAD, ALUMINIUM ALUMINIUM ALLOY STEEL REINFORCE)




POLE TOP SWITCHES — NON ENCLOSED ISOLATING SWITCHES

LOAD BREAK INTERRUPTERS

POLE TRANSFORMERS

POLE TRANSFORMERS CAN ONLY BE CONNECTED TO CROSS-ARM MOUNTED COVERED CONDUCTORS.

ANGLE OF DEVIATION SPECIFICATIONS




ANGLE OF DEVIATION	REQUIRED CONSTRUCTION
VERTICAL CONSTRUCTION $> 30^\circ$ DEVIATION	STRAIN CLAMP AND STRAIN ROD ARRANGEMENT
HORIZONTAL CONSTRUCTION $< 25^\circ$ DEVIATION	PIN POST (SINGLE CROSS ARM)
$> 25^\circ$ BUT $< 30^\circ$	PIN POST (DOUBLE CROSS ARM)
$> 30^\circ$	STRAIN CLAMP AND STRAIN ROD ARRANGEMENT

NON ENCLOSED ISOLATING SWITCHES

LOAD BREAK INTERRUPTERS


FORMERS CAN ONLY BE CONNECTED TO MOUNTED COVERED CONDUCTORS.

ION SPECIFICATIONS



ANGLE OF DEVIATION	REQUIRED CONSTRUCTION
VERTICAL CONSTRUCTION $> 30^\circ$ DEVIATION	STRAIN CLAMP AND STRAIN ROD ARRANGEMENT
HORIZONTAL CONSTRUCTION $\leq 25^\circ$ DEVIATION	PIN POST (SINGLE CROSS ARM)
$> 25^\circ$ BUT $\leq 50^\circ$	PIN POST (DOUBLE CROSS ARM)
$> 50^\circ$	STRAIN CLAMP AND STRAIN ROD ARRANGEMENT

HIGH VOLTAGE AERIAL LINE



- AS 1622 (STEEL CORE)
- AS 1581 (CONDUCTORS)
- AS 1746 (CONDUCTORS)
- AS 3607 (CONDUCTORS)

VERTICAL

- PHASE (C)
- PHASE (B)
- PHASE (A)

THE WORK METHODS & INSTALLATION PROCEDURES
MUST COMPLY WITH THE FOLLOWING AUSTRALIAN
STANDARDS AND SAFETY REGULATIONS

MINIMUM ACCEPTABLE IR (INSULATION RESISTANCE)

400 MΩ PHASE TO PHASE

100+ MΩ PHASE TO EARTH

AS 1307.2 SURGE ARRESTERS - METAL OXIDE TYPE FOR AC SYSTEM

AS 1824.1 INSULATION CO-ORDINATION

AS 1824.2 INSULATION CO-ORDINATION APPLICATION TYPE

AS 3675 CONDUCTORS - COVERED OVERHEAD FOR WORKING VOLTAGE
6.35 / 11KV

AS 3599.1 ELECTRIC CABLE, AERIAL BUNDLES

AS 3766 FITTINGS FOR AERIAL BUNDLED CABLE

ESAA HB C(b)-1 - GUIDE LING & MAINTENANCE OF OH

1999 DISTRIBUTION & TRANSMISSION LINE.

ELECTRICITY SAFETY ACT 1945

OHS ACT 2000

OHS REGULATIONS 2001

ENVIRONMENTAL REGULATIONS

& ACTS

