

Q007

pb DETERMINE THE VOLTAGE DROP FOR EACH 3 ϕ SEPARATE FINAL SUB CIRCUIT
PERMISSIBLE VOLTAGE DROP IS 14.2V.

SEPARATE FINAL SUB CIRCUIT	ROUTE LENGTH	CURRENT	TABLE	V_c	$V_d = \frac{V_c L I}{1000}$	VOLTAGE	CONDITION	
							ACCEPTABLE	NOT ACCEPTABLE
① 2.5mm ² COPPER V75 TPI CABLE IN CONDUIT	30m	75A	40	1.54	$\frac{1.54 \times 30 \times 75}{1000}$	3.49	✓	
② 2.5mm ² COPPER V75 SBI CABLE UNENCLOSED & SPACED APART	40m	27A	41	15.6	$\frac{15.6 \times 40 \times 27}{1000}$	16.85		✓
③ 10mm ² COPPER X-HF 110 MULTICORE CABLE ON CABLE TRAY	10m	80A	42	4.3	$\frac{4.3 \times 10 \times 80}{1000}$	3.43	✓	
④ 10mm ² COPPER MULTICORE MIMS	25m	55A	48	3.92	$\frac{3.92 \times 25 \times 55}{1000}$	5.39	✓	
⑤ 150mm ² COPPER MULTICORE MIMS	3m	400A	48	0.297	$\frac{0.297 \times 3 \times 400}{1000}$	0.36	✓	

SEPARATE FINAL SUB CIRCUIT	ROUTE LENGTH	CURRENT	TABLE	V_c	$V_d = \frac{V_c L I}{1000}$	VOLTAGE	CONDITION	
							ACCEPTABLE	NOT ACCEPTABLE
⑥ 70mm ² ALUMINIUM MULTI WIRE X-90 CABLE ON TRAY	120m	180A	45	0.943	$\frac{0.943 \times 120 \times 180}{1000}$	21.45		✓
⑦ 2.5mm ² COPPER V75 TPS MULTI WIRE CABLE IN CONDUIT	15m	16A	40	15.6	$\frac{15.6 \times 15 \times 16}{1000}$	3.74	✓	
⑧ 10mm ² COPPER V90 TPS MULTI WIRE, UG CONDUIT	55m	8A	40	44.7	$\frac{44.7 \times 55 \times 8}{1000}$	19.67		✓
⑨ 25mm ² ALUMINIUM X-90 TPI CABLE IN CONDUIT	117m	90A	43	2.67	$\frac{2.67 \times 117 \times 90}{1000}$	28.1		✓
⑩ 2.5mm ² COPPER V90 SDI CABLE ON CABLE TRAY	81m	25A	41	15.6	$\frac{15.6 \times 81 \times 25}{1000}$	31.59		✓

SEPARATE FINAL SUB CIRCUIT	ROUTE LENGTH	CURRENT	TABLE	V_c	$V_d = \frac{V_c L I}{1000}$	VOLTAGE	CONDITION	
							ACCEPTABLE	NOT ACCEPTABLE
11 1.5mm ² COPPER U 90 SO 1 ON CABLE TRAY	17m	17A	41	28.6	$\frac{28.6 \times 17 \times 17}{1000}$	8.27	✓	
12 1mm ² 4 CORE FLEXIBLE CABLE	36m	4A	47	39.1	$\frac{39.1 \times 36 \times 4}{1000}$	5.63	✓	
13 6mm ² COPPER 4 CORE PVC INSULATED TWISTED AERIAL CABLE	40m	36A	49	6.71	$\frac{6.71 \times 40 \times 36}{1000}$	9.66	✓	
14 25mm ² ALUMINIUM PVC INSULATED SINGLE CORE, AERIAL CABLE	13m	100A	50	2.6	$\frac{2.6 \times 13 \times 100}{1000}$	3.38	✓	
15 10mm ² R-EP FLEXIBLE CABLE 4 CORE	2m	60A	47	4.38	$\frac{4.38 \times 2 \times 60}{1000}$	0.33	✓	

Q007

USE AS / NZS 3008.1.1 / TO DETERMINE THE VOLTAGE
DROP IN FOUR FINAL SUB CIRCUITS. COMPLETE THE TABLE BELOW

FOR FOUR CIRCUITS DESCRIBED

FOR EACH CIRCUIT — A — D GIVE

- ROUTE LENGTH OF THE CIRCUIT
- RATING OF THE CIRCUIT PROTECTION DEVICE
- THE CONDUCTOR SIZE OF THE CIRCUIT CABLES
- THE $mV/A\cdot m$ VALUE FOR CONDUCTOR SIZE
- CALCULATION WORKING
- VOLTAGE DROP FOR CABLE.

ASSUME ALL CABLES ARE OPERATING AT THEIR
NORMAL TEMPERATURE.

(A) - A CIRCUIT IN A FACTORY SUPPLYING TWO 15 A 3ϕ SOCKET OUTLETS
ROUTE 42 m, PROTECTED BY 25 A C.B. V75 TPI CABLES
ARE INSTALLED ENCLOSED IN AIR. — TABLE 40

(B) - A 40 A 3ϕ BOILER IS WIRED USING 10 mm, V75 TPI CABLES
INSTALLED IN RIGID PVC CONDUIT - THE BOILER IS SITUATED
56 m FROM THE SWITCH BOARD

(C) SIX 240V, 1000 W FLOOD LIGHTS OUTSIDE A FACTORY ON A
CIRCUIT PROTECTED BY A 32 A C.B. THE CIRCUIT CABLES ARE
V75 TPI INSTALLED ENCLOSED IN AIR, ROUTE LENGTH 46 m

(D) TWO SINGLE PHASE SOCKET OUTLETS INSTALLED ON A CIRCUIT WITH
ROUTE LENGTH 56 m. PROTECTED BY 32 A C.B.
CABLES ARE V75 TPI INSTALLED ENCLOSED IN AIR
NON DOMESTIC INSTALLATION.

CIRCUIT	ROUTE LENGTH	PROTECTION DEVICE RATING	CONDUCTOR SIZE	mV / Arm V _c	CALCULATION WORKING V _d = $\frac{V_c L}{1000}$	VOLTAGE DROP
A	3φ SINGLE CORE TABLE 2(2) 3 SINGLE CORE ITEM (4) → TABLE 6/7 col 8/9 42 m	25 A	4 mm ²	TABLE (40) 9.91	$\frac{9.91 \times 42 \times 25}{1000}$	10.19
B	3 SINGLE CORE TABLE 2(2) 1 ITEM (4) → TABLE 6/7 col 8/9 56 m	40 A	10 mm ²	TABLE (40) 3.86	$\frac{3.86 \times 56 \times 40}{1000}$	8.64
C	SINGLE CORE TABLE 2(2) ITEM (1) → TABLE 3/4 col 8/9 46 m	32 A	6 mm ²	TABLE (40) $6.49 \div 0.866$ 7.5	$\frac{7.5 \times 46 \times 32}{1000}$	11.04
D	SINGLE CORE TABLE 2(2) ITEM (1) → TABLE 3/4 col 8/9 56 m	32 A	6 mm ²	TABLE (40) $6.49 \div 0.866$ 7.5	$\frac{7.5 \times 56 \times 32}{1000}$	13.44 V

