

## PROTECTION MECHANISM

- THERMAL
- MAGNETIC
- THERMAL MAGNETIC
- ELECTRONIC

## FAULT CURRENT LIMITERS

HRC FUSES CAN BE UTILIZED AS CURRENT LIMITERS TO TAKE OVER THE PROTECTION.

## SURGE DIVERTERS


THE SURGE DIVERTER HAS TWO MAJOR IMPORTANT FUNCTIONS. IT MUST DISCHARGE THE HIGH VOLTAGE SURGE TO EARTH. IT MUST PREVENT ANY FOLLOW UP CURRENT AT NORMAL LINE VOLTAGE.

### TWO BASIC TYPES

- VALVE TYPE
- EXPULSION TYPE

## INTERNALLY GENERATED OVER VOLTAGE

- SWITCHING TRANSIENT CAUSED BY SWITCHING
- VOLTAGE SPIKES THAT OCCUR WHEN A FUSE (OR) CIRCUIT BREAKER OPERATES
- MODERN ELECTRONIC EQUIPMENTS THAT INJECT HARMONIC VOLTAGE



CURRENT LIMITING  
RESISTOR

N<sub>1</sub> - RANGE

N<sub>2</sub> - POWER (1)





N<sub>3</sub> - POWER (2)

L - LIGHT

HWS - HOT WATER  
SYSTEM

## MOTOR PROTECTION

## SWITCH BOARD LAYOUT, WIRING & MARKING





## SWITCH BOARDS FOR NON DOMESTIC INSTALLATIONS

WITH COMMERCIAL AND INDUSTRIAL TYPE INSTALLATIONS AND IN COMMON WITH MOST OTHER INSTALLATION TYPES, THE CONSUMER'S MAIN TERMINATE AT A MAIN CONTROL POINT.

THE NATURE AND ELECTRICAL RATING OF THE LOAD DETERMINE THE NUMBER AND LOCATIONS OF VARIOUS DISTRIBUTION CENTRES AS NECESSARY.

CLIPAL SWITCH — SUPPLIED WITH 150A 3 $\phi$  MAIN SWITCH

BUSBAR RATING

150A  $\rightarrow$  400A TESTED FOR 16kA  
& 20kA

SPECIFICATION


AS 3000, AS 3439

LOCATION & ACCESS

MAIN SWITCH MUST BE READILY ACCESSIBLE. IT MUST NOT BE HIGHER THAN 2m ABOVE-GROUND, FLOOR (OR) OPERATION PLATFORM

MAIN SWITCH ACCOMMODATES FUSES, CIRCUIT BREAKERS AND SWITCHES.

- A SWITCH BOARD SHOULD NOT BE LOCATED IN BATH ROOM, TOILET, LAUNDRY, KITCHEN OF A DOMESTIC INSTALLATIONS.
- FIRE & SMOKE PROTECTION MUST BE PROVIDED



#### ARRANGEMENT OF EQUIPMENTS

FUSES AND CIRCUIT BREAKERS MUST BE ARRANGED SO THAT A PERSON LOOKING AT SWITCH BOARD CAN SEE INSTANTLY THEIR INTERRELATIONS.

- NO FUSE OR CIRCUIT BREAKER AT THE BACK OF SWITCH BOARD
- APPROPRIATE CLEARANCES FOR LIVE PARTS & BARE CONDUCTORS

### NEUTRAL LINK

MINIMUM SIZE AS SPECIFIED IN AS 3000 MUST BE FOLLOWED

### MARKING

LEGIBLE AND INDELIABLE

### WIRING

WIRING MUST BE RUN AT THE BACK OF SWITCH BOARD PANEL

### PANEL SWING

GO  $\rightarrow$  40° SWING

### RATING

FAULT LEVEL 1 kA FOR REWIRABLE FUSE

1.5 kA FOR PLUG IN C.B

8 kA FOR MCB (MAIN CIRCUIT BREAKER)

## AS3000: 2007 RULE BOOK EXERCISE

FIND THE RELEVANT CLAUSES FOR THE FOLLOWINGS: -

- SURGE DIVERTERS, MOTOR PROTECTION,  
SWITCH BOARD, ARRANGEMENT OF  
EQUIPMENTS IN SWITCH BOARD

- SWITCH BOARD WIRING

- NEUTRAL LINK, MARKING, RATING OF SWITCH BOARD.

G008 / G008 GENERAL  
NOTE (1)  
PART (4)

G008 / G008 GENERAL  
NOTE (2)  
PART (1)

G003 / G004  
HAZARD LIGHTING  
PANEL. ZIP (PART 1)



# AS 3000 — AS 3008 TABLE EXTRACT - ZIP

Pb (2)

DETERMINE THE MAXIMUM DEMAND OF THE HEAVIEST LOADED PHASE IN A DOMESTIC ELECTRICAL INSTALLATION COMPRISING:

- ✓ - 26 LIGHTING POINTS ————— BLUE
- ✓ - 24 x 10A SINGLE SOCKET OUTLET (15 IN WHITE, THE REMAINING IN BLUE)
- ✓ - 1 x 15A SOCKET OUTLET (WHITE)
- ✓ - 1 x 6.6 kW RANGE
- ✓ - 1 x 4 kW AIR CONDITIONING UNIT (RED)
- 1 x 12.96 kW INSTANTANEOUS WATER HEATER
- 1 x 3.6 kW CLOTH DRYER

AND ARRANGED FOR CONNECTION ACROSS A 3 $\phi$  SUPPLY AS FOLLOWS

RED	WHITE	BLUE
15A SOCKET OUTLET	15 x 10A SOCKET OUTLET	26 LIGHT
5 kW HOT PLATE	5 kW HOT PLATE	4 x 10A SOCKET OUTLET
4 kW AIR CON.	4.3 kW INSTANTANEOUS WATER HEATER	6.6 kW OVEN
4.3 kW INSTANTANEOUS WATER HEATER	3.6 kW CLOTH DRYER	4.3 kW INSTANTANEOUS WATER HEATER



EQUIPMENT	LOAD GROUP	COLUMN	RED	WHITE	BLUE
<u>LIGHTING</u>					
3A for 1-20 pt	A (1)	2			
2A for additional 20 pt					
3 + 2 = 5A					→ 5A
<u>24x 10A SOCKET OUTLET</u>	B (1)	2			
10A for first 20 pt				→ 10A	
REMAINING 9 pt					→ 10A
10A					
<u>RANGE</u>	C	2			
50% CONNECTED LOAD					
$0.5 \times \frac{5000}{240} = 10.4A$			10.4	10.4	
$0.5 \times \frac{6.6 \times 1000}{240} = 12.7A$					→ 12.7A
<u>15A SOCKET</u>	B (1)				
10A for first 20 pt				→ 10	

EQUIPMENT	LOAD GROUP	COLUMN	RED	WHITE	BLUE
4 kW AIR COND					
75% $0.75 \times \frac{4 \times 1000}{240} = 12.5A$	D	2			
			12.5A		
INSTANTANEOUS WATER HEATER					
33% $0.33 \times \frac{4.3 \times 10^3}{240} = 7.5A$			7.5	7.5	7.5
CLOTH DRYER 3.6 kW					
LAUNDRY					
50% LOAD $0.5 \times \frac{3.6 \times 10^3}{240} = 7.5$			7.5		
TOTAL			38.9A	33.9A	34.7A
HEAVIEST LOAD (RED) = 38.9A					

pb ③ DETERMINE THE MAXIMUM DEMAND OF THE HEAVIEST LOADED PHASE OF A BLOCK OF 80 UNITS COMPRISING THE FOLLOWING LOADS.

- ✓ LIGHTING - 80 UNITS
  - ✓ 10A SOCKET OUTLET - 80 UNITS
  - ✓ ELECTRIC RANGE - 17 UNITS
  - ✓ 2.5 kW (10.4 A) PERMANENT STRIP HEATER - 80 UNITS
  - ✓ QUICK RECOVERY WATER HEATER - 80 UNITS
- LOADING NOT ASSOCIATED

90 - 60W LIGHTING POINTS

21 - 100W LIGHTING POINTS

TOTAL LIGHTING = 7.5 kW

20 - 10A SINGLE SOCKET OUTLETS

10 - 3.6 kW CLOTH DRYERS

2 - 12 kW LIFT MOTOR

1 - 5.5 kW 3φ pump motor

1 - 4 kW 3φ water supply motor

$$\text{INDIVIDUAL UNITS/PHASE} = \frac{80}{3} = 27 \text{ UNIT}$$

$$\text{RANGE/PH} = \frac{17}{3} = 6$$

① INDIVIDUAL UNIT, REFER TABLE C1

EQUIPMENT	LOAD GROUP	COLUMN	CALCULATION	RESULT (Amp)
LIGHTING	A (1) 21 (OR) MORE x 0.5 Amp / UNIT 27 x 0.5	5	27 x 0.5	13.5 Amp
10A SOCKET OUTLET	B (1) 50A + 1.9 / x UNIT / UNIT	5	50 + 1.9 x 27	101.3 Amp
ELECTRIC RANGE	6 → 10 UNIT 2.8 A / UNIT x NO. OF UNIT	4	2.8 x 6	16.8 Amp.
STRIP HEATER	SPACE HEATING / 75% LOAD	5	$\frac{0.75 \times 2.5 \times 10^3}{240} \times 27$	210.6 Amp




EQUIPMENT	LOAD GROUP	COLUMN	CALCULATION	RESULT
WATER HEATER	STORAGE HEATER	5		
	21 UNITS OR MORE		$100 + 0.8 \times 27$	121.6 Amp
	$100A + 0.8A / \text{UNIT} \times \text{UNIT}$		TOTAL	463.8 Amp.
II Common Load	(H)	3/4/5	$\frac{7.5 \times 10^3}{240 \times 3}$	10.4 A
COMMUNAL LIGHTING	FULL LOAD			
10A SINGLE OUTLET	$\frac{20}{3} \approx 7 \times 1A / \text{UNIT}$	4	$1 \times 7$	7 A
3.6 kW CLOTH DRYER	J	3/4/5	$\frac{0.5 \times 3.6 \times 10^3 \times 4}{240}$	30 A
$\frac{10}{3} \approx 4$	50% OF LOAD			
LIFT MOTOR	TABLE C2	COL 3/4/5	$\frac{5.5 \times 10^3}{240} + \frac{0.5 \times 4 \times 10^3}{240}$	N/A
5.5 kW 3 $\phi$ Pump	HIGHEST + 50% OF REMAINING			14.6A
4 kW 3 $\phi$ WATER SUPPLY	-3 $\phi$		TOTAL	62A

$$\begin{aligned} \text{TOTAL CURRENT} / P_A &= 463.8 + 62 \\ &= \underline{\underline{525.8 \text{ Amp}}} \end{aligned}$$




## INSTALLATION AND RCD TESTING




- ① TURN OFF SUPPLY
- ② DISCONNECT THE MAIN EARTH AND MAIN NEUTRAL FROM NEUTRAL LINK
- ③ TEST EACH APPLIANCE INDIVIDUALLY.
- ④ TEST BETWEEN THE LOAD SIDE OF THE MAIN SWITCH AND THE MAIN EARTH AND BETWEEN NEUTRAL LINK AND MAIN EARTH
- ⑤ IF LOW READING IS OBTAINED, REMOVE FUSE (OR) SWITCH OFF CIRCUIT BREAKER, TEST AGAIN.

## ENERGY DEMAND METERING



THE ENERGY METER CONSISTS OF CURRENT COIL WHICH IS TO BE CONNECTED IN SERIES WITH THE CIRCUIT AND POTENTIAL COIL WHICH IS CONNECTED IN PARALLEL WITH THE CIRCUIT. THE MAGNETIZING FORCE PRODUCED BY TWO COILS ROTATES THE DISC

## CONNECTION OF ENERGY DEMAND METERS



$I_c$  - CT FOR ELEMENT 2

$I_m$  - CT FOR ELEMENT 1

V - VOLTAGE SENSOR

A - ACTIVE (125 AMP MAX)


N - NEUTRAL

$L_m$  - ELEMENT 1 LOAD (UNCONTROLLED)

$L_2$  - ELEMENT 2 LOAD (CONTROLLED)


ERS


SOCKET



AD


CONNECTING KWH METER TO SUPPLY








KWH meter connection for Hot Water,  
Lighting and Power











(b)



(c)



(d)



(e)

Fig. 14.6(b)-(e) (b) Type II two-pole RCD






Fig. 14.9(b) Wiring diagram of the control adaptor arrangement




Fig. 14.10 RCD calibration tester

GERARD INDUSTRIES

## 14.7 Installation arrangements for RCD protection

There are a number of installation arrangements for providing residual current protection. The factors governing these options are:

- the level of protection required by regulations;
- additional protection specified by the consumer;
- installation limitations; and
- overall cost.

The first three of these factors will be discussed here.

### Level of protection required by regulations

Residual current protection is mandatory for most GPOs in new domestic installations in Australia (Clause 4.14.9) and for socket outlets in medical treatment areas (AS 3003). As mentioned in section 14.4, RCD protection for socket outlets supplying equipment in damp situations is mandatory in New Zealand. The installation arrangements in medical treatment areas are fairly well defined in AS 3003, which specifies the location of RCDs for easy access and restricts the number of outlets connected to an RCD-protected circuit (see Chapter 19 for more details on areas in which electromedical equipment is used).

In a domestic installation, a number of options are available for the provision of RCD protection to GPO circuits. Installing an RCD-protected socket outlet (see Fig. 14.11) in place of a standard outlet will also provide earth-fault protection on all GPOs installed downstream from the device. Figure 14.12 shows this arrangement where a GPO is left unprotected for the connection of a refrigerator or food freezer, both of which are exempt from a mandatory requirement, while all other GPOs are protected. In an existing installation it will be necessary to determine the location of the first GPO on a circuit, as any GPOs or wiring upstream of the RCD will not be protected.

The other options in a domestic installation involve the installation of devices at the main switchboard, and include the following:

- *Four-pole RCD installed on the load side of the circuit protection devices* (as shown in Fig. 14.13). This arrangement is easy to install, particularly in existing installations, as little modification to the switchboard is required. However, this setup is limited to protected installations with two protected power circuits only; any additional power circuit installed at a later date will require an additional RCD, unless it is a dedicated circuit for a refrigerator or freezer. Also, a fault on either circuit will trip both circuits.

- *Two-pole RCD installed on the line side of the circuit protection devices* (as shown in Fig. 14.14). With this arrangement, although circuits can be added later, the








Fig. 14.9(a) Low-reading clamp ammeter used with a control adaptor to detect leakage current in an appliance

GERARD INDUSTRIES

## RESIDUAL CURRENT DEVICE (RCD)



THE RCD USES A TOROIDAL TRANSFORMER SIMILAR TO CURRENT TRANSFORMER TO DETECT EARTH LEAKAGE CURRENT. THE SECONDARY WINDING IS SENSING WINDING.

WHEN  $I_a$  &  $I_b$  ARE NOT EQUAL DUE TO LEAKAGE CURRENT, RCD TRIPS C.B.

## RCD CLASSIFICATION


TYPE <u>I</u>	RESIDUAL CURRENT NOT EXCEEDING 10mA
TYPE <u>II</u>	RESIDUAL CURRENT BETWEEN 10mA & 30mA
TYPE <u>III</u>	RESIDUAL CURRENT BETWEEN 30mA & 300mA
TYPE <u>IV</u>	TYPE <u>III</u> WITH SELECTIVE TRIPPING TIME DELAY

## PORTABLE RCD

CLASS L -	HOUSE HOLD / GENERAL USE
CLASS H -	GENERAL INDUSTRIAL USE



# TYPICAL INSTALLATION CIRCUIT ARRANGEMENT






## RCD CLASSIFICATION

TYPE <u>I</u>	RESIDUAL CURRENT NOT EXCEEDING 10mA
TYPE <u>II</u>	RESIDUAL CURRENT BETWEEN 10mA & 30mA
TYPE <u>III</u>	RESIDUAL CURRENT BETWEEN 30mA & 300mA
TYPE <u>IV</u>	TYPE <u>III</u> WITH SELECTIVE TRIPPING TIME DELAY

## PORTABLE RCD


CLASS L -	HOUSE HOLD / GENERAL USE
CLASS H -	GENERAL INDUSTRIAL USE

G008 / G008 GENERAL NOTE (2) PART (3)





kWh METER CONNECTION FOR HOT WATER,  
LIGHTING AND POWER

GOOG | METERING.ZIP



## RESIDUAL CURRENT DEVICE (RCD)



THE RCD USES A TOROIDAL TRANSFORMER SIMILAR TO CURRENT TRANSFORMER TO DETECT EARTH LEAKAGE CURRENT. THE SECONDARY WINDING IS SENSING WINDING.

WHEN  $I_a$  &  $I_b$  ARE NOT EQUAL DUE TO LEAKAGE CURRENT, RCD TRIPS C.B.

## RCD CLASSIFICATION

TYPE I	RESIDUAL CURRENT NOT EXCEEDING 10mA
TYPE II	RESIDUAL CURRENT BETWEEN 10mA & 30mA
TYPE III	RESIDUAL CURRENT BETWEEN 30mA & 300mA
TYPE IV	TYPE III WITH SELECTIVE TRIPPING TIME DELAY


## PORTABLE RCD

CLASS L -	HOUSE HOLD / GENERAL USE
CLASS H -	GENERAL INDUSTRIAL USE

GOOB / GOOB GENERAL NOTE (2) PART (3)



# TYPICAL INSTALLATION CIRCUIT ARRANGEMENT



NOT EXCEEDING 10mA

TWEEN 10mA & 30mA

EEN 30mA & 300mA

UE TRIPPING TIME

RAL USE

TRIAL USE

2) PART (3)



50)



# 

G008/ 9008 GENERAL NOTE(2) PART(2)

TEMPERATURE CONTROL → MANUAL SWITCHING  
→ AUTOMATIC



LOW



MEDIUM




HIGH



OFF

MANUAL CONTROL SWITCH



AUTOMATIC CONTROL

THERMOSTATIC CONTROL

SIMMERSTATIC (PROPORTIONAL ENERGY REGULATOR)  
CONTROL

CLASSIFICATION OF WATER HEATER

- INSTANTANEOUS
- STORAGE

THERMOSTAT

BOOST ELEMENT


THERMOSTAT

MAIN ELEMENT


BIMETAL


EXPANDING TUBE

VAPOUR PRESSURE




INK TUBE  
 R PRESSURE





AL  
 DING TUB  
 OR PRESSURE



# FIND THE CLAUSES RELATED TO

RCD

HOT WATER SYSTEM

WATER HEATER

RCD TESTING

RCD PROTECTED CIRCUIT