

SAFETY TESTING OF ELECTRICAL EQUIPMENTS


UENEE E033 B + UENEE E034 B

- THE SWITCHES MUST BE CONNECTED TO OPERATE IN THE ACTIVE CONDUCTORS
- SCREW LAMP HOLDER

ACTIVE FOR CENTRE TERMINAL

NEUTRAL FOR OUTER AND SCREW BASE

POLARITY OF SOCKET OUTLET



TEST METHOD

① TEST LAMP CONNECTED BETWEEN ACTIVE AND EARTH, 'SWITCH OFF'



NO GLOW (OR) INDICATES INFINITY OHM

② TEST LAMP CONNECTED BETWEEN ACTIVE AND EARTH, SWITCH ON


LAMP GLOWS (OR) INDICATE ZERO OHM

③ TEST LAMP CONNECTED BETWEEN NEUTRAL AND EARTH

SWITCHES CLOSED - NO GLOW (OR) INDICATES INFINITY OHM.




POLARITY TESTING OF
POWER OUTLETS




POLARITY TESTING OF LIGHTING CIRCUIT.

SIMPLE METHOD OF CHECKING THAT LIGHTS ARE IN ACTIVE CONDUCTORS.


IF LIGHT (OR) SWITCHES ARE CONNECTED IN NEUTRAL CONDUCTOR, ALTHOUGH THE LIGHT CAN BE SWITCHED ON / OFF, THE SWITCH CAN NOT BREAK THE CIRCUIT IN THE EVENT OF EMERGENCY.



SWITCH AND
LAMPS ARE
WRONGLY CONNECTED
IN NEUTRAL
CONDUCTION




TESTING THE EDISON
SCREW (ES) LAMP HOLDERS



TEMPORARY
BRIDGING CONNECTION
FOR TESTING

TWO WAYS SWITCH




ADAPTOR FOR
LAMP HOLDER

TEST PROBES
MAY BE USED
ON OTHER OUTLETS
SUCH AS
FLUORESCENT FITTINGS.

WHERE ACCESS TO SWITCH CONTACT IS
DIFFICULT, SPECIAL TEST LAMP MAY BE
USED.

POLARITY TESTING OF A NEW INSTALLATION (OR) INSTALLATION
ISOLATED FROM SUPPLY




PROCEDURE

- 1) REMOVE FUSE CARRIER AND THEN CONNECT TESTING DEVICE BETWEEN LOAD ACTIVE AND EARTH AT THE SUBCIRCUIT FUSE
- 2) INSERT SHORTING PLUG IN SOCKET OUTLET. TESTING DEVICE SHOULD INDICATE OPEN CIRCUIT.

(3) CLOSE SWITCH - A SHORT CIRCUIT SHOULD BE INDICATED BY THE TESTING DEVICE.

METHOD FOR REDUCING EFFECTIVE LENGTH OF TEST CIRCUIT



SWITCH ON - 0Ω

SWITCH OFF - $\infty \Omega$

PROCEDURE

- (1) DISCONNECT THE NEUTRAL LINE
- (2) CONNECT MAIN ACTIVE TERMINAL TO EARTH, ALL LAMPS MUST BE REMOVED.
- (3) TEST EACH SWITCH WITH OHM METER AS INDICATED IN CIRCUIT DIAGRAM


(4) SWITCH ON - OHM METER SHOWS ' 0 ' OHMS

SWITCH OFF - OHM METER SHOWS


∞ OHM

IF IT HAPPENS, THE POLARITY IS CORRECT.

TESTING THE POLARITY OF SOCKET OUTLET



A & E BRIDGED



TESTING WITH A SHORTING PLUG

TEST DEVICE INDICATES WHEN PLUG IS INSERTED AND SWITCH IS ON.


PROCEDURE

- (1) DISCONNECT NEUTRAL LINK. REMOVE FUSES
- (2) ONE PERSON HOLDS OHM METER WHICH TOUCHES MAIN ACTIVE AND EARTH
- (3) ANOTHER PERSON INSERTS SHORTING PLUG INTO ACTIVE AND EARTH TERMINALS HOLES OF EACH SOCKET OUTLET
- (4) SWITCH ON THE SOCKET OUTLET → OHM METER SHOWS '0' OHM
SWITCH OFF THE SOCKET OUTLET → OHM METER SHOWS '∞' OHM.

INSULATION RESISTANCE TEST


USE MEGGER TO TEST THE INSULATION RESISTANCE OF
CIRCUIT WIRING, ELECTRICAL EQUIPMENTS AND MACHINES.

MEGGER MUST INDICATE INFINITY.



INSULATION RESISTANCE

$\approx \infty \Omega$




EARTH RESISTANCE $\approx 50 \Omega$


EARTHING SYSTEMS

REASON FOR EARTHING

THE FAILURE OF INSULATION IMMEDIATELY INTRODUCES HAZARDS TO LIFE OR EQUIPMENT BY ELECTRIC SHOCK (OR) UNSTABLE VOLTAGE CONDITIONS.

THE EARTH LEAKAGE CURRENT MUST BE TAKEN AWAY BY EARTH WIRE.





IF THERE IS NO EARTH LEAKAGE, $I_1 = I_2$


IF THERE IS EARTH LEAKAGE CURRENT, $I_1 > I_2$,

THE RCD TRIPS OFF MAIN CIRCUIT BREAKER TO PROTECT THE EARTH LEAKAGE CURRENT.


THE SUPPLY CURRENT OF 20mA UNIT WILL BE SUFFICIENT TO CAUSE AN OUT OF BALANCE CONDITION IF THIS SUPPLY CURRENT IS NOT RETURNED TO NEUTRAL LINK THROUGH TOROID CORE

DISTRIBUTION SYSTEM PROTECTED BY EARTH LEAKAGE CIRCUIT BREAKER (E L CB)

DIRECT EARTHING SYSTEM



EARTH LEAKAGE CIRCUIT BREAKER SYSTEM



SIMPLE TEST PANEL FOR MEASURING CURRENT AND VOLTAGE OF AN APPLIANCE

