


# POWER SYSTEM CONTROL EQUIPMENTS



## MAIN FEEDER

Q1 THE FEEDER C  
WHERE THE S

## SECTIONALISING

Q1 THE ACT OF D  
THE CREATION  
APART

## RE-CLOSERS


Q1 AUTOMATIC  
THE POWER  
TROUBLE

## OPERATING U

THE



# SYSTEM CONTROL EQUIPMENTS



## MAIN FEEDER

Q1 THE FEEDER CABLE RUNS TO CROSS CONNECT POINT IN THE NETWORK WHERE THE SECOND FACILITY CABLE FEEDS ARE CONNECTED.

## SECTIONALISING

Q1 THE ACT OF DIVIDING OR PARTITIONING, SEPARATION BY THE CREATION OF A BOUNDARY THAT DIVIDES OR KEEPS APART

## RECLOSER

Q1 AUTOMATIC, HIGH VOLTAGE ELECTRIC SWITCH. IT SHUTS OFF THE POWER WHEN TROUBLE OCCURS. THEN RECLOSSES WHERE TROUBLE IS CLEAR OFF.

## OPERATING VOLTAGE

THE DESIGN VOLTAGE RANGE WITH TOLERANCE

## BOOSTER

TO

## BIL

## BIL

THE

LIGH

TO H

BIL

WITHS



Q1

BOOSTER

TO BOOST THE VOLTAGE LEVEL THAT FALLS UNDER DESIGNED LEVEL.

BIL (BASIC INSULATION LEVEL)

Q2 BIL IS BASIC INSULATION LEVEL (BASIC IMPULSE LEVEL) WHICH IMPLIES THE LIMIT UP TO WHICH AN INSULATOR COULD WITHSTAND IMPULSE DUE TO LIGHTNING STRIKES. IMPULSE IS GENERATED ON THE INSULATION DUE TO HIGH VOLTAGE SURGES AND SPIKES DUE TO LIGHTNING STRIKES. BIL IS GENERALLY MUCH HIGHER AS COMPARED TO POWER FREQUENCY WITHSTAND VOLTAGE.

SUBST

Q3

Power &  
CONTROL

- DISTRIBUTION TRANSFORMERS

- BOOSTER TRANSFORMERS

- VOLTAGE REGULATOR

- P.F. CORRECTOR

SUB

Q4

-

-

-


-

TRANSFORMER



## SUBSTATION EQUIPMENTS

Q3



Q4

## SUBSTATION OPERATION

- |                        |   |
|------------------------|---|
| - CONTROL / PROTECTION | - TESTING SECONDARY EQUIPMENTS              |
| - H.V SWITCH GEAR      | - RELAY / TRANSFORMERS CHARACTERISTICS TEST |
| - PROTECTION SETTING   | - REGULAR MAINTENANCE WORK                  |
| - BLACK OUT PLAN       |   |

Q5

## IMPORTANT

- TRANSFORMER

AIR CIRCUIT

POLARITY

TRANSFORMER

SURGE

INTERNAL

ELECTRIC

ARC



Q5

## IMPORTANT AUXILIARY SYSTEM

TRANSFORMER COOLING — TRANSFORMER OIL TESTING — FILTERING — FORCED OIL COOLING — FORCED AIR COOLING

AIR CIRCUIT BREAKING — AIR COMPRESSOR OPERATION — AIR PRESSURE — AIR RESERVOIR

POLARITY TESTING FOR PARALLEL OPERATION OF TRANSFORMERS.

SURGE (OR) LIGHTNING ARRESTER — DISCHARGING THE HIGH VOLTAGE SPIKES TO GROUND.

INTERRUPT CONTROL CIRCUIT — STORAGE CIRCUIT FOR STORING AND OUTPUTTING A REFERENCE TIME FOR ERROR DETECTING CIRCUIT.

## ELECTRIC ARC EXTINGUISHING

ARC → RADIATION, IONIZING  
HIGH TEMPERATURE  
ELECTRON COLLISION

← ARC INTERRUPTION

HIGH RESISTANCE METHOD

COOLING ARC

REDUCING C.S.A OF ARC

SPLITTING ARC

DE IONIZING

LENGTHENING GAP

HIGH PRESSURE

Q1

SKETCH THE

EXPLAIN T

(a) MAIN FEEDER (b)

(c) BOOSTER

Q2

WHAT IS

Q3

SKETCH THE O

Q4

WHAT ARE FUNCTIONS?

Q5

WHAT ARE

IN SUB



TING | FORCED OIL COOLING  
FORCED AIR COOLING

Q1 SKETCH THE OVER VIEW OF SUBSTATION AND  
EXPLAIN THE FOLLOWINGS

(a) MAIN FEEDER (b) SECTIONALIZING (c) RE-CLOSER (d) OPERATING  
VOLTAGE

(e) BOOSTER

Q2 WHAT IS BIL?

Q3 SKETCH THE OUT LINES OF SUBSTATION EQUIPMENTS

Q4 WHAT ARE THE MAIN ASPECTS OF SUBSTATION OPERATION  
FUNCTIONS?

Q5 WHAT ARE THE IMPORTANT AUXILIARY SYSTEMS  
IN SUBSTATION AND EXPLAIN ANY THREE OF THEM.

tion ← { HIGH RESISTANCE  
METHOD  
COOLING ARC  
REDUCING C.S.A OF ARC  
SPLITTING ARC  
DE IONIZING — LENGTHENING GAP  
HIGH PRESSURE



## SUBSTATION GROUNDING

### GROUND RESISTANCE

THE RESISTANCE SEEN BY THE GROUNDING CONDUCTOR OF AN ELECTRICAL SYSTEM

### SOIL RESISTIVITY

A FUNCTION OF SOIL MOISTURE AND THE CONCENTRATION OF IONIC SOLUBLE SALTS AND IS CONSIDERED TO BE MOST COMPREHENSIVE INDICATOR OF A SOIL CORROSIVITY.

THE LOWER THE RESISTIVITY, THE HIGHER THE CORROSIVITY

SOIL RESISTIVITY ( $\Omega\text{-cm}$ )	CORROSIVITY RATING	SOIL RESISTIVITY ( $\Omega\text{-cm}$ )	CORROSIVITY RATING
$> 20,000$	ESSENTIALLY NON CORROSIVE	$< 1000$	EXTREMELY CORROSIVE
10,000 TO 20,000	MILDLY CORROSIVE		
5000 TO 10,000	MODERATELY CORROSIVE		
3000 TO 5000	CORROSIVE		
1000 TO 3000	HIGHLY CORROSIVE		

6044 PRA  
5 → 7 TH  
30 BAL  
30 POWER



9 PRACTICAL  
THURSDAY  
BALANCED  
POWER

Q7

## Types of protection utilized in sub station

ELECTRIC RACEWAYS → TO SAVE THE VITAL CABLE NETWORK FROM CORROSION & DESTRUCTION

SUB STATION GROUNDING → LIGHTNING / SURGE PROTECTION

VOLTAGE REGULATOR → TO MAINTAIN CONSTANT VOLTAGE LEVEL

CIRCUIT BREAKER → TO INTERRUPT THE CIRCUIT

INSTRUMENT TRANSFORMER → POTENTIAL TRANSFORMER (PT)  
CURRENT TRANSFORMER (CT)

TO REDUCE SYSTEM VOLTAGE / CURRENT

RELAYING → DIFFERENTIAL - TRANSFORMER PROTECTION

PILOT PROTECTION

VOLTAGE SURGE DIVERTER

MICROWAVE RELAYING

STABILITY CONTROL

UTILIZES HIGH  
VOLTAGE DIRECT  
CURRENT  
FOR TRIP CIRCUIT


CIRCUIT BREAKER → OIL CIRCUIT BREAKER

AIR CIRCUIT BREAKER

VACUUM INTERRUPTER

FUSE

SF<sub>6</sub>-CB





Q 8

### WIDE AREA MONITORING & CONTROL SYSTEM

- EMERGENCY OPERATION FUNCTION
- LOCATE THE FAULT
- VERIFY THAT PROTECTION HAS OPERATED CORRECTLY TO CORRECT THE FAULT
- SHED THE LOAD TO ENSURE THAT FAULT DOES NOT CAUSE AN OVERLOAD OF AN AFFECTED LINES
- MANUALLY RE-ROUTE POWER TO RESTORE SERVICE TO SUBSCRIBERS
- DISPATCH CREWS AND EMERGENCY TEAM TO FIX THE FAULT
- CAPTURE FAULT RECORDINGS SO THE ENGINEERS CAN LATER ANALYZE THE CAUSE OF THE FAULT.

Q 6 How DOES SOIL RESISTIVITY AFFECT THE CORROSION?

Q 7 WHAT ARE THE TYPES OF PROTECTION UTILIZED IN SUBSTATION?

Q 8 EXPLAIN WIDE AREA MONITORING & CONTROL SYSTEM

Q 5

IMPORTANT

- TRANSFORMER

AIR CIRCUIT

POLARITY TO TRANSFORMER

SURGE (OR HIGH)

INTERFERENCE

ELECTRIC

ARC