

POWER SYSTEM PROTECTION

THE PROTECTION OF ELECTRICAL POWER SYSTEMS FROM FAULTS THROUGH THE ISOLATION OF FAULTY PARTS FROM THE REST OF THE ELECTRICAL NETWORK.

THE OBJECTIVE OF PROTECTION SCHEME IS TO KEEP THE POWER SYSTEM STABILITY BY ISOLATING ONLY THE COMPONENTS THAT ARE UNDER FAULT, WHILST LEAVING AS MUCH OF THE NETWORK AS POSSIBLE STILL IN OPERATION.


COMPONENTS OF POWER SYSTEM PROTECTION SCHEME

SMALL POWER SYSTEM \rightarrow FUSE

MEDIUM (OR) LARGE POWER SYSTEM \rightarrow PROTECTIVE RELAY + CIRCUIT BREAKER

AUTOMATIC LINE SECTIONALIZER

AUTOMATIC SWITCH WITH A SELF CONTAINED CIRCUIT OPENING DEVICE THAT AUTOMATICALLY OPENS THE MAIN ELECTRICAL CIRCUIT AFTER SENSING AND RESPONDING TO A PRE-DETERMINED NUMBER OF SUCCESSIVE MAIN CURRENT IMPULSES.



RE-CLOSER

AN AUTOM
THE LINE
CONDITION.
THE LINE

BIL

BASIC INSU
A REFERE
OF THE IN

SUB STATION

PROTECTION

OVER CUR
REVERSE
VOLTAGE LE

STEP DOWN
EARTHING

EARTHING

FAULTS THROUGH THE ISOLATION
ELECTRICAL NETWORK.


KEEP THE POWER SYSTEM STABILITY
ARE UNDER FAULT, WHILST
STILL IN OPERATION.

ME

OVERCURRENT RELAY + CIRCUIT BREAKER

DESIGNATED CIRCUIT OPENING DEVICE
MAIN ELECTRICAL CIRCUIT AFTER
- DETERMINED NUMBER OF

ES.



RE-CLOSER

AN AUTOMATIC HIGH VOLTAGE ELECTRIC SWITCH. IT TRIES TO RE-CLOSE
THE LINE FOR FOUR OR FIVE TIMES UNDER TEMPORARY FAULT
CONDITION. WHEN THE FAULT IS PERMANENT, IT WILL ISOLATE
THE LINE PERMANENTLY.

BIL

BASIC INSULATION LEVEL.

A REFERENCE INSULATION LEVEL THAT MEASURES THE ABILITY
OF THE INSULATION TO WITHSTAND VERY HIGH VOLTAGE SURGES.

SUBSTATION EQUIPMENTS

PROTECTION

OVERCURRENT RELAY, DIFFERENTIAL RELAY

REVERSE POWER RELAY

VOLTAGE LEVEL CHANGE

STEP DOWN POWER TRANSFORMERS


EARTHING

EARTHING TRANSFORMERS

POWER FACTOR IMPROVEMENT

FREE RUNNING SYNCHRONOUS
POWER FACTOR OF THE WH

OVERCURRENT RELAY



RIC SWITCH. IT TRIES TO RE-CLOSE
TIMES UNDER TEMPORARY FAULT
PERMANENT, IT WILL ISOLATE

THAT MEASURES THE ABILITY
D VERY HIGH VOLTAGE SURGES.


ENTIAL RELAY

RMERS


POWER FACTOR IMPROVEMENT

FREE RUNNING SYNCHRONOUS MOTORS TO IMPROVE THE
POWER FACTOR OF THE WHOLE SYSTEM.

OVER CURRENT RELAY



DISTANCE RE




CT-
PT-

OPERATION
RESTRAINT

NORMAL

FAULT

DISTANCE RELAY



CT - CURRENT TRANSFORMER
PT - POTENTIAL TRANSFORMER

LINE PROTECTION

OPERATING COIL FLUX \propto LINE CURRENT

RESTRAINING COIL FLUX \propto LINE VOLTAGE

NORMAL LINE VOLTAGE IS HIGH
LINE CURRENT IS LOW


$$\text{LINE IMPEDANCE} = \frac{\text{LINE VOLTAGE}}{\text{LINE CURRENT}}$$

FAULT LINE VOLTAGE IS LOW
LINE CURRENT IS HIGH


LINE IMPEDANCE IS LOW

$$\phi_{\text{OPERATING}} > \phi_{\text{RESTRAINING}}$$

DIFFERENTIAL RELAY



DIFFERENTIAL PROTECTION
MAIN POWER TRANSFORMER



LINE PROTECTION

TRANSFORMER
TRANSFORMER

\propto LINE CURRENT

\propto LINE VOLTAGE

VOLTAGE IS HIGH
CURRENT IS LOW


$$\text{LINE IMPEDANCE} = \frac{\text{LINE VOLTAGE}}{\text{LINE CURRENT}}$$

VOLTAGE IS LOW
CURRENT IS HIGH

LINE IMPEDANCE IS LOW

$$\phi_{\text{OPERATING}} > \phi_{\text{RESTRAINING}}$$

DIFFERENTIAL RELAY



DIFFERENTIAL PROTECTION FOR
MAIN POWER TRANSFORMER

SUPERVISING

EQUIPMENTS FOR

- TRANSMISSION LINE
ARE UTILIZED.

- DISTRIBUTION

(OR) WOODEN

INSULATORS

PIN INSULA


DIS INSULA

INSULATOR ST

POLE STRENGTH

WIND FORCE

CONDUCTOR



LINE PROTECTION

LINE TRANSFORMER
TIAL TRANSFORMER

FLUX \propto LINE CURRENT

COIL FLUX \propto LINE VOLTAGE

LINE VOLTAGE IS HIGH
LINE CURRENT IS LOW


$$\text{LINE IMPEDANCE} = \frac{\text{LINE VOLTAGE}}{\text{LINE CURRENT}}$$

LINE VOLTAGE IS LOW
LINE CURRENT IS HIGH

LINE IMPEDANCE IS LOW

$$\phi_{\text{OPERATING}} > \phi_{\text{RESTRAINING}}$$

DIFFERENTIAL RELAY



DIFFERENTIAL PROTECTION FOR
MAIN POWER TRANSFORMER

SUPERVISING TRIP

EQUIPMENTS FOR LINE

TRANSMISSION LINES
ARE UTILIZED.

DISTRIBUTION LINES

(OR) WOODEN POLES

INSULATORS

PIN INSULATOR

DIS INSULATOR



INSULATOR STR

POLE STRENGTH

WIND FORCE

CONDUCTOR,

RELAY



PROTECTION FOR
TRANSFORMER



SUPERVISING TRIP SIGNAL TRAVELS OVER TELECOM: LINE

EQUIPMENTS FOR LINE CONSTRUCTION

- TRANSMISSION LINES (132 kV, 230 kV, 330 kV, 500 kV), STEEL TOWERS ARE UTILIZED.
- DISTRIBUTION LINES (66 kV, 33 kV, 11 kV, 415 V), CONCRETE POLE (OR) WOODEN POLE (OR) STEEL POLES ARE UTILIZED.

INSULATORS

PIN INSULATOR (415 V)

DIS INSULATOR (11 kV, 33 kV)

INSULATOR STRING (TRANSMISSION LEVEL VOLTAGE
132 kV, 230 kV, 330 kV, 500 kV)

POLE STRENGTH

WIND FORCE, CONDUCTOR WEIGHT, TENSIONS IN
CONDUCTOR, LINE DEVIATION.

DISTRIBUTION TRANSFORMER

ANY TRANSFORMER RATED
INCLUSIVE WITH A PRIMARY
GREATER. A TRANSFORMER
RELATIVELY SMALL AMOUNT
IT IS USED AT THE END OF
DELIVERY SYSTEM. OFTEN

UNDER GROUND TRANSFORMER

IN BUILDINGS CONSISTING
MONO BLOCK STRUCTURE
UNDER GROUND INSTALLATION
DIFFERENT TYPES OF E
CONFIGURATIONS.

TRIP SIGNAL TRAVELS OVER TELECOM: LINE

REQUIREMENTS FOR LINE CONSTRUCTION

TRANSMISSION LINES (132 kV, 230 kV, 330 kV, 500 kV), STEEL TOWERS ARE UTILIZED.

DISTRIBUTION LINES (66 kV, 33 kV, 11 kV, 415 V), CONCRETE POLE

WOODEN POLE (OR) STEEL POLES ARE UTILIZED.

TOWERS

INSULATOR (415 V)

INSULATOR (11 kV, 33 kV)

INSULATOR STRING (TRANSMISSION LEVEL VOLTAGE
132 kV, 230 kV, 330 kV, 500 kV)

STRENGTH

WIND FORCE, CONDUCTOR WEIGHT, TENSIONS IN

CONDUCTOR, LINE DEVIATION.

DISTRIBUTION TRANSFORMER

ANY TRANSFORMER RATED BETWEEN 3 AND 500 KVA INCLUSIVE WITH A PRIMARY VOLTAGE OF 0.6 KV OR GREATER. A TRANSFORMER USED TO SUPPLY RELATIVELY SMALL AMOUNT OF POWER TO RESIDENCES. IT IS USED AT THE END OF ELECTRICAL UTILITY'S DELIVERY SYSTEM. OFTEN MOUNTED ON POLE.

UNDER GROUND TRANSFORMER


IN BUILDINGS CONSISTING OF A REINFORCED CONCRETE MONOBLOCK STRUCTURE ENCLOSURE, DESIGNED FOR UNDER GROUND INSTALLATION, WHICH CAN HOUSE DIFFERENT TYPES OF ELECTRICAL DISTRIBUTION CONFIGURATIONS.

RATING

HT (HIGH TENSION) SUBSTATION MEANS IF SUBSTATION IS SUPPLYING POWER TO ANOTHER SUBSTATION IS CALLED H.T SUBSTATION (500 KV, 330 KV, 230 KV, 132 KV, 66 KV)

LT (LOW TENSION) SUBSTATION MEANS IF SUBSTATION IS SUPPLYING POWER TO DOMESTIC AND INDUSTRIAL USAGE (66 KV, 33 KV, 11 KV, 415 V)

SURGE (OR) LIGHTNING ARRESTER



SURGE ARRESTER (OR) LIGHTNING ARRESTER DISCHARGE THE OVER VOLTAGE SURGES TO EARTH AND PROTECT THE EQUIPMENT INSULATION FROM SWITCHING SURGES AND LIGHTNING SURGES. IN A SUBSTATION, SURGE ARRESTER IS LOCATED AT THE STARTING OF THE SUBSTATION

AS SEEN IN
EQUIPMENT

SUB STA

REVENUE

THE FUN

TO PRO

ACCEPTED

OF OPER

PROTECTION

MEASURES

POWER

THE

AND

DEMAND

IN

APPLYING POWER TO ANOTHER
30 kV, 230 kV, 132 kV, 66 kV)
IS SUPPLYING POWER TO
11 kV, 415 V)

DISCHARGE THE OVER VOLTAGE
EQUIPMENT INSULATION FROM
ES. IN A SUBSTATION, SURGE
OF THE SUBSTATION

AS SEEN FROM INCOMING TRANSMISSION LINE AND IS THE FIRST
EQUIPMENT OF SUBSTATION.

SUBSTATION EQUIPMENTS (ECONOMIC ASPECT)

REVENUE METER

THE FUNDAMENTAL FUNCTIONS OF A REVENUE METER ARE
TO PROVIDE MEASUREMENTS THAT ARE WITHIN INDUSTRY
ACCEPTED LIMITS FOR ACCURACY OVER A DEFINED RANGE
OF OPERATING CONDITIONS AND TO PROVIDE ADEQUATE
PROTECTION AGAINST UNAUTHORIZED ALTERATION OF THESE
MEASURED QUANTITIES.

POWER FACTOR

THE RELATIONSHIP BETWEEN WORKING (ACTIVE) POWER
AND TOTAL POWER CONSUMED (APPARENT POWER).


DEMAND CONTROL

MAXIMUM DEMAND CONTROL.

ELECTRONIC METERING

POWER & ENERGY

PROTECTIVE



AIR CIRCUIT BREAKER

- COMPRISE ONE (OR)
- WHEN THE ELECTRIC
IT IS EXTINGUISH

IF OIL IS UTILIZED

IMPORTANT FACTORS

POLARITY, BUSHING

NE AND IS THE FIRST

ASPECT)

REVENUE METER ARE
ARE WITHIN INDUSTRY
A DEFINED RANGE
PROVIDE ADEQUATE
ALTERATION OF THESE


WORKING (ACTIVE) POWER
(APPARENT POWER).

OL.

ELECTRONIC METERING

POWER & ENERGY METER

PROTECTIVE SWITCH GEARS



AIR CIRCUIT BREAKER

- COMPRISE ONE (OR) MORE FIXED CONTACTS AND MOVING CONTACTS.
- WHEN THE ELECTRIC ARC OCCURS BETWEEN FIXED AND MOVING CONTACTS, IT IS EXTINGUISHED WITH AIR

IF OIL IS UTILIZED TO COOL THE ARC, IT WILL BE OIL CIRCUIT BREAKER

IMPORTANT FACTORS

POLARITY, BUSHING, OIL (TRANSFORMER INSULATING OIL), COOLING

IONISING PROCESS

RADIATION (OR) ION
WHICH ARE OF SHORT

THE ELECTRIC ARC
EXTINGUISHED A

THE CIRCUIT BREAKER

ARC INTERRUPTION

① HIGH RESISTANCE

ARC RESISTANCE

② LOW RESISTANCE

IONISING PROCESS

RADIATION (OR) IONIZING CONSISTS OF PARTICLES OR ELECTROMAGNETIC WAVES WHICH ARE OF SHORT WAVE LENGTHS.

THE ELECTRIC ARC NEEDS TO BE ELONGATED, CUT, SPLIT AND EXTINGUISHED AFTER SOLID ARC BECOMES SPLIT ARC PARTICLES.

THE CIRCUIT BREAKER MUST PERFORM SUCH FUNCTIONS.

$$R = \frac{\rho L}{A}$$

ARC INTERRUPTION

- ① HIGH RESISTANCE METHOD → ARC RESISTANCE IS MADE TO INCREASE WITH TIME SO THAT THE CURRENT BECOMES INSUFFICIENT TO MAINTAIN THE ARC.

ARC RESISTANCE CAN BE INCREASED BY


- (i) LENGTHENING THE ARC
- (ii) COILING THE ARC
- (iii) REDUCING THE CROSS SECTION OF THE ARC
- (iv) SPLITTING THE ARC.

- ② LOW RESISTANCE METHOD - USED FOR AC CIRCUIT ONLY.

DE IONISATION CAN BE ACHIEVED BY


- (i) LENGTHENING THE GAP
- (ii) HIGH PRESSURE
- (iii) COOLING
- (iv) BLAST EFFECT.

OIL CIRCUIT BREAKER



WHEN FIXED CONTACT AND MOVING CONTACT ARE SEPARATED, THE ELECTRIC ARC OCCURS. THE ELECTRIC ARC IS SPLITTED BY ARC SPLITTERS AND EXTINGUISHED BY OIL.


DIAGRAM OF CURRENT LIMITING FUSE



MONITORING AND CONTROL INSTRUMENTS

- SMOKE DETECTOR
- HEATING REGULATORS
- THERMOSTATS
- MEASURING, WEIGHING (OR) ADJUSTING APPLIANCES FOR HOUSE HOLD (OR) AS LABORATORY EQUIPMENT
- OTHER MONITORING AND CONTROL INSTRUMENTS USED IN INDUSTRIAL INSTALLATIONS

CURRENT LIMITING FUSE



CONTROL INSTRUMENTS

CTOR

REGULATORS

FTS

WEIGHING (OR) ADJUSTING
FOR HOUSE HOLD (OR) AS

EQUIPMENT

ITORING AND CONTROL INSTRUMENTS

INDUSTRIAL INSTALLATIONS


(E.g. CONTROL PANELS)

VOLTAGE REGULATOR

IT IS AN ELECTRICAL REGULATOR DESIGNED TO AUTOMATICALLY MAINTAIN A CONSTANT VOLTAGE LEVEL. A VOLTAGE REGULATOR MAY BE A SIMPLE FEED FORWARD DESIGN (OR) MAY INCLUDE NEGATIVE FEED BACK CONTROL LOOPS.

ELECTRONIC VOLTAGE REGULATORS ARE UTILIZED TO PROVIDE THE STABLE DC VOLTAGE FOR COMPUTERS, PROCESSORS & OTHER ELEMENTS.

INSTRUMENT TRANSFORMERS



CL - CURRENT
COIL

PC - POTENTIAL
COIL

INSTRUMENT TRANSFORMERS

TO PROVIDE (i)
(ii)

OPERATION

AIR BREAK CIRCUIT

THE ARC IS EXTINGUISHED
AND 150 ms
TRIPPED.


OIL CIRCUIT BREAKER

DURING OF A

VACUUM INTERRUPTER

IT PROVIDES SELF
ELECTRONICALLY
PROTECTION IN
CONSTRUCTION.

CURRENT LIMITING FUSE



AND CONTROL INSTRUMENTS

DETECTOR
REGULATORS
STATS
g, WEIGHING (OR) ADJUSTING
ES FOR HOUSE HOLD (OR) AS
TORY EQUIPMENT
MONITORING AND CONTROL INSTRUMENTS
N INDUSTRIAL INSTALLATIONS


(E.g. CONTROL PANELS)

VOLTAGE REGULATOR

IT IS AN ELECTRICAL REGULATOR DESIGNED TO AUTOMATICALLY MAINTAIN A CONSTANT VOLTAGE LEVEL. A VOLTAGE REGULATOR MAY BE A SIMPLE FEED FORWARD DESIGN (OR) MAY INCLUDE NEGATIVE FEED BACK CONTROL LOOPS.

ELECTRONIC VOLTAGE REGULATORS ARE UTILIZED TO PROVIDE THE STABLE DC VOLTAGE FOR COMPUTERS, PROCESSORS & OTHER ELEMENTS.

INSTRUMENT TRANSFORMERS



CC - CURRENT COIL
PC - POTENTIAL COIL

INSTRUMENT TO
TO PROVIDE

OPERATE

AIR BREAK CIRCUIT

THE ARC
AND ISOLATION
TRIPPED

OIL CIRCUIT

DURING O

VACUUM

IT PROVIDES

ELECTRONIC

PROTECTION

CONSTRUCT

INSTRUMENT TRANSFORMERS ARE USED IN POWER SYSTEM TO PROVIDE

- (i) REDUCED VOLTAGE FOR VOLTMETER
- (ii) REDUCED CURRENT FOR AM METER.

OPERATION SPEEDS OF CIRCUIT BREAKERS

AIR BREAK CIRCUIT BREAKER

THE ARC IS EXTINGUISHED BETWEEN 30 ms AND 150 ms AFTER THE MECHANISM HAS BEEN TRIPPED.

OIL CIRCUIT BREAKER

DURING OF ARCING IS 0.02 TO 0.05 SEC.

VACUUM INTERRUPTER

IT PROVIDES SINGLE (OR) 3 PHASE. ELECTRONICALLY CONTROLLED OVER CURRENT PROTECTION IN A DEAD FRONT, SUBMERSIBLE CONSTRUCTION.

THE NEED FOR ELECTRICAL PROTECTION

THE PROTECTION OF A POWER SYSTEM DETECTS THE ABNORMAL CONDITIONS, LOCALIZES THE FAULTS AND PROMPTLY REMOVE THE FAULTY EQUIPMENTS FROM SERVICE.

ESTIMATION OF OPERATION SPEED OF PROTECTION EQUIPMENTS, DETERMINATION OF POSSIBLE ELECTRICAL FAULT LEVEL AND PROVIDING THE APPROPRIATE SIZE OF CIRCUIT BREAKER + RELAY PROTECTION SYSTEM ARE THE IMPORTANT ASPECTS OF POWER SYSTEM PROTECTION.

OVERVIEW OF ELECTRICAL FAULTS

ELECTRICAL FAULTS USUALLY OCCUR DUE TO BREAK DOWN OF THE INSULATION MEDIA BETWEEN LIVE CONDUCTORS (OR) A LIVE CONDUCTOR AND EARTH.

THE BREAK DOWN MAY BE CAUSED BY ANY ONE (OR) MORE OF SEVERAL FACTORS : MECHANICAL DAMAGE, OVER HEATING, VOLTAGE SURGE, IONIZING AIR, DEGRADING INSULATION MEDIA.

ELECTRIC POWER UTILITIES ARE FACED WITH AGING INFRASTRUCTURE, INCREASING RISK OF BLACK OUTS AND BLOWN OUTS CAUSING UNPLANNED MAINTENANCE AND SECURITY THREATS.

THE IN FRED CAMERAS ARE UTILIZED TO CHECK THE SITUATION OF THE INSULATION OF ELECTRICAL MACHINES AND EQUIPMENTS SO THAT THE PREVENTIVE MAINTENANCE CAN BE DONE BEFORE THE EQUIPMENTS ARE TOTALLY BROKEN DOWN.

PROTECTION SYSTEM

- PILOT WIRE PROTECTION SYSTEM
- MICROWAVE RELAYING
- WIDE AREA MONITORING AND CONTROL SYSTEM

EMERGENCY OPERATION FUNCTION IS TO PROVIDE THE COMMUNICATION SERVICES PERMITTING AN OPERATOR TO TAKE THE FOLLOWING ACTIONS IN RESPONSE TO A FAULT IN THE POWER SYSTEM

- LOCATE THE FAULT
- VERIFY THAT CLEAR THE FAULT
- SHED LOAD TO PREVENT OF UNAFFE
- MANUALLY
- DISPATCH
- CAPTURE THE CAUSE

IN INFRASTRUCTURE, INCREASING
AND PLANNED MAINTENANCE

THE SITUATION OF
EQUIPMENTS SO THAT
THE EQUIPMENTS

TEAM
PROVIDE THE COMMUNICATION
AND TAKE THE FOLLOWING
THE POWER SYSTEM

- LOCATE THE FAULT
- VERIFY THAT PROTECTION HAS OPERATED CORRECTLY TO CLEAR THE FAULT
- SHED LOAD TO ENSURE THAT FAULT DOES NOT CAUSE AN OVER LOAD OF UN AFFECTED LINES
- MANUALLY RE-ROUTE POWER TO RESTORE SERVICE TO CONSUMERS
- DISPATCH CREWS AND EMERGENCY TEAM TO FIX THE FAULT.
- CAPTURE FAULT RECORDINGS SO ENGINEERS CAN LATER ANALYZE THE CAUSE OF THE FAULT.