




POWER LINE EARTHING

OBJECTIVE OF SITE EARTHING


- TO AVOID PHYSICAL DAMAGE TO BUILDINGS AND EQUIPMENTS DUE TO DIRECT (OR) INDIRECT LIGHTNING STRIKE
- TO PROVIDE A SAFE WORKING ENVIRONMENT FOR PERSONNELS DURING LIGHTNING STRIKE
- TO PROVIDE SHIELDING AND ALTERNATIVE PATH FOR INDUCED CURRENT
- TO PROVIDE EQUIPOTENTIAL PLATFORM FOR ELECTRONIC EQUIPMENTS.

CATEGORIES OF EARTHING

- NEUTRAL EARTHING
- SAFETY EARTHING
- SIGNAL REFERENCE CONDUCTOR EARTHING
- SCREEN REFERENCE EARTHING.



THING




CIRCUIT


CIRCUITS

NEUTRAL LINE
EARTH BAR


CONCENTRIC CABLE
COAXIAL CABLE



SIGNAL REFERENCE CONDUCTOR EARTHING




TWO SEPARATELY EARTHING




TWO SEPARATELY EARTHED
BUILDINGS A & B WITH
CABLE CONNECTION

EARTH RESISTANCE MUST
BE LOW ENOUGH TO CARRY
THE LEAKAGE CURRENT



R EARTHING



TWO SEPARATELY EARTHED BUILDINGS A & B WITH CABLE CONNECTION.

EARTH RESISTANCE MUST BE LOW ENOUGH TO CARRY THE LEAKAGE CURRENT


- EARTH IN ROAD MATERIAL
- SOIL RESISTIVITY
- TYPE OF SOIL
- MOISTURE CONTENT.


ARTIFICIAL EARTHING EARTHING MESH } TO REDUCE EARTH RESISTANCE




DRIVE EARTH ELECTRODES

BONDING OF EARTH ELECT TO OTHER COMPONENTS







BONDING OF EARTH ELECTRODES TO OTHER COMPONENTS



TO REDUCE EARTH RESISTANCE



BONDING OF CONDUIT CABLE & CABLE ARMOURING



STRENGTH of 30 kV/cm
BREAK DOWN WILL OCCUR.

004

5 pF

2000

33 kV

$$\times \frac{200 - 6.32 \times 10^3}{200 + 6.32 \times 10^3}$$

$$\times \frac{(-6120)}{6520} = -30.9$$

$$+ 30.9 = 63.9 \text{ kV}$$

$$Z_c = \sqrt{\frac{200}{5 \times 10^{-6}}}$$

$$= \sqrt{40 \times 10^6}$$

$$= 6.32 \times 10^3$$

ELECTRICAL INSULATION


Types of INSULATIONS

OIL IMPREGNATED PAPER, VARNISHED, CARBIC,
POLYETHYLENE.

THE TRANSMISSION SYSTEM INSULATORS SUFFER

(1) ELECTRICAL STRESS (2) MECHANICAL STRESS.

INSULATOR DIELECTRIC BEHAVIOUR




$$E = \frac{V}{t}$$

V/cm
ELECTRIC
STRESS

V = VOLTAGE
t = THICKNESS OF INSULATION

- CAPACITANCE EFFECT
- LEAKAGE CURRENT
- ELECTRIC FIELD
- SURFACE LEAKAGE CURRENT



ELECTRICAL
STRESS

THE INSULATOR MUST HAVE CAPABILITY
TO WITHSTAND THE PUNCTURE STRENGTH.


TESTING INSULATOR

INSULATION BREAK DOWN REQUIRES THE ENERGY TO BE DELIVERED FROM THE VOLTAGE SOURCE TO INSULATION VOLUME.

IT NEEDS TO NOTE THE FOLLOWINGS:-

- TIME REQUIRED FOR BREAK DOWN

< IN THIS CASE, THE LOWER THE APPLIED VOLTAGE, THE MORE SLOWLY DOES THE BREAK DOWN PROCESS PROCEEDS AND THE LONGER THE TIME TO REACH THE BREAKDOWN POINT >




CHARACTERISTICS OF INSULATING MATERIAL

MATERIAL	RESISTIVITY	PUNCTURE STRENGTH V/cm	RELATIVE PERMITTIVITY
GLASS	2×10^{17}	$(0.5 \rightarrow 3) \times 10^4$	$5.4 \rightarrow 9.9$
MICA	2×10^{17}	$(3.5 \rightarrow 7) \times 10^4$	$2.5 \rightarrow 4.5$


SOURCE OF OVER VOLTAGE

I LIGHTNING




BIL — BASIC INSULATION LEVEL

— CAPABILITY TO WITHSTAND THE TRANSIENT OVER VOLTAGE




II SWITCHING TRANSIENT




III

CONTACT WITH THE CIRCUIT WITH HIGHER VOLTAGE



TRAVELLING WAVE



THE RETURN / REFLECTION COMPONENT OF THE STRIKING TRAVELLING WAVE CAN BE HIGHER THAN THE ORIGINAL STRIKING WAVE MAGNITUDE.

TRANSMISSION LINE NEEDS TO WITHSTAND TRANSIENT OVER VOLTAGE

V_i = ORIGINAL WAVE

V = REFLECTED WAVE

R = LINE RESISTANCE


Z_c = CHARACTERISTICS IMPEDANCE

$$= \sqrt{\frac{L}{C}}$$

$$V = V_i \frac{R - Z_c}{R + Z_c}$$

WHEN THE EXCEEDS,

LIGHTING ARRESTER IS UTILIZED TO ABSORB THE TRANSIENT OVER VOLTAGE



$$\therefore V_T = V +$$

TRANSMISSION LINE NEEDS TO WITHSTAND TRANSIENT OVER VOLTAGE

V_i = ORIGINAL WAVE

V = REFLECTED WAVE


R = LINE RESISTANCE

Z_c = CHARACTERISTICS IMPEDANCE

$$= \sqrt{\frac{L}{C}}$$

$$V = V_i \frac{R - Z_c}{R + Z_c}$$

LIGHTNING ARRESTER IS UTILIZED TO ABSORB THE TRANSIENT OVER VOLTAGE



WHEN THE ELECTRIC STRENGTH OF 30 kV/cm EXCEEDS, THE BREAK DOWN WILL OCCUR.

$$L = 200 \text{ H}$$

$$C = 5 \text{ pF}$$

$$R = 2000 \Omega$$

$$V_i = 33 \text{ kV}$$

$$Z_c = \sqrt{\frac{200}{5 \times 10^{-6}}}$$

$$= \sqrt{40 \times 10^6}$$

$$= 6.32 \times 10^3$$

$$V = 33 \times \frac{200 - 6.32 \times 10^3}{200 + 6.32 \times 10^3}$$

$$= 33 \times \frac{(-6120)}{6520} = -30.9$$

$$\therefore V_T = V + V_i = 33 + 30.9 = 63.9 \text{ kV}$$

$= 30.9 \text{ TRAY}$

Types of
OIL IMP
POLY E
THE TRANS

