

pb A 250 MVA, 25 KV 3 ϕ STEAM TURBINE GENERATOR HAS A SYNCHRONOUS REACTANCE OF 1.6 pu AND A TRANSIENT REACTANCE X_d' OF 0.23 p.u. IT DELIVERS ITS RATED OUTPUT AT A POWER FACTOR OF 100%. A SHORT CIRCUIT SUDDENLY OCCURS ON THE LINE CLOSE TO GENERATING STATION.

CALCULATE (a) BASE IMPEDANCE

(b) RATED VOLTAGE DROP

(c) TRANSIENT REACTANCE


(d) INITIAL SHORT CIRCUIT CURRENT

(e) STEADY VALUE OF CURRENT AT SHORT CIRCUIT.

$$(a) \text{ BASE IMPEDANCE} = \frac{E_{\text{BASE}}^2}{S_{\text{BASE}}} = \frac{(25000)^2}{250 \times 10^6} = 2.5 \Omega$$

$$(b) \text{ RATED VOLTAGE DROP} = \text{RATED CURRENT} \times \text{IMPEDANCE}$$


E_f = GENERATED VOLTAGE



I_{RATED}

$X_s =$

HAS A
REACTANCE
AT A
ON THE



$$I_{RATED} = \frac{S_{BASE}}{\sqrt{3} \times E_{BASE}}$$

$$= \frac{250 \times 10^6}{1.7321 \times 25 \times 10^3}$$

$$= 5771 \text{ Amp}$$

$$X_s = 1.6 \text{ p.u.}$$

$$= 1.6 \times 2.5$$

$$= 4 \Omega$$

← BASE IMPEDANCE

ULT.

$$\frac{(25000)^2}{250 \times 10^6}$$

$$2.5 \Omega$$

IMPEDANCE

$$\text{RATED VOLTAGE DROP} = I_{RATED} \times X_s$$

$$= 5771 \times 4$$

$$= 23100 \text{ V}$$

$$= 23.1 \text{ kV}$$


(c) TRANSIENT REACTANCE

$$X_d' = X_d'(\text{p.u.}) \times Z_{BASE}$$

$$= 0.23 \times 2.5 \Omega$$

$$= 0.575 \Omega$$

(d) SHORT CIRCUIT



$E_f = ?$

$E_f =$

INIT

(e) ST
SH

$$E_{BASE(ph)} = \frac{E_{BASE}}{\sqrt{3}} = \frac{25 \text{ kV}}{\sqrt{3}} = 14.4 \text{ kV}$$

$E_f = ?$

$$E_f = \sqrt{(E_{BASE(ph)})^2 + (I X_{S(ph)})^2}$$

$$= \sqrt{(14.4)^2 + (23.1)^2}$$

$$= 27.2 \text{ kV}$$

INITIAL SHORT CIRCUIT CURRENT

$$= \frac{E_f}{X_d}$$

$$= \frac{27.2 \times 10^3}{0.575}$$

$$= 47300 \text{ A}$$

$$= 47.3 \text{ kA}$$

(Q) STEADY STATE SHORT CIRCUIT CURRENT

$$= \frac{E_f}{X_s} = \frac{27.2 \times 10^3}{4}$$


$$= 6800 \text{ A}$$

$$= 6.8 \text{ kA}$$

GENERATOR CONTROL LOAD FLOW

pb AN ISOLATED 75 MVA SYNCHRONOUS GENERATOR FEEDS IT'S OWN LOAD AND OPERATES INITIALLY AT NO LOAD AT 3000 RPM, 50 Hz. A 20 MW LOAD IS SUDDENLY APPLIED AND THE STEAM VALVE TO THE TURBINE COMMENCE TO OPEN AFTER 0.5 sec DUE TO THE TIME LAG IN THE GOVERNOR SYSTEM.

CALCULATE THE FREQUENCY TO WHICH THE GENERATED VOLTAGE DROPS BEFORE THE STEAM FLOW MEETS THE NEW LOAD. THE STORED ENERGY FOR THE MACHINE IS 4 KW-S PER KVA OF GENERATOR'S CAPACITY.



$$f = \sqrt{\frac{\text{NO LOAD STORED ENERGY} - \text{APPLIED LOAD ENERGY}}{\text{NO LOAD STORED ENERGY}}} \times \text{RATED FREQUENCY}$$

$$E_{BASE(PH)} = \frac{E_{BASE}}{\sqrt{3}} = \frac{25 \text{ kV}}{\sqrt{3}} = 14.4 \text{ kV}$$

$$E_{BASE(PH)}^2 + (I X_S)^2$$

$$14.4^2 + (23.1)^2$$

$$2 \text{ kV}$$

$$\begin{aligned} \text{RT CIRCUIT} &= \frac{E_f}{X_d} \\ &= \frac{27.2 \times 10^3}{0.575} \\ &= 47300 \text{ A} \\ &= 47.3 \text{ kA} \end{aligned}$$


$$\begin{aligned} \text{UIT} &= \frac{E_f}{X_s} = \frac{27.2 \times 10^3}{4} \\ &= 6800 \text{ A} \\ &= 6.8 \text{ kA} \end{aligned}$$

GENERATOR CONTROL LOAD FLOW

pb AN ISOLATED 75 MVA SYNCHRONOUS GENERATOR FEEDS IT'S OWN LOAD AND OPERATES INITIALLY AT NO LOAD AT 3000 RPM, 50 Hz.

A 20 MW LOAD IS SUDDENLY APPLIED AND THE STEAM VALVE TO THE TURBINE COMMENCE TO OPEN AFTER 0.5 SEC DUE TO THE TIME LAG IN THE GOVERNOR SYSTEM.

CALCULATE THE FREQUENCY TO WHICH THE GENERATED VOLTAGE DROPS BEFORE THE STEAM FLOW MEETS THE NEW LOAD. THE STORED ENERGY FOR THE MACHINE IS 4 KW-S PER KVA OF GENERATOR'S CAPACITY.



$$f = \sqrt{\frac{\text{NO LOAD STORED ENERGY} - \text{APPLIED LOAD ENERGY}}{\text{NO LOAD STORED ENERGY}}} \times \text{RATED FREQUENCY}$$

NO LOAD STORED

APPLIED LOAD

GENERATOR FEEDS ITS OWN LOAD

AT 3000 RPM, 50 Hz.

AND THE STEAM VALVE

AFTER 0.5 SEC DUE TO
SYSTEM.

THE GENERATED VOLTAGE
THE NEW LOAD. THE
4 KW-S PER KVA OF

LOAD

$$\frac{\text{NO LOAD STORED ENERGY} - \text{APPLIED LOAD ENERGY}}{\text{NO LOAD STORED ENERGY}} \times \text{RATED FREQUENCY}$$

$$\text{NO LOAD STORED ENERGY} = \frac{\text{KW-S}}{\text{KVA}} \times \text{MACHINE CAPACITY KVA}$$

$$= 4 \times 75 \times 10^3 \text{ KVA}$$

$$= 300 \times 10^3 \text{ KVA}$$

$$\text{APPLIED LOAD ENERGY} = \text{POWER OF APPLIED LOAD} \times \text{TIME}$$

$$= 20 \times 10^3 \text{ KW} \times 0.5$$

$$= 10 \times 10^3 \text{ KW}$$

TIME LAG IN
GOVERNOR
SYSTEM

$$f = \sqrt{\frac{(300 \times 10^3 - 10 \times 10^3)}{300 \times 10^3}} \times 50$$

$$= 49.2 \text{ Hz}$$

$$\sqrt{\frac{300-10}{300}} \times 50$$

$$\sqrt{\frac{290}{300}} \times 50$$

ph Two

ENDS O

AND WI

IS TO

CALCULA

OF CUR



POWER TR

PER P

VOLTAGE D


DUE TO P

TRANSF

CAPACITY

TIME LAG IN
GOVERNOR
SYSTEM

Two units of generation maintain 66 kV and 60 kV line at the ends of an interconnector of inductive reactance per phase of 40Ω and with negligible resistance and short capacitance. A load of 10 MW is to be transferred from the 66 kV unit to the other end. Calculate the necessary condition between two ends including p.f. of current transmitted.



$$\text{Power Transfer per phase } (\Delta P) = \frac{10 \times 10^6}{3} = 3.33 \times 10^6 \text{ WATT}$$

$$\begin{aligned} \text{Voltage Difference due to power transfer} &= V_Q = \frac{X \times \Delta P}{V_R (\text{ph})} \\ &= \frac{40 \times 3.33 \times 10^6}{60 \times 10^3} \\ &= 3840 \text{ V} \end{aligned}$$

$$\sqrt{\frac{300-10}{300}} \times 50$$

$$\sqrt{\frac{290}{300}} \times 50$$

$$\sin \delta = \frac{\Delta V_Q}{V_S} = \frac{3840}{\frac{66,000}{\sqrt{3}}} = 0.101$$

$$\delta = \sin^{-1} 0.101 = 5.44^\circ$$

Reactive power transfer

$$\begin{aligned} \Delta Q &= \frac{E_S (\text{ph}) \times E_R (\text{ph})}{X} \\ &= \frac{\frac{66,000}{\sqrt{3}} \times \frac{60,000}{\sqrt{3}}}{40} \\ &= 33 \times 10^6 \text{ VAR} \end{aligned}$$


$$\tan \phi = \frac{\Delta Q}{\Delta P}$$

$$= \frac{33 \times 10^6}{3.33 \times 10^6} = 10$$

$$\phi = \tan^{-1} 10 = 84.2^\circ$$

$$\text{PF} = \cos \phi = \cos 84.2^\circ = 0.1$$

FREQUENCY
+
SPEED CONTROL



$\Delta P' =$ CHANGE IN
SPEED CHANGER
SETTING

TG - SPEED GOVERNING SYSTEM

$\Delta PW =$ STEAM
POWER CHANGE

$T_s =$ TURBINE

$\Delta P =$ CHANGE IN
TURBINE MECHANICAL
POWER OUTPUT

$m_s =$ GENERATOR INERTIA

$\Delta \delta =$ CHANGE IN POWER
ANGLE

→ SPEED

$R =$ SPEED REGULATION
(OR) GOVERNOR DROP

$$s \delta = \frac{1}{m}$$

$$K = \text{CONSTANT}$$

$$\Delta PL =$$

$$s \delta =$$

$$s\delta = \frac{1}{M_s + K} (\Delta P - \Delta P_L)$$

$K = \text{CONSTANT}$


$\Delta P_L = \text{CHANGE IN PRIME MOVER AND LOAD POWER}$

$s\delta = \text{CHANGE FROM NORMAL SPEED (OR) FREQUENCY}$

EQUALIZATION
ERROR DROP


METHODS OF VOLTAGE CONTROL

- (i) INJECTION OF REACTIVE POWER
- (ii) SHUNT CAPACITORS AND REACTORS
- (iii) SERIES CAPACITOR
- (iv) SYNCHRONOUS COMPENSATOR




AVR - AUTOMATIC VOLTAGE REGULATOR

TAP CHANGING




METHODS OF VOLTAGE CONTROL



- (i) INJECTION OF REACTIVE POWER
- (ii) SHUNT CAPACITORS AND REACTORS
- (iii) SERIES CAPACITOR
- (iv) SYNCHRONOUS COMPENSATOR



AVR - AUTOMATIC VOLTAGE REGULATOR


TAP CHANGING TRANSFORMER






CONTROL INPUT


LOCATION OF TAP CHANGER IN POWER SYSTEM




BOOSTER TRANSFORMER



PHASE SHIFT TRANSFORMER




VOLTAGE CONTROL IN DISTRIBUTION



SYNCHRONIZING


- THE PROCESS OF SYN
- THE FREQUENCY OF INCOMING MACHINE OF LIVE BUSBAR.
 - THE INDUCED VOLTAGE BE EQUAL TO THE AND PHASE.

TAP CHANGER IN POWER SYSTEM




FORMER

PHASE SHIFT TRANSFORMER



VOLTAGE CONTROL IN DISTRIBUTION NETWORK




SYNCHRONIZING

THE PROCESS OF SYNCHRONIZING IS

- THE FREQUENCY OF THE INDUCED VOLTAGES IN THE INCOMING MACHINE MUST BE EQUAL TO THE FREQUENCY OF LIVE BUSBAR.
- THE INDUCED VOLTAGE IN THE INCOMING MACHINE MUST BE EQUAL TO THE LIVE BUSBAR VOLTAGES IN MAGNITUDE AND PHASE.

(c) PHASE SEQUENCE
MACHINE VOLT

DIGITAL EXCITATION




A/D - ANALOG
TO
DIGITAL
CONVERTER


D/A - DIGITAL TO ANALOG
CONVERTER

THE OUTPUT
BEFORE GENERATING
THE OUTPUT
CONVERTER


GENERATOR IN POWER SYSTEM



PHASE SHIFT TRANSFORMER



VOLTAGE CONTROL IN DISTRIBUTION NETWORK




SYNCHRONIZING

THE PROCESS OF SYNCHRONIZING IS

- THE FREQUENCY OF THE INDUCED VOLTAGES IN THE INCOMING MACHINE MUST BE EQUAL TO THE FREQUENCY OF LIVE BUSBAR.
- THE INDUCED VOLTAGE IN THE INCOMING MACHINE MUST BE EQUAL TO THE LIVE BUSBAR VOLTAGES IN MAGNITUDE AND PHASE.


(c) PHASE SEQUENCE OF MACHINE VOLTAGE

DIGITAL EXCITATION



THE OUTPUT FIRST BEFORE GENERATING THE OUTPUT SIGNAL CONVERTER.


IN DISTRIBUTION NETWORK



SYNCHRONIZING IS
 OF THE INDUCED VOLTAGES IN THE
 ING MUST BE EQUAL TO THE FREQUENCY
 VOLTAGE IN THE INCOMING MACHINE MUST
 THE LIVE BUSBAR VOLTAGES IN MAGNITUDE


(c) PHASE SEQUENCE OF BUSBAR VOLTAGE AND INCOMING
 MACHINE VOLTAGE MUST BE SAME.


DIGITAL EXCITATION SYSTEM




THE OUT PUT FIRST GOES TO D/A CONVERTER THROUGH POWER SHAPE
 BEFORE GENERATING THE OUT PUT CONTROL SIGNAL.
 THE OUT PUT SIGNAL IS APPLIED TO INPUT THROUGH A/D
 CONVERTER.

OVER VIEW OF STEAM TURBINE SYSTEM (NUCLEAR/BOILER/)







BASIC HYDRO-ELECTRIC POWER SYSTEM




Computer Control



TRIC POWER SYSTEM




Computer Control



THE DIGITAL

- CONFIRM TI
- ARE IN A
- PERFORM
- ESTABLISH
- LIGHTS AN
- ACCELERAT
- SYSTEM P
- THE FOLLOW
- ARITH ME
- MEMOR
- INTERRU
- CONTACT
- ANALOG
- OUT PU
- DIREC




THE DIGITAL COMPUTER CONTROL SYSTEM PERFORMS THE FOLLOWING

- CONFIRM THAT PRESENT CONDITIONS (TEMPERATURE, LEVEL, VALUE SETTINGS) ARE IN ACCORDANCE WITH PROPER SETTING
- PERFORM TURBINE TRIP TEST
- ESTABLISH THE WATER CIRCULATION AND AIR FLOW THROUGH FURNACE
- LIGHTS AND BURNERS
- ACCELERATION THE TURBINE UP TO 3600 RPM, SYNCHRONIZES TO SYSTEM FREQUENCY AND LOADING THE GENERATOR

THE FOLLOWING SYSTEMS ARE INCLUDED

- ARITHMETIC | CONTROL UNIT
- MEMORY UNIT
- INTERRUPT CONTROL UNIT
- CONTACT INPUT CONTROL UNIT
- ANALOG | DIGITAL CONVERTER
- OUTPUT CONTROL UNITS
- DIRECT DIGITAL CONTROL (DDC)

- SEQUENCE CONTROL
- SEQUENCE MONITOR TO KNOW THE SY
- PERFORMANCE CA
- BOILER EFFICI
- TURBINE E
- FEED WATER
- CONDENSER
- OVER ALL C



FOLLOWING
(E, LEVEL, VALUE SETTINGS)

FLOW THROUGH FURNACE


PM, SYNCHRONIZES TO
ATOR.

- SEQUENCE CONTROL IS IMPORTANT DURING START UP AND SHUT DOWN.
- SEQUENCE MONITORING IS IMPORTANT FOR STARTUP AND SHUT DOWN TO KNOW THE SYSTEM CONDITIONS.

- PERFORMANCE CALCULATION

- BOILER EFFICIENCY
- TURBINE EFFICIENCY
- FEED WATER HEATER PERFORMANCE
- CONDENSER PERFORMANCE
- OVER ALL CYCLE HEAT RATE.

LUBRICATING / COOLING



PERFORMANCE

COMPUTER PERFORMANCE

(a) RELIABILITY

- ON LINE COMPUTE

UNLESS DEFIN

- RELIABILITY OF

EXPERIENCE

TURBINE COM

CASING, BU

GOVERNOR U

TURBINE IN

SPINDLE ALL

SHAFT VIBRA

SPINDLE /

CYLINDER


SHUT DOWN.

AND SHUT DOWN

ATING / COOLING

COMPRESSOR

TURBINE
GOVERNOR



COMPRESSOR

PERFORMANCE OF COMPUTER

COMPUTER PERFORMANCE SHOULD BE RATED ACCORDING TO
(a) RELIABILITY (b) SPEED (c) MEMORY STORAGE

- ON LINE COMPUTERS CAN NOT DEAL WITH A REAL TIME PROBLEM UNLESS DEFINED ACTIONS ARE STORED AND ARE AVAILABLE WHEN NEEDED.
- RELIABILITY OF COMPUTERS SHOULD BE EVALUATED IN ACTUAL FIELD EXPERIENCE

TURBINE COMPONENTS

CASING, BUCKET, SEAL, GLAND, BEARINGS, BOLT, PIPING
GOVERNOR VALVE.

TURBINE INSTRUMENTATION

SPINDLE ACCELERATION METER

SHAFT VIBRATION METER

SPINDLE POSITION METER

CYLINDER EXPANSION METER


- SPEED AND GOVERNOR VALVE POSITION METER

- BEARING CONDITION


- STEAM CONDITION

- GLAND SPEED CONDITION.

pb



CALCULATE ACTIVE POWER FLOW OVER THE LINE AND
THE CONNECTING LINE HAS INDUCTIVE REACTANCE
 14Ω .



$$P = \frac{E_1 E_2}{X_s} \sin \delta$$

$$= \frac{20 \times 15}{14} \sin (42 - 5)$$

$$= \frac{300}{14} \sin 37 = 12.9 \text{ MW}$$

MAIN FEEDER

MAIN FEEDER 1

THE FEEDER CAP

FACILITY CABLE

SECTIONALIZATION

SEPARATION

RE-CLOSER

AUTOMATIC, H
THE TROUBLE

LOAD BALANCE

BALANCING

VOLTAGE REG

ELECTRIC

BOOSTER

TO COM

MAIN FEEDER

MAIN FEEDER IS THE FIRST FACILITY CABLE COMING FROM THE DISTRIBUTION SUBSTATION. THE FEEDER CABLE RUNS TO CROSS CONNECT POINTS IN THE NETWORK WHERE THE SECOND FACILITY CABLE FEEDS ARE CONNECTED.

SECTIONALIZATION

SEPARATION BY THE CREATION OF BOUNDARY THAT DIVIDES (OR) KEEPS APART

RE-CLOSER

AUTOMATIC, HIGH VOLTAGE ELECTRIC SWITCH. IT AUTOMATICALLY RECLOSES WHEN THE TROUBLE IN LINE HAS BEEN REMOVED.

LOAD BALANCING

BALANCING THE LOADS DRAWN FROM THE FEEDER

VOLTAGE REGULATOR

ELECTRIC REGULATOR DESIGNED TO AUTOMATICALLY MAINTAIN A CONSTANT VOLTAGE LEVEL

BOOSTER

TO COMPENSATE THE VOLTAGE DROP IN LINE, MOTOR GENERATOR SET FOR VOLTAGE REGULATION.

ANALOG
SIGNAL

ANALOG
INPUT
CONTROL
UNIT

CONTACT

DIGITAL
INPUT